

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI- 110001**

No F 6/DFS/MS/CNG/2023/SZ/278

Dated 06/06/2023

**FIRE SAFETY CERTIFICATE**

Certified that the M/s Indraprastha Gas Limited Retail Outlet (CNG Pump) located at Vasant Kunj, New Delhi Comprised of Ground plus one upper Floor only owned/occupied by M/s Indraprastha Gas Limited, was issued FSC by this department vide letter no F6/DFS/MS/CNG/2020/SZ/257 Dated 16/07/2020. The premise was re-inspected by the officer concerned of this department on 28.05.2023 in the presence of Mr. Prahlad Kumar (Manager) of the said filling station and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for (03 Cascade at roof of the office building, 02 Compressor Unit & 05 Nos Dispensing Unit) occupancy class Storage (CNG Pump) with effect from 06/06/2023 for a period of three years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010.

Issued on 06/06/2023 at New Delhi by

(A. H. GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to -

1. The Joint C.P (Lic/Unit) First Floor, PS Defence Colony, New Delhi 110049
2. Sh. Ajay Khatri, DGM-(Fire & Safety) (IGL) LGL Bhawan, Plot No 4, Community Centre, R. K Puram, Sector- 09, New Delhi 110049

**Conditions for the validity of Fire Safety Certificate -**

1. All the means of escape/entry/exit shall be kept free from any obstruction
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management
3. All the staff members must know the correct method of operation of fire fighting system.
4. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry



## INSPECTION REPORT

1	Name & Address of the Building	Indraprastha Gas Ltd. Retail outlet (CNG pumps) Vasant Kunj New Delhi		
2	Type of Occupancy	Storage (CNG Pump) 03 Cascades at roof of the office building 02 compressor unit & 05 nos Dispensing unit		
3	Building Comprised of	Ground plus one upper floor only		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/CNG/2020/SZ/257 Dated 16/07/2020		
6	Fire Safety Directives Letter No	F6/DFS/MS/CNG/2011/85 dated 25/03/2011		
7	Date of Inspection	28-05-2023		
8	Name of the Inspecting Officers	Mr. Rajesh Kumar (ADO BCP)		
9	Name & Designation of Officers from the building side	Mr. Prahlad Kumar (Manager)		
10	Year of construction	2011		
11	Applicant letter No.	IGL/F&S/2023/15/58/1 Dated 15-05-2023		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	Old NOC Requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	09 mtr	12 mtr	MR
	• Gate width	-NA-	-NA-	-NA-
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	• Upper floors	01 nos	02 Nos	MR ✓
	• Basement floor	-NA-	-NA-	-NA-
	b. Width of Staircase			
	• Upper floors	1.25m / 0.70m	1.25m & 0.70m	MR ✓
	• Basement floor	-NA-	-NA-	-NA-
	c. Protection of exits			
	• Fire check door	-NA-	-NA-	-NA-
	• Pressurization	-NA-	-NA-	-NA-
	d. No. of continuous staircase to terrace	-NA-	-NA-	-NA-
	e. Width of corridor	-NA-	-NA-	-NA-
	f. Door size	1m	Provided	MR
3	Compartmentation.			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire rating of shaft door	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers	-NA-	-NA-	-NA-
4	Smoke Management system.			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
5	Fire Extinguishers.			
	• Total numbers	20 mtr	25 Nos	MR
	• Types	ISI Marked	DCP/75 kg- 03, DCP/10kg - 18 & 4.5 KG- 04	MR ✓
	• ISI Marking		Provided	MR
6	First Aid Hose Reels.			
	• Total numbers on each floor	-NA-	-NA-	-NA-
	• Length of hose-reel hose	-NA-	-NA-	-NA-
	• Nozzle Diameter	-NA-	-NA-	-NA-

N/13

N/15

7	<b>Automatic Fire Detection and Alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>	Gas & Flame	Provided in compressors	MR
		Required	Ground floor	MR
		-NA-	-NA-	-NA-
		Required	Provided	MR
		Required	Technician room	MR
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors</li> <li>Sprinkler above false ceiling</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> <li>Size of Riser / Down-comer</li> <li>Number of Hydrant per floor</li> <li>Hose box</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> <li>Total number of hydrants.</li> <li>Hose box</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>			
	➤ Discharge of main pump	-NA-	-NA-	-NA-
	➤ Head of main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump output	-NA-	-NA-	-NA-
	➤ Jockey Pump head	-NA-	-NA-	-NA-
	➤ Standby Pump output	-NA-	-NA-	-NA-
	➤ Standby Pump head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Terrace Level</li> </ul>			
	➤ Discharge of pump	-NA-	-NA-	-NA-
	➤ Head of pump	-NA-	-NA-	-NA-
	➤ Power supply	-NA-	-NA-	-NA-
	➤ Auto starting of pump	-NA-	-NA-	-NA-
14.	Captive water storage for fire-fighting.			
	<ul style="list-style-type: none"> <li>Underground tank capacity               <ul style="list-style-type: none"> <li>➤ Draw-off connection</li> <li>➤ Fire Service Inlet</li> <li>➤ Access to tank</li> </ul> </li> <li>Overhead tank capacity</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
15.	No Smoking signage	Required	Provided in Hindi & English	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft</li> <li>Pressurization of lift lobby</li> <li>Communication in lift car</li> <li>Fireman's switch</li> <li>Lift signage</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
17	Standby Power Supply	NA	Provided (DG Set)	NA
18.	Refuge Area			
	<ul style="list-style-type: none"> <li>Total area</li> <li>Location</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-



9.	Fire Control Room.			
	<ul style="list-style-type: none"> <li>• Detector System Panel.</li> <li>• Flow Switch Panel</li> <li>• PA system Panel.</li> <li>• Battery backup</li> <li>• Building floor plan</li> </ul>	-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
		-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	Co2 flooding system connected through detectors provided in each compressor unit		MR ✓

"No Smoking" Sign boards were found displayed both in Hindi & English at conspicuous places. No loose electric wiring was seen in the premises.

The fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under rules, renewal of the FSC issued vide letter No. F-6/DFS/MS/CNG/2020/SZ/257 Dated 16/07/2020, under rules 37 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly, DFA is put up for perusal and signature please

*[Signature]*  
 Signature of the Inspecting Officer  
 Name: Mr. Rajesh Kumar  
 Designation: ADO (BCP)

DO (SD)

*[Signature]*  
 07/16

*[Signature]*  
 01/06/2023

*[Signature]*  
 2/06/23

*[Signature]*

As approved, F.T. letter is put up for your signature pl  
*[Signature]*  
 21/6/2023

*[Signature]*  
 21/6/23