



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2023/School/ 402

Dated: 09/06/2023

**FIRE SAFETY CERTIFICATE**

Certified that the Mount Olivet Sr. Sec. School located at Street No.100, B-Block, Sant Nagar, Burari, Delhi-110084 comprised of 02 blocks (Ground & 03 upper floors interconnected) owned/ occupied by the Mount Olivet Sr. Sec. School was issued fire safety certificate vide this office letter no. F6/DFS/MS/2019/School/2366 dated 24.012.2019. The premises was re-inspected by the officer concerned of this department on 02.06.2023 in presence of Mr. Pranav Kumar (Admin) and observed that all the fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education vide letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy class **Group B Educational** with effect from 09/06/2023... for a period of **Valid up to 31.03.2026** subject to compliance of the conditions mentioned below:

Issued on ...09/06/2023... at New Delhi

(Atul Garg)  
Director  
Ph:-011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Mount Olivet Sr. Sec. School located at Street No.100, B-Block, Sant Nagar, Burari, Delhi-110084.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doiit fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

# INSPECTION REPORT

- 1 Name & address of the building : Mount Olivet Sr. Sec. School at Street no. 100, B-Block, Sant Nagar, Burari Delhi-110084
- 2 Type of Occupancy : Educational
- 3 Type of Case : Renewal
- 4 Composition of building : Two blocks -(Ground & 03 upper floors-Interconnected )
- 5 Details of previous NOC : F6/DFS/MS/2019/School/2366 Dated 24.12.2019
- 6 Fire Safety directives letter No : Nil
- 7 Date of inspection : 02.06.2023
- 8 Name of the Inspecting Officers : ADO (RN)
- 9 Name and designation of officers from the building side : Mr. Pranav Kumar (Admin)
10. Year of Construction : 1997
11. Applicant's letter No. : Letter No. MO/23/05/SSS/2023-2396 Dated 23.05.2023

	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Rule 35 (6)	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	04nos	04nos	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.60m, 1.50m, 1.10m & 1.05m	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	NA	1.70m	NA
	f. Door Size	1m	1m	MR
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilated	MR
5	<b>Fire Extinguishers</b>			
	• Total numbers	10nos	16nos	MR
	• Types	ABC	ABC-16	MR
	• ISI marking	ISI Marked	Yes	MR
6	<b>First-Aid Hose Reels.</b>			

*[Handwritten signature]*



		01	02	MR
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	30m	30m	MR
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	5mm	5mm	MR
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>			
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hooters' Location</li> </ul>	NA	NA	NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>			
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	NA	NA	NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	100mm	100mm	MR
	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	01	01	MR
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	01	01	MR
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level               <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> </ul>	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
	<ul style="list-style-type: none"> <li>Terrace level               <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	450 LPM	450 LPM	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Draw-off connection</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Fire service inlet</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Access to tank</li> </ul>	NA	NA	NA
	<ul style="list-style-type: none"> <li>Overhead Tank capacity</li> </ul>	10,000 LTR	10,000 LTR	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> </ul>	N/A	N/A	N/A

	<ul style="list-style-type: none"> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> <li>Detector System Panel</li> <li>Flow Switch Panel</li> <li>PA System Panel</li> <li>Batter backup</li> <li>Building Floor Plans</li> </ul>	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in good working condition, at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. F6/DFS/MS/2019/School/2366 dated 24.12.2019.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular dated 01.03.2011 the FSC issued vide letter of even no. F6/DFS/MS/2019/School/2366 dated 24.01.2019 renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended

*[Signature]*  
02/06/2023  
D.B. Mukharjee  
Divisional Officer (NWD)

*[Signature]*  
03/06/2023  
Signature of the Inspecting Officer  
Name: - C.L. Meena  
Designation: Asst. Div. Officer (RN)

*[Signature]*  
5/6/2023  
Director

*[Signature]*  
01/06/23  
Director

As approved, F.T. letter is set up for your signature pl.

*[Signature]*  
04/06/2023  
Asst. Div. Officer