

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the Name & Style of M/S Aslam Chicken Corner located at 972, 973 and 985, Ground & First Floor, Bazar Matia Mahal, Jama Masjid, Delhi, in the building comprised of Ground + 03 upper floor owned/ occupied by Aslam Chicken Corner have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 23.05.2023 in the presence of Mohd. Arbaaz (Owner) and that the premises is fit for occupancy class "Group - D Assembly" (Restaurant Running at Ground & 1st floor only) with effect from 07/06/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to conditions under Rule 38 of Delhi Fire Service Rules, 2010 printed below.

Issued on 07/06/2023 at New Delhi by


(Atul Garg)
Director
Delhi Fire Service
Tel: 011-23414000

Copy to:-

1. The Joint Commissioner of Police (Licensing), 1st Floor, Police Station Defence Colony, New Delhi: - Ref. MHA Portal ID. No. 2023051508949 dated 15.05.2023.
2. The Commissioner, Municipal Corporation of Delhi, Minto Road, New Delhi.
3. The Manager, M/S Aslam Chicken Corner at 972, 973 and 985, Ground & First Floor, Bazar Matia Mahal, Jama Masjid, Delhi.

Condition for the validity of fire safety certificate

1. This FSC is valid for ground & first floor only.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub Rule (I) of Rule 37] along with a copy of this Certificate, six month prior to its expiry. Any change in the occupancy shall be intimated to this Deptt. and approval shall be obtained thereto before occupancy of the same.

INSPECTION REPORT

1	Name & address of the building	M/S Aslam Chiken Corner located at 972, 973 & 985, Ground & First Floor, Bazaar Matia Mahal, Jama Masjid, Delhi -06.		
2	Building is comprised of	Ground + 03 upper floors (Restaurant Running at GF & FF floor only) 2 nd & 3 rd floor- Owner's residence		
3	Type of occupancy	Assembly Building (Group-D)		
4	Type of case	New Case		
5	Details of previous FSC	NA		
6	Fire safety direction letter no.	UBBL-2016/ NBC Part-IV-2016		
7	Date of inspection	23.05.2023		
8	Name of the inspecting officers	Rajinder Atwal DO (CD) & Sumit Kumar ADO (SPM)		
9	Name of the designation of officer from the building side	Mohd. Arbaaz (Owner)		
10	Year of construction	2002		
11	Applicant's letter no.	Online application no. 2023051508949 dated 15.05.2023		
S.No	Minimum Standards on fire Prevention and fire safety requirements U/R 33	UBBL/ NBC Part-IV-2016	Provided at Site	Remarks MR/ NMR
1	Access To Building:			
	Road width	06	Provided	MR
	Gate width	NA	NA	NA
	Width of internal road	NA	NA	NA
2	Number, Width, Type and Arrangement of Exits:			
	A Number of staircases			
	a Upper floor	02 nos.	02 nos.	MR ✓
	b Basement	NA	NA	NA
	B Width of staircases			
	a Upper floor	1.5 mtr. each	1.5 mtrs. each	MR ✓
	b Basement	NA	NA	NA
	C Protection of exits			
	a Fire check door	NA	NA	NA
	b Pressurization	NA	NA	NA
	D No. of continuous staircases to terrace	01 nos.	01 nos.	MR ✓
	E Width of corridor	NA	NA	NA
	F Door size	1.5 mtrs. - 02 nos.	Provided	MR
3	Compartmentation:			
	A Fire check door	NA	NA	NA
	B Sealing of electrical shafts	NA	NA	NA
	C Fire rating of shaft door	NA	NA	NA
	D Water curtain	NA	NA	NA
	E Fire dampers	NA	NA	NA
4	Smoke Management System:			
	A Upper floors	12 ACPH	Natural/ Ventilation	MR
	B Basements	NA	NA	NA

e 8 6 50

- N/3 -


5. Fire Extinguisher:				
A	Total numbers	10 nos.	10 nos.	MR
B	Types	ABC & Co2	ABC & Co2	MR
C	ISI marking	Required	Provided	MR
6 First-Aid-Hose Reels:				
A	Total numbers of each floor	01 nos.	01 nos.	MR
B	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
C	Nozzle diameter	5 mm	5 mm	MR
7 Automatic Fire Detection And Alarming System:				
A	Type of detectors	NA	NA	NA
B	Location of main panel	NA	NA	NA
C	Location of repeater panel	NA	NA	NA
D	Alternate source of power	NA	NA	NA
E	Hooters Location	NA	NA	NA
8	MOEFA:	Required	Provided	MR
9	Public Address System:	NA	NA	NA
10 Automatic Sprinkler System:				
A	Basement	NA	NA	NA
B	Upper floor	NA	NA	NA
C	Sprinkler above false ceiling	NA	NA	NA
11 Internal Hydrants:				
A	size of riser/down-comer	100 mm	Provided	MR
B	Number of hydrants per floor	01 no.	01 no.	MR
C	Hose box	01 no.	01 no.	MR
12 Yard Hydrants:				
A	Total number of hydrants	NA	NA	NA
B	Hose box	NA	NA	NA
13 Pumping Arrangements:				
A	Ground level			
a)	Discharge of main pump	NA	NA	NA
b)	Head of main pump	NA	NA	NA
c)	Number of main pumps	NA	NA	NA
d)	Jockey pump out put	NA	NA	NA
e)	Jockey pump head	NA	NA	NA
f)	Standby pump out put	NA	NA	NA
g)	Standby pump head	NA	NA	NA
h)	Auto starting /manual stopping	NA	NA	NA
B	Terrace level			
a)	Discharge of pump	450 LPM	450 LPM	MR
b)	Head of the pump	40 mtrs.	40 mtrs.	MR
c)	Power supply	Required	Provided	MR
d)	Auto starting of pump	Required	Provided	MR


8/ 6/ 50/

14	Captive Water Storage For Fire Fighting:			
A	Underground tank capacity	NA	NA	NA
B	Draw-off connection	NA	NA	NA
C	Fire service inlet	Required	Provided	MR
D	Access to tank	NA	NA	NA
E	Overhead tank capacity	20,000 ltrs.	Provided	MR
15	Exit Signage:	Required	Provided	MR
16	Provision of Lifts:			
A	Pressurization of lift shaft	NA	NA	NA
B	Pressurization of lift lobby	NA	NA	NA
C	Communication in lift car	NA	NA	NA
D	Firemen's grounding switch	NA	NA	NA
E	Lift signage	NA	NA	NA
17	Standby Power Supply:	Required	Provided	MR
18	Refuge Area:			
A	Total area	NA	NA	NA
B	Location	NA	NA	NA
19	Fire Control Room :			
A	Detector system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	Pa system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plans	NA	NA	NA
20	Special Fire Protection Systems For Protection of Special Risks, If Any:			NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections. Building is comprised of Ground plus four upper floors and terrace of fourth floor has been punctured at few locations and undertaking submitted that fourth floor will not be used for any purpose and the building is now comprised of ground plus three upper floors out of which second and third floor are being used as residence. Restaurant is running at ground and first floor only.


Keeping in view of the substantially satisfactory compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, it is recommended to grant Fire Safety Certificate to restaurant (Assembly Occupancy) at ground and first floor only under Rules 35(3) of the Delhi Fire Service Rules, 2010.



 Signature of the Inspecting Officer
 Name Rajinder Atwal
 Designation DO (CD)


 Signature of the Inspecting Officer
 Name Sumit Kumar
 Designation ADO (SPM)

~~Dy.CFO (NDZ)~~


 30/05/23

~~C.F.O. ~~
 31/5/2023

~~Director ~~
 11/06/23