

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI- 110001

No.F.6/DFS/MS/EH/2023/SZ/181

Dated: 12/06/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s KD FOODS running at second floor only in a building comprised of basement, ground plus three upper floors located at D-4, Rajouri Garden, New Delhi-110027, owned/occupied by M/s KD FOODS have complied with the fire prevention and fire safety requirements in accordance with the Rule 33 of the Delhi Fire Service Rule 2010 and verified by the officers concerned of this department on 02/06/2023 in the presence of Sh. Juned (Maintenance) and found that the building (Second floor only) is fit for occupancy 'Class D "Assembly Building"(Restaurant) ' for with effect from 12/06/2023 for a period of three years in accordance with the Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on.....12/06/2023.....at New Delhi by


(Atul Garg)
Director

Delhi Fire Service



Copy to:-

1. M/s KD FOODS, D-4, Second Floor, Rajouri Garden, New Delhi-110027.
2. The Joint Commissioner of Police, Licensing Unit, First Floor, Police Station, Defence Colony, New Delhi.

Following fire safety directives must be adhered to:-

- The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- All the means of escape shall be kept free of all the type of obstruction all the time.
- All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
- All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
- The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc may be got verified from the authorities concerned.
- This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.

The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : M/s KD FOODS, D-4, Second floor, Rajouri Garden, New Delhi-110027.
2. Building comprised of : Basement, ground plus three upper floors but eating house at second floor only.
3. Type of Occupancy : Assembly
4. Type of Case : New Case
5. Details of Previous NOC : F6/DFS/MS/Mercantile/2023/SZ/76 Dated 13/02/2023 (for entire building)
6. Fire Safety directives letter No : F6/MS/DFS/BP/2019/242 dated 21/06/2019
7. Date of inspection : 02/06/2023
8. Name of Inspecting Officers : A.D.O. R.K. Yadav and D.O. Vedpal Chhikara
9. Name and designation of officers
From the building side : Sh. Juned (Maintenance)
10. Year of Construction : 2022
11. Applicant's letter No. : ID No. 2023052309470 dated 23/05/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	12 m N/A N/A	provided On road N/A	MR MR N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> • Upper Floors • Basements 	Two N/A	Provided N/A	MR N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> • Upper Floor • Basements 	2 m & 1.5 m N/A	2 m & 1.5 m N/A	MR N/A
	c. Protection of exits			
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	Required N/A	Provided N/A	MR ✓ N/A
	d. No. of continuous staircases to terrace	Two N/A	Provided N/A	MR N/A
	e. Width of Corridor	2 m & 1.5 m	2 m & 1.5 m	MR
	f. Door Size			
3.	Compartmentation			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	Required Required N/A N/A N/A	Provided Sealed N/A N/A N/A	MR ✓ MR ✓ N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> • Basements • Upper floors 	N/A Required	N/A Provided	N/A MR
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	04 no.'s ABC & CO ₂ Type ISI marked	Provided Provided Provided	MR MR MR

N/G

6.	First-Aid Hose Reels	One	Provided	MR
	• Total numbers on each floor	30 m	Provided	MR
	• Length of hose reel hose	5 mm	Provided	MR
	• Nozzle diameter			
7.	Automatic fire detection and alarming system	N/A	Provided	N/A
	• Type of detectors	N/A	N/A	N/A
	• Location of Main Panel	N/A	N/A	N/A
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System	N/A	N/A	N/A
	• Basement	N/A	Provided	N/A
	• Ground Floor	N/A	N/A	N/A
	• Sprinkler above false ceiling			
11.	Internal Hydrants	100 MM	Provided	MR
	• Size of riser/down-comer	One	Provided	MR
	• Number of hydrants per floor	One	Provided	MR
	• Hose Box			
12.	Yard Hydrants	N/A	N/A	N/A
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box			
13.	Pumping Arrangements	Fire fighting system is common for entire building		
	• Ground Level			
	➢ Discharge of main Pump	2280 LPM	Provided	MR
	➢ Head of Main pump	60 m	Provided	MR
	➢ Number of main pumps	one	Provided	MR
	➢ Jockey Pump out put	180 LPM	Provided	MR
	➢ Jockey pump head	40 m	Provided	MR
	➢ Standby Pump out put	2280 LPM	Provided	MR
	➢ Standby Pump Head	60 m	Provided	MR
	➢ Auto Starting/Manual Stopping	Required	Provided	MR
	➢ Pump House Access	Required	Provided	MR
	• Terrace level			
	➢ Discharge of pump	900 LPM	Provided	MR
	➢ Head of the pump	40 m	Provided	MR
	➢ Power Supply	Required	Provided	MR
	➢ Auto Starting of pump	Required	Provided	MR
14.	Captive Water Storage for fire fighting			
	• Underground tank capacity	2,00,000 ltrs.	Provided	MR
	➢ Draw-off connection	Required	Provided	MR
	➢ Fire service inlet	N/A	N/A	N/A
	➢ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	30,000 Ltrs	Provided	MR
		Required	Provided	MR
15.	Exit Signage.			

(Handwritten signature)

Provision of Lifts

	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area.			
	<ul style="list-style-type: none"> > Total Area > Location 	N/A	N/A	N/A
		N/A	N/A	N/A
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:	Required	LT & HT Panel provided	MR

The FSC was already issued vide letter No. F6/DFS/MS/Mercantile/2023/SZ/76 dated 13/02/2023 for mercantile part only.

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The shortcomings issued vide letter No. F6/DFS/MS/EH/2023/SZ/264 dated 19/05/2023 has been complied.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under Rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer
 Name : R.K. Yadav
 Designation : ADO (JKP)

Signature of the Inspecting Officer
 Name : Vedpal Chhikara
 Designation : DO (SW)

CFO (HQ)

Handwritten notes and signatures:
 6/6/2023
 Director / 11/06/23
 AD O/DO = on c/l
 FT letter is put up for sign of
 DIRECTOR/DFS/11/06/23
 9/6/23
 001(S-W)
 FIPY