



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No.F6/DFS/MS/EH/NDZ/2023/ 183

Dated: 12/06/2023

FIRE SAFETY CERTIFICATE

Certified that the Pummy Food Zone Restaurant and Party Hall Located at Shop No.- 15, Ground & 1st Floor L.S.C.O & P Mkt., Dilshad Garden, Delhi-110095 owned / occupied by Pummy Food Zone Restaurant and Party Hall, was earlier issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/EH/2019/NDZ/756 Dated 08/04/2019. The premises was re-inspected by the officers concerned of this department on 02/06/2023 in the presence of Sh. Pravin Gupta and observed that all the Fire prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore, deemed complied with rule 33 of the Delhi Fire Service rules, 2010 and that the building / premises is fit for occupancy Class "Assembly" (Group-D) and valid up to 31/03/2026 (Three years) accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under 38 of the Delhi Fire Service rules, 2010.

Issued on 12/06/2023 at New Delhi.

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE.

Copy to:-

1. Joint Commissioner of Police (Lic.) P. S.: Defence Colony, New Delhi-110024 w.r.t. MHA portal ID-2023052509662 dated 27/05/2023.
2. Smt. Sunita Gupta, Pummy Food Zone Restaurant and Party Hall, Shop No.-15, Ground & 1st Floor L.S.C. O & P Mkt., Dilshad Garden, Delhi-110095.

Conditions for the validity of Fire Safety Certificate:-

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
3. The trained fire- fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhi.govt.nic.in.

INSPECTION REPORT

N/11

1. Name & address of the building : Pummy Food Zone Restaurant and Party Hall,
Shop No.-15, Ground & 1st Floor L.S.C. O & P
Mkt., Dilshad Garden, Delhi-110095.
2. Building is comprised of : Ground & 1st Floor only
3. Type of Occupancy : Assembly (Restaurant)
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/EH/2019/NDZ/756 Dated 08/04/2019
6. Fire Safety directives Letter No. : NBC (Part-IV)
7. Date of inspection : 02/06/2023
8. Name of the Inspecting Officer : A.K.Jaiswal D.O.(ED) & Yashwant Singh Meena,
ADO(LN)
9. Name and designation of Officer
From the building side : Mr. Pravin Gupta
10. Year of Construction : 2006
11. Applicant's MHA Portal No. : 2023052509662 dated 27/05/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC (Part-IV) Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	6.0 mtr	Provided	MR
	• Gate width	2.0 mtr	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	1	1	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.25m	1.25m	MR ✓
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	1	2	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	2.0 mtr	2.0 mtr	MR ✓
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	6	Provided	MR
	• Types	ISI marked ABC/CO ₂	Provided	MR
	• IS marking	Required	Provided	MR ✓

(u)

60

6.	First - Aid Hose Reels			
	• Total numbers on each floor	1	Provided	MR
	• Length of hose reel hose	30 mtr.	30 mtr.	MR
	• Nozzle diameter	5mm.	5mm.	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	1	Provided	MR
	• Hose Box	1	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	1	NA
	• Hose Box	NA	1	NA
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 LPM	Provided	MR
	➤ Head of the pump	40 MH	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 lts.	Provided	MR

		H/13		MR
		Required	Provided	
15.	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NR	NR	NR
	➤ Location	NR	NR	NR
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Note: - Basement is now closed by MCD (At present basement is not existing).

The fire protection system was randomly checked and tested and was found functional at the time of inspection. The shortcomings issued vide letter no. F6/DFS/MS/2023/NDZ/291 dated 30.05.2023 by this department have been rectified by the management.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, it is recommended to grant Fire Safety Certificate under Rules 37 of Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer
Name : Yashwant Singh Meena
Designation : A.D.O. (LN).

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : D.O. (East. Div.).

Dy. C.O. (NDZ)

05/06/23

C.O.
7/6/2023
Director
01/06/23
A.D.O.