

30

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

No F 6 DFS/MS/School/2023/SZ/395

Dated 07/06/2023

FIRE SAFETY CERTIFICATE

Certified that the **Rao Ganga Ram Public School**, at Old Delhi Gurgaon Road, Kapashera, New Delhi-110037 comprised of Ground plus two upper floor owned/ occupied by Rao Ganga Ram Public School was issued Fire Safety Certificate by this department vide letter No F.6/DFS/MS/School/2020/SZ/125 Dated 18/03/2020. The said premise was re-inspected by officer concerned of this department on 31/05/2023 in presence of Mr Satish Kumar and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules 2010 and that the building is fit for occupancy class "**Educational Building Group – B**" with effect from 07/06/2023 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 07/06/2023 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Principal, Rao Ganga Ram Public School, at Old Delhi Gurgaon Road, Kapashera, New Delhi-110037
2. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi- 110054

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
2. All the staff members must know the correct method of operation of firefighting system.
3. This certificate cannot be treated as regularization of unauthorized construction, if any.
4. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
5. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
6. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

N/116

SECRETARY
FIRE DEPARTMENT

INSPECTION REPORT

1	Name & Address of the Building	Rao Ganga Ram Public School, at Old Delhi Gurgaon Road, Kapashera, New Delhi-110037		
2	Type of Occupancy	Educational Building, "Group-B" (School)		
3	Building Comprised of	Ground plus two upper floors		
4	Type of Case	Renewal		
5	Details of Previous NOC	F 6/DFS/MS/School/2020/SZ/125 Dt 18/03/2020		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	31/05/2023		
8	Name of the Inspecting Officers	Sh Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr Satish Kumar		
10	Year of construction	2005 & 2012		
11	Applicant letter No	RGRPS/2023/276 dated 22/05/2023		

S. No.	Minimum standards on Fire Prevention and Fire Safety U/R 33	Requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	Required	6 mtr	MR
	• Gate width	Required	5 mtr	MR
	• Width of internal road	-NA-	-NA-	-NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	➤ Upper floors	02 Nos	02 Nos	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	b) Width of Staircase			
	➤ Upper floors	1 50 mtr	1 60 mtr & 1 50 mtr	MR
	➤ Basement floor	-NA-	-NA-	-NA-
	c) Protection of exits			
	➤ Fire check door	-NA-	-NA-	-NA-
	➤ Pressurization	-NA-	-NA-	-NA-
	d) No. of continuous staircase to terrace	Required	05 Nos	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1 mtr	Provided	MR
3	Compartmentation.			
	• Fire check door	-NA-	-NA-	-NA-
	• Sealing of electrical shafts	-NA-	-NA-	-NA-
	• Fire rating of shaft door	-NA-	-NA-	-NA-
	• Water curtain	-NA-	-NA-	-NA-
	• Fire dampers	-NA-	-NA-	-NA-
4.	Smoke Management system.			
	• Basement	30 ACPH	-NA-	-NA-
	• Upper floors	12 ACPH	-NA-	-NA-
5.	Fire Extinguishers.			
	• Total numbers	20 No's	20 No's	MR
	• Types	ABC / CO ₂	ABC-26 & CO ₂ -14	MR
	• ISI Marking	ISI marked	Provided	MR
6.	First Aid Hose Reels.			
	• Total numbers on each floor	02 No's	02 No's	MR
	• Length of hose-reel hose	30m	30m	MR
	• Nozzle Diameter	5mm	5mm	MR

Q

~

h

N117

7	Automatic fire detection & alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	• Size of Riser/Down-comer	-NA-	-NA-	-NA-
	• Number of Hydrant per floor	-NA-	-NA-	-NA-
	• Hose box	-NA-	-NA-	-NA-
12.	Yard Hydrants.			
	• Total number of hydrants	-NA-	-NA-	-NA-
	• Hose box	-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump	-NA-	-NA-	-NA-
	➤ Head of main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump output	-NA-	-NA-	-NA-
	➤ Jockey Pump head	-NA-	-NA-	-NA-
	➤ Standby Pump output	-NA-	-NA-	-NA-
	➤ Standby Pump head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping	-NA-	-NA-	-NA-
	➤ Pump house access	-NA-	-NA-	-NA-
	• Terrace Level			
	➤ Discharge of pump	450 LPM	450 LPM	MR
	➤ Head of pump	40m	40m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water storage for fire fighting.			
	• Underground tank capacity			
	➤ Draw-off connection	-NA-	-NA-	-NA-
	➤ Fire Service Inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead tank capacity	10,000 Ltr	10,000 Ltr	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft	-NA-	-NA-	-NA-
	• Pressurization of lift lobby	-NA-	-NA-	-NA-
	• Communication in lift car	-NA-	-NA-	-NA-
	• Fireman's switch	-NA-	-NA-	-NA-
	• Lift signage	-NA-	-NA-	-NA-
17.	Standby Power Supply	-NA-	-NA-	-NA-
18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-
19.	Fire Control Room.			

Y

N


C

• Detector system panel	-NA-	-NA-	-NA-
• Flow switch panel	-NA-	-NA-	-NA-
• PA system panel	-NA-	-NA-	-NA-
• Battery backup	-NA-	-NA-	-NA-
• Building floor plan	-NA-	-NA-	-NA-
20. Special Fire Protection System for the Protection of special Risk, if any.	-NA-	-NA-	-NA-

The fire protection system provided in the building / premises were test checked at random and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under DOE circular, FSC issued vide letter No F 6/DFS/MS/School/2020/SZ/125 Dt 18/03/2020, renewal under rule 37 of the Delhi Fire Service Rules, 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.


 Signature of the Inspecting Officer
 Name Sh. Rajesh Kumar
 Designation ADO (BCP)

DO (SD)

mmh
7/6

CPA
5/6/2023

Director / MV
5/6/23

FTPH

ADYBUN

As approved, F.T. letter is put up for
your signature pl

Director / MV
5/6/23
on

1/16
6/6