



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F.6/DFS/MS/School/2023/NDZ/417

Dated: 14/06/2023

FIRE SAFETY CERTIFICATE

Certified that Bal Mandir Public School running on ground and first floor building comprised of ground plus two upper floor at Jatar Nagar, Parwana Road, Delhi-110051, owned/occupied by Bal Mandir Public School was issued FSC vide letter No. F.6/DFS/MS/School/2018/NDZ/1411 dated 15/06/18. The premises was re-inspected by the officer concerned of this department on dated 23/05/2022 in the presence of Mrs. Sneh Nandwani (Principal) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with Circular No.262-362 dated 17/01/2005 issued by the Director of Education and that the building/premises is fit for occupancy class 'Educational (Group-B)' with effect from 14/06/2023 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on 14/06/2023 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

To:-

1. The Principal
Bal Mandir Public School at Jatar Nagar, Parwana Road, Delhi-110051
2. The Director of Education, MCD
5th Floor, E- Block, Dr. S.P. Mukherjee Civic Center, JLN Marg, New Delhi-110002

Conditions for the validity of Fire Safety Certificate

1. Fire Safety Certificate is valid for ground and first floor only.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry

1	Name & address of the building	Bal Mandir Public School Jitar Nagar Parwana Road, Delhi-110051
2	Building is comprised of	Ground plus two upper floors (School is running on ground & first floor only)
3	Type of Occupancy	Educational
4	Type of Case	Renewal
5	Details of Previous FSC letter	F 6/DFS/MS/School/2018/NDZ/1411dt 15 2018
6	Fire Safety directive letter No	Circular No 262-362 dated 17/01/2005 issued by DoE
7	Date of Inspection	23/05/2022
8	Name of the Inspecting officers	ADO Deepak Kumar
9	Name and designation of officer from the building side	Mrs. Sneh Nandwani (Principal)
10	Year of Construction	2000
11	Applicant's letter No	Nil Dated- 10/05/2023

Sr No	Minimum Standards on Fire Prevention and Fire Safety U/R33	DoE Circular Requirement	Provided at Site
01	Access to Building		
	• Road width	06 mtr	06 mtr ✓
	• Gate width	N/A	N/A
	• Width of internal road	N/A	N/A
02	Number, Width, Type and Arrangement of Exits		
	a Number of Staircases		
	• Upper floor	01 nos	01 nos ✓
	• Basement	N/A	N/A
	b Width of Staircases		
	• Upper floor	1 50 mtr	1 30 mtr ✓ MR fold
	• Basement	N/A	N/A
	c Protection of exits		
	• Fire check door	N/A	N/A
	• Pressurization	N/A	N/A
	d No. of Continuous Staircases to Terrace	01 no	01 no
	e Width of corridor	1 50 mtr	1 50 mtr ✓
	f Door Size	01 mtr	01 mtr ✓
03	Compartmentation		
	• Fire check door	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A
	• Fire rating of shaft door	N/A	N/A
	• Water curtain	N/A	N/A
	• Fire dampers	N/A	N/A
04	Smoke Management System		
	• Basement	N/A	N/A
	• Upper floor	N/A	N/A
05	Fire Extinguishers		
	• Total numbers	04 nos	06 nos ✓
	• Types	ABC /CO ₂	ABC /CO
	• IS marking	ISI marked	ISI marked

24 50

06	First-Aid-Hose Reels			
	Total numbers on each floor	01 no	01 no	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic fire detection and alarming system			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter's location	N/A	N/A	N/A
08	MOEFA	N/A	N/A	N/A
09	Public Address System			
10	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	N/A	N/A	N/A
	• Number of hydrants per floor	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
12	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose box	N/A	N/A	N/A
13	Pumping Arrangements			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of Main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out put	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	220 LPM	220 LPM	MR
	• Head of the pump	40 M	40 M	MR
	• Power supply	Required	Provided	MR
	• Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	N/A	N/A	N/A
	• Overhead tank capacity	2500 ltr	2500 ltr	MR
15	Exit Signage	Required	Provided	MR

✓ 50/

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	N/A	N/A	
18	Refuge Area			
	• Total area	N/A	N/A	
	• Location	N/A	N/A	
19	Fire Control Room			
	• Detector system panel	N/A	N/A	
	• Flow switch panel	N/A	N/A	
	• PA system panel	N/A	N/A	
	• Battery backup	N/A	N/A	
	• Building floor plans	N/A	N/A	
20	Special Fire Protection Systems for Protection of Special Risks, if any	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards for fire prevention and fire safety required under the rule the FSC issued vide letter No. F 6/DFS/MS/School/2018/NDZ/1411 dated 15/06/18 renewal under rule 35 of Delhi Fire Service Rule, 2010 is recommended.

Deepak 26/05/2023
 Signature of the Inspecting Officer
 Name - Deepak Kumar
 Designation - A D O (Shd)

~~DO (ED)~~ *Deepak*
 02/06/2023

~~Dy. C.F.O. (NDZ)~~ *R.V.P.*
 02/06/23

~~C.F.O.~~ *Khushi*
 5/6/2023

~~Director~~ *6/06/23*

Arif SHH