

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

Dated: 14/06/2023

No. F6/DFS/MS/SZ/2023/286

FIRE SAFETY CERTIFICATE

Certified that the CNG Dispensing Station Located at Sector-18 CC, Phase II, Dwarka, New Delhi-110075, comprised of Ground Floor only was issued No Objection Certificate vide letter No. F6/DFS/MS/CNG/2020/SZ/284, dated- 31/07/2020. The premises was re inspected by the officer concerned of this department on 30/05/2023 in the presence of Mr. Vijay Kumar Yadav (Manager) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Hazardous" (CNG Dispensing station) with effect from 14/06/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 14/06/2023 at New Delhi by.

(Atul Garg)
Director,
Delhi Fire Service

Copy to:

1. Sh.Ajay Khatri DGM - Fire & Safety Indraprastha Gas Limited New Delhi.
2. The Manager CNG Dispensing station Sector-18 CC, Phase II, Dwarka, New Delhi-110075.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used as per building bye laws 1983.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

M/16

INSPECTION REPORT

1. Name & address of the building: CNG Dispensing Station Located at Sector-18 CC, Phase II, Dwarka, New Delhi-110075
2. Type of Occupancy : Group J Hazardous (CNG Dispensing Station)
3. Type of Case : Renewal (Ground Floor & Cascade at terrace)
4. Details of previous NOC: F6/D/S/MS/CNG/2020/SZ/284, dated- 31/07/20
5. Fire Safety directives I. No. F6/D/S/MS/CNG/2016/1984, dated 17/08/16
6. Date of inspection : 30/05/2023
7. Name of the Inspecting Officer : Sh. Uday vir singh, ADO (DWK)
8. Name and designation of Officer from the building side : Mr Vijay Kr. Yadav (Manager)
9. Year of Construction : 2016
10. Applicant's letter No : IGL/F&S/2023/15/109/1 dated 15/05/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/12, N/13 & N/14	Provided at site	Remarks MR/NMR
1	Access of building <ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	12 m NA NA	Provided Directly accessible from road NA	MR NA NA
2	Number, width, type & Arrangements of exits <ul style="list-style-type: none"> a. Number of staircases <ul style="list-style-type: none"> • Upper floors • Basements b. Width of staircases <ul style="list-style-type: none"> • Upper floors • Basements c. Protection of exits <ul style="list-style-type: none"> • Fire check door • Pressurization d. No of continuous staircase to terrace e. Width Of Corridor f. Door Size 	01 No. NA 1.5 m NA NA NA NA NA NA	Provided NA Provided NA NA NA NA NA	MR NA MR NA NA NA NA NA
3	Compartmentation <ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
4	Smoke managements System <ul style="list-style-type: none"> • Basements • Upper floors 	NA NA	NA NA	NA NA




11/17

5.	Fire Extinguishers				
	• Total numbers	10 Nos.	Provided	MR	
	• Types	As per IS 2190/Clause 19 OISD	2 Nos. CO2 4.5kg 2 Nos. DCP trolley 75 Kg 4 Nos. DCP 10 Kg	MR	
	• IS marking	Required	Provided	MR	
6.	First Aid Hose Reels				
	• Total numbers on each floor	NA	NA	NA	
	• Length of hose reel hose	NA	NA	NA	
	• Nozzle diameter	NA	NA	NA	
7.	Automatic fire detection and alarming system				
	• Type of detectors	Gas & flame	Provided	MR	
	• Location of Main Panel	Office area	Provided	MR	
	• Location of Repeater Panel	NA	NA	NA	
	• Alternate source of power	NA	NA	NA	
	• Hooters' Location	Compressor	Provided	MR	
8.	MOIFA	Required	Provided	MR	
9.	Public Address System	NA	NA	NA	
10.	Automatic Sprinkler System	<i>Water mist totally provided</i>			
	• Ground Floor	NA	NA	NA	
	• Upper Floor	NA	NA	NA	
	• Sprinkler above false ceiling	NA	NA	NA	
11.	Internal Hydrants				
	• Size of riser/down-comer	NA	NA	NA	
	• Number of hydrants per floor	NA	NA	NA	
	• Hose Box	NA	NA	NA	
12.	Yard Hydrants				
	• Total number of hydrants	NA	NA	NA	
	• Hose Box	NA	NA	NA	
13.	Pumping Arrangements				
	• Ground Level				
	• Discharge of main pump	NA	NA	NA	
	➤ Head of main pump	NA	NA	NA	
	➤ Number of main pumps	NA	NA	NA	
	➤ Jockey pump out put	NA	NA	NA	
	➤ Jockey pump head	NA	NA	NA	
	➤ Standby Pump out put	NA	NA	NA	
	➤ Standby Pump Head	NA	NA	NA	
	➤ Auto Starting/Manual stopping	NA	NA	NA	
	➤ Pump House Access	NA	NA	NA	
	• Terrace level				
	➤ Discharge of pump	NA	NA	NA	
	➤ Head of the pump	NA	NA	NA	
	➤ Power supply	NA	NA	NA	
	➤ Auto starting of pump	NA	NA	NA	

Handwritten initials/signature

14	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead tank capacity	NA	NA	NA
15	Exit Signage	Required no smoking board	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided DG set	MR
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any.	CO2 Flooding	Provided for compressor	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter No 16/DI S/MS/CNG/2020/SZ/284, dated- 31/07/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended

Signature of the Inspecting Officer
 Name Uday Vir Singh
 Designation ASD/AR

ng/sec
dt 2/6/23
CFO (S2)
8/6/2023
Director
8/6/23
ADU/AR