

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6/DFS/MS/CNG/2023/ 285

Dated:-14.06.2023

FIRE SAFETY CERTIFICATE

Certified that the NAGLA MACHI CNG Station at Ring Road, New Delhi is comprised of ground floor was earlier granted FSC by this department vide letter No.F6/DFS/MS/CNG/2020/253 dated 16/07/2020. Now, the premises was re-inspected by the officers concerned of this department on 07/06/23 in the presence of Sh. Abhijeet Shrivastava and found that the said building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Hazardous Group J with effect from 14/06/2023 for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.


(Ajay Garg)
DIRECTOR
Delhi Fire Officer

Copy to:-

1. The Commissioner, MCD, Civic Centre, New Delhi.
2. Ajay Khatri, DGM (Fire & Safety),
Indraprastha Gas Limited, IGL Bhawan, Plot No.4, Community Centre, R.K. Puram,
Sec.9, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management and this certificate does not give guarantee that there will be no fire.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

INSPECTION REPORT

1. Name & address of the building **NAGLA MACHI CNG Station** located at Ring Road, New Delhi
2. Type of occupancy:- **Hazardous Group J**
Single story building
3. Type of case:- **Renewal**
4. Details of previous FSC:- **F6/DFS/MS/CNG/2020/253** dated 16/07/2020
5. Fire safety directives No.- **F5/(3A)/DFS/CNG/BP/2010/143** dated 03.06.10
6. Date of inspection:- **07/06/23**
7. Name of the inspecting officer:- **Sh. Ravinder Singh (ADO/CC)**
8. Name & designation of officer From the building side:- **Sh. Abhijeet Shrivastava**
2000
9. Year of construction:- **2000**
10. Applicant's letter No:- **IGL/F&S/2023/15/48/1** dated 15/05/2023.

Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	30 mtr.	MR ✓
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	N/A	N/A	N/A
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	23 DCP 9 Kg, 03 Co2 4.5 Kg, 03 DCP 75Kg, 09 DCP flooding system, 1 water mist trolley, 02 Co2 45 Kg.	35nos - 9 Kg DCP, 06nos - Co2 4.5 Kg, 06nos - DCP 75Kg, 09 DCP flooding system, 1 water mist trolley, 03 Co2 45 Kg flooding, 02 water mist trolley system	MR ✓
	2) Types	ABC, CO2, DCP, Mist cum foam trolley	ABC, CO2, DCP, Mist cum foam trolley	MR ✓

✓

	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	N/A	N/A	N/A
	2) Length of hose reel hose	N/A	N/A	N/A
	3) Nozzle diameter	N/A	N/A	N/A
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Flame	Provided in Compressor Package Area	MR
	2) Location of main panel	G.F.	Gr. Floor	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hostler's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank	N/A	N/A	N/A

✓

6

84

N/14

	capacity			
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	N/A	N/A	N/A
15.	Exit Signage.	N/A	N/A	N/A
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: Provided Fire buckers filled with sand. No smoking bards displayed in Hindi & English electrical wiring in metal conduit. MCB, Co2, flooding system.			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/CNG/2020/253 dated 16/07/2020, renewal under rule 35(6) of the Delhi Fire Service rules 2010, is recommended for approval.

Signature of the Inspecting Officer



Name :- Ravinder Singh
Designation :- ADO (CC)

Dated

9/6/23

Sy. G. S. (P. 02)

9/6/23

C.F.O.

12/6/2023

Director

12/6/23

12/6/23