

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001

No. F6/DFS/MS/CNG/2023/ 283

Dated:- 14.06.2023

FIRE SAFETY CERTIFICATE

Certified that the Udyan Marg CNG Station (01 CNG Compressors with 03 CNG Dispenser) at Udyan Marg, New Delhi is comprised of single story building was earlier granted FSC by this department vide letter No F6/DFS/MS/CNG/2020/255 dated 16/07/2020. Now, the premises was re-inspected by the officers concerned of this department on 08/06/23 in the presence of Sh. Anuj Tiwari and found that the said building has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Hazardous Group J with effect from 14/06/2023 for period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010.

Issued 14/06/2023 at New Delhi by


(Atul Garg)
DIRECTOR
Delhi Fire Officer

Copy to:-

1. The Chairman, NDMC, Palika kendra, New Delhi.
2. Ajay Khatri, DGM (Fire & Safety),
Indraprastha Gas Limited, IGL Bhawan, Plot No.4, Community Centre, R.K. Puram,
Sec 9, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to nonfunctional fire safety measures shall be at the responsibility of the management and this certificate does not give guarantee that there will be no fire.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry."

N/110

INSPECTION REPORT

1. Name & address of the building **Udyan Marg CNG Station (01 CNG Compressors with 03 CNG Dispenser), Udyan Marg, New Delhi**
2. Type of occupancy:- **Hazardous Group J
Single story building**
3. Type of case:- **Renewal**
4. Details of previous NOC:- **F6/DFS/MS/CNG/2020/255 dated 16/07/2020.**
5. Fire safety directives No.- **N/A**
6. Date of inspection:- **08/06/23**
7. Name of the inspecting officer:- **Sh. Ravinder Singh (ADO/CC)**
8. Name & designation of officer From the building side.- **Sh. Anuj
2000**
9. Year of construction:- **2000**
10. Applicant's letter No:- **IGL/F&S/2023/15/1/1 dated 15/05/2023.**

Old Case

| S.No | Minimum Standards on fire Prevention and fire safety U/R 33 | Requirement Existing | Provided at site | Remarks MR/NMR |
|-----------|---|--|--|----------------|
| 1. | Access to Building | | | |
| | 1) Road width | 06 mtr. | 30 mtr. | MR |
| | 2) Gate width | N/A | N/A | N/A |
| | 3) Width of internal road | N/A | N/A | N/A |
| 2. | Number, Width Type & Arrangement of Exits | | | |
| | A. Number of staircases | | | |
| | 1. Upper floors | N/A | N/A | N/A |
| | 2. Basements | N/A | N/A | N/A |
| | B. Width of staircase | | | |
| | 1. Upper floors | N/A | N/A | N/A |
| | 2. Basements | N/A | N/A | N/A |
| | C. Protection of exits | | | |
| | 1. Fire check door | N/A | N/A | N/A |
| | 2. Pressurization | N/A | N/A | N/A |
| | D. No. of continuous staircase to terrace | | | |
| | E. Width of corridor | N/A | N/A | N/A |
| | F. Door size | N/A | N/A | N/A |
| 3. | Compartmentation | | | |
| | 1) Fire check door | N/A | N/A | N/A |
| | 2) Sealing of electrical shafts | N/A | N/A | N/A |
| | 3) Fire rating of shaft door | N/A | N/A | N/A |
| | 4) Water curtain | N/A | N/A | N/A |
| | 5) Fire Dampers | N/A | N/A | N/A |
| 4. | Smoke Management System | | | |
| | 1) Basements | N/A | N/A | N/A |
| | 2) Upper floors | N/A | N/A | N/A |
| 5. | Fire Extinguishers | | | |
| | 1) Total numbers | 01 trolley DCP 75Kg, 15 trolley DCP 15 Kg, 2 Co ₂ 45 Kg | 04 trolley DCP 75kg, 15 trolley DCP 15 Kg, 5 Co ₂ 45 Kg, 01 water mist, Co ₂ flooding system -2 nos. DCP | MR ✓ |

e

✓

M17

| | | | | |
|-----|---|--|---|-----|
| | 2) Types | ABC, CO ₂ , Mist cum foam trolley | flooding system -02 nos ABC, CO ₂ , Mist cum foam trolley | MR |
| | 3) ISI marking | Required | Provided | MR |
| 6. | First-Aid Hose Reel | | | |
| | 1) Total number of each floor | N/A | N/A | N/A |
| | 2) Length of hose reel hose | N/A | N/A | N/A |
| | 3) Nozzle diameter | N/A | N/A | N/A |
| 7. | Automatic Fire Detection & Alarming System | | | |
| | 1) Type of detectors | Flame | Provided in Compressor Packager Area | MR |
| | 2) Location of main panel | G.F. | Gr. Floor | MR |
| | 3) Location of repeater panel | N/A | N/A | N/A |
| | 4) Alternate source of power | Required | Provided | MR |
| | 5) Hooter's Location | N/A | N/A | N/A |
| 8. | MOEFA | Required | Provided | MR |
| 9. | Public Address System | N/A | N/A | N/A |
| 10. | Automatic Sprinkler System | | | |
| | 1) Basement | N/A | N/A | N/A |
| | 2) Upper floors | N/A | N/A | N/A |
| | 3) Sprinkler above false ceiling | N/A | N/A | N/A |
| 11. | Internal Hydrants | | | |
| | 1) Size of riser/down-comer | N/A | N/A | N/A |
| | 2) Number of hydrants per floor | N/A | N/A | N/A |
| | 3) Hose box | N/A | N/A | N/A |
| 12. | Yard Hydrants | | | |
| | 1) Total number of hydrants | N/A | N/A | N/A |
| | 2) Hose box | N/A | N/A | N/A |
| 13. | Pumping Arrangement | | | |
| | 1) Ground level | N/A | N/A | N/A |
| | a) Discharge of main pump | N/A | N/A | N/A |
| | b) Head of main pump | N/A | N/A | N/A |
| | c) Number of main pump | N/A | N/A | N/A |
| | d) Jockey pump out put | N/A | N/A | N/A |
| | e) Jockey pump head | N/A | N/A | N/A |
| | f) Stand by pump output | N/A | N/A | N/A |
| | g) Stand by pump head | N/A | N/A | N/A |
| | h) Auto starting/Manual stopping | N/A | N/A | N/A |
| | 2) Terrace level | | | |
| | a) Discharge of pump | N/A | N/A | N/A |
| | b) Head of pump | N/A | N/A | N/A |
| | c) Power supply | N/A | N/A | N/A |
| | d) Auto starting of pump | N/A | N/A | N/A |
| 14. | Captive Water Storage for Fire Fighting | | | |

[Handwritten signature]

[Handwritten signature]

| | | | | |
|-----|---|-----|-----|-----|
| | 1) Under ground tank capacity | N/A | N/A | N/A |
| | a) Draw-off connection | N/A | N/A | N/A |
| | b) Fire service inlet | N/A | N/A | N/A |
| | c) Access to tank | N/A | N/A | N/A |
| | d) Over head tank capacity | N/A | N/A | N/A |
| 15. | Exit Signage. | N/A | N/A | N/A |
| 16. | Provision of Lifts. | | | |
| | a) Pressurization of lift shaft | N/A | N/A | N/A |
| | b) Pressurization of lift lobby | N/A | N/A | N/A |
| | c) Communication in lift car | N/A | N/A | N/A |
| | d) Fireman's switch | N/A | N/A | N/A |
| | e) Lift signage | N/A | N/A | N/A |
| 17. | Stand by Power Supply | N/A | N/A | N/A |
| 18. | Refuge Area | N/A | N/A | N/A |
| | Total area location | N/A | N/A | N/A |
| 19. | Fire Control Room | N/A | N/A | N/A |
| | a) Detector system panel | N/A | N/A | N/A |
| | b) Flow switch panel | N/A | N/A | N/A |
| | c) PA system panel | N/A | N/A | N/A |
| | d) Battery backup | N/A | N/A | N/A |
| | e) Building floor plan | N/A | N/A | N/A |
| 20. | Special Fire Protection System for Protection of special Risk, if any: Provided Fire buckers dilled with sand. No smoking bards displayed in Hindi & English electrical wiring in metal conduit. MCB, Co2, flooding system. | | | MR |

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F6/DFS/MS/CNG/2020/255 dated 16/07/2020, renewal under rule 35(6) of the Delhi Fire Service rules 2010, is recommended for approval .

Signature of the Inspecting Officer

Name :- Rayinder Singh
Designation :- ADO (CC)

Dg
9/6/23

9/6/23

C.F.O.

12/6/2023

Director
09/06/23

Director
12/6/23

Adulca