

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001

No F 6/DFS/MS/Storage/2023/SZ/ 290

Dated 15/06/2023

**FIRE SAFETY CERTIFICATE**

Certified that the **Ware House** located at Ghitorni Feeder Bus Depot Near Ghitorni Metro Station, New Delhi comprised of **Ground Floor only** owned/occupied by M/s Raj Kumar and Sons have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by officer concerned of this department on 08/06/2023 in presence of Mr. Bhupesh Khanna and that the building is fit for occupancy class "**Storage building**" with effect from 15/06/2023 for a period of **Three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010

Issued 15/06/2023 at New Delhi by

  
(ATEL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to -

- 1 Dy Chief Architect, Delhi Metro Rail Corporation, Metro Bhawan, Fire Brigade Lane, New Delhi 110001 (Ref application DMRC/FIRE/133/2023-05/318 dated 26/05/2023)
- 2 M/s Raj Kumar Khanna and Sons ([rksons1988@gmail.com](mailto:rksons1988@gmail.com))

**Conditions for the validity of Fire Safety Certificate:**

- 1 All the means of escape/entry/exit shall be kept free from any obstruction
- 2 All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
- 3 All the staff members must know the correct method of operation of fire fighting system
- 4 The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
- 5 This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any
- 6 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six month prior to its expiry



N/S

	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>	-NA-	-NA-	-NA-
		Required	Provided	MR
8.	MOEFA	Required	All Areas	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided	MR
11.	Internal Hydrants.			
	<ul style="list-style-type: none"> <li>Size of Riser/Down-comer</li> </ul>	100 mm	Provided	MR
	<ul style="list-style-type: none"> <li>Number of Hydrant per floor</li> </ul>	02 Nos	Provided	MR
	<ul style="list-style-type: none"> <li>Hose box</li> </ul>	02 Nos	Provided	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	02 Nos	Provided	MR
	<ul style="list-style-type: none"> <li>Hose box</li> </ul>	02 Nos	Provided	MR
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> <li>Ground Level</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of main pump</li> </ul>	1620 LPM	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Head of main pump</li> </ul>	70 mtr	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>	01 No	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Jockey Pump output</li> </ul>	180 LPM	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Jockey Pump head</li> </ul>	70 mtr	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Standby Pump output</li> </ul>	1620 LPM	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Standby Pump head</li> </ul>	70 mtr	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Auto Starting/Manual Stopping</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Pump house access</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Terrace Level</li> </ul>			
	<ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>	450 LPM	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Head of pump</li> </ul>	40m	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Power supply</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Auto starting of pump</li> </ul>	Required	Provided	MR
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> </ul>	50,000 Ltrs	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Draw-off connection</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Fire Service Inlet</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>➤ Access to tank</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Overhead tank capacity</li> </ul>	10,000 Ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> <li>Pressurization of lift shaft</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Pressurization of lift lobby</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Communication in lift car</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Fireman's switch</li> </ul>	Required	Provided	MR
	<ul style="list-style-type: none"> <li>Lift signage</li> </ul>	Required	Provided	MR
17.	Standby Power Supply	Required	Provided (DG Set)	MR
18.	Refuge Area			
	<ul style="list-style-type: none"> <li>Total area</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Location</li> </ul>	-NA-	-NA-	-NA-
19.	Fire Control Room.			
	<ul style="list-style-type: none"> <li>Detector system panel</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>Flow switch panel</li> </ul>	-NA-	-NA-	-NA-
	<ul style="list-style-type: none"> <li>PA system panel</li> </ul>	-NA-	-NA-	-NA-

2

	<ul style="list-style-type: none"> <li>Battery backup</li> <li>Building floor plan</li> </ul>	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	LT, HT & Transformers provided with Co2 flooding	MR

The fire protection system provided in the building were randomly checked and found functional at the time of inspection.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010

Accordingly DFA is put up for approval and signature please.

*Manoj*  
Signature of the Inspecting Officer  
Name: Sh. Manoj Sharma  
Design: DO (South)

*Rajesh*  
Signature of the Inspecting Officer  
Name: Sh. Rajesh Kumar  
Design: ADO (BCP)

*Rajesh*  
9/06/2023

CFO (HQ) - On Leave

~~Director~~ *[Signature]*  
9/06/23

ft PLs

*ADP/BCP*

As approved, f.t. letter is pending for your signature pl

*[Signature]*  
14/6

~~Director~~ *[Signature]*  
15/06/23  
*mu*