

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F.6/DFS/MS/EH/2023/SZ/187

Dated: 14/06/2023

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the Name & Style of M/s Haldiram Marketing Pvt Ltd located at Ground, First & Second Floor, B-1/H-8, Mohan Cooperative Industrial Estate, Main Mathura Road, New Delhi-110044 in the building comprised of Basement, Ground plus two upper floors owned/occupied by M/s Haldiram Marketing Pvt. Ltd. was issued Fire Safety Certificate by this department vide letter no F6/DFS/MS/EH/2020/SZ/94 dated 15/06/2020. The restaurant premises was re-inspected by the officer concerned of this department on 02/06/2023 in the presence of Mr. Sanjeev Yadav (GM) and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the building/premises is fit for occupancy class-D "Assembly" (Restaurant) and validity upto 31/03/2026 in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 14/06/2023 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Joint CP (Lic.), 1st floor, Police Station Defence Colony, New Delhi -110049.
2. The DHO, Public Health Department, MCD, Central Zone, Jal Vihar Lajpat Nagar, New Delhi 110024. (Ref. MHA Portal ID 2023052409530 dated 25/05/2023)

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management. The trained staff should be available round the clock.
3. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
4. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
5. Basement shall be used as per building bye laws.
6. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

| 1 | Name & Address of the Building | Haldiram Restaurant located at Plot no B-1/H-8, M.C.I.E, Main Mathura Road, New Delhi-110044 | | |
|-------|---|--|-----------------------|----------------|
| 2 | Type of Occupancy | Assembly Building (Group-D) | | |
| 3 | Building Comprised of | Basement, Ground + 02 upper floors. | | |
| 4 | Type of Case | Renewal | | |
| 5 | Details of Previous NOC | F6/DFS/MS/EH/2020/SZ/94 dated 15/06/2020 | | |
| 6 | Fire Safety Directives Letter No | Nil | | |
| 7 | Date of Inspection | 02/06/2023 | | |
| 8 | Name of the Inspecting Officers | DO (South) & ADO (BCP) | | |
| 9 | Name & Designation of Officers from the building side | Mr. Sanjeev Yadav (GM) | | |
| 10 | Year of construction | 2011/ Restaurant at Ground, First & Second Floor | | |
| 11 | Applicant letter No. | MHA Portal ID 2023052409530 dated 25/05/2023 | | |
| S. No | Minimum standards on Fire Prevention and Fire Safety U/R 33 | Old NOC Requirements | Provided at Site | Remarks NR/NMR |
| 1 | Access to Building. | | | |
| | • Road width | 06 m | Provided | MR |
| | • Gate width | -N/A- | -N/A- | -N/A- |
| | • Width of internal road | -N/A- | -N/A- | -N/A- |
| 2 | Number, width, type & arrangement of exits. | | | |
| | a) Number of Staircase | | | |
| | ➤ Upper floors. | 02 Nos | Provided | MR |
| | ➤ Basement floor | -N/A- | -N/A- | -N/A- |
| | b) Width of Staircase | | | |
| | ➤ Upper floors | 1.5 m & 1.25m | Provided | MR |
| | ➤ Basement floor | -N/A- | -N/A- | -N/A- |
| | c) Protection of exits | | | |
| | ➤ Fire check door | -N/A- | -N/A- | -N/A- |
| | ➤ Pressurization | -N/A- | -N/A- | -N/A- |
| | d) No. of continuous staircase to terrace | 01 no | 01 no | MR |
| | e) Width of corridor | -N/A- | -N/A- | -N/A- |
| | f) Door size | 1.5 m | Provided | MR |
| 3 | Compartmentation. | | | |
| | • Fire check door. | -N/A- | -N/A- | -N/A- |
| | • Sealing of electrical shafts. | -N/A- | -N/A- | -N/A- |
| | • Fire rating of shaft door. | -N/A- | -N/A- | -N/A- |
| | • Water curtain | -N/A- | -N/A- | -N/A- |
| | • Fire dampers. | -N/A- | -N/A- | -N/A- |
| 4 | Smoke Management system. | | | |
| | • Basement | -N/A- | -N/A- | -N/A- |
| | • Upper floors | Required in Kitchen | Provided | MR |
| 5 | Fire Extinguishers. | | | |
| | • Total numbers | 10 nos. | Provided | MR |
| | • Types | ABC / Co ₂ / W Co ₂ | ABC & Co ₂ | MR |
| | • ISI Marking | ISI marked | Provided | MR |
| 6 | First Aid Hose Reels. | | | |
| | • Total numbers on each floor | One | Provided | MR |
| | • Length of hose-reel hose | 30m | Provided | MR |
| | • Nozzle Diameter | 5mm | Provided | MR |

| | | | | |
|-----|--|-------------|-----------------|-------|
| 7 | Automatic fire detection & alarming system. | | | |
| | • Type of detectors | -N/A- | Smoke type | -N/A- |
| | • Location of Main Panel | -N/A- | Ground Floor | -N/A- |
| | • Location of Repeater Panel | -N/A- | -N/A- | -N/A- |
| | • Alternate source of power | -N/A- | Provided | -N/A- |
| | • Hooter's location | -N/A- | Each floor | -N/A- |
| 8. | MOEFA | Required | Provided | MR |
| 9. | Public Address System | -N/A- | -N/A- | -N/A- |
| 10. | Automatic Sprinkler System | | | |
| | • Basement | -N/A- | -N/A- | -N/A- |
| | • Upper floors | Required | Provided | MR |
| | • Sprinkler above false ceiling | -NA- | -NA- | -NA- |
| 11. | Internal Hydrants. | | | |
| | • Size of Riser / Down-comer | 100 mm | Provided | MR |
| | • Number of Hydrant per floor | One | Provided | MR |
| | • Hose box. | One | Provided | MR |
| 12. | Yard Hydrants. | | | |
| | • Total number of hydrants. | Required | Two | MR |
| | • Hose box. | Required | Two | MR |
| 13. | Pumping arrangements. | | | |
| | • Ground Level | | | |
| | Discharge of main pump. | -NA- | 2280 LPM | -NA- |
| | ➤ Head of main pump. | -NA- | 88 Mtrs. | -NA- |
| | ➤ Number of main pumps | -NA- | Provided 01 no. | -NA- |
| | ➤ Jockey Pump output. | -NA- | 180 LPM | -NA- |
| | ➤ Jockey Pump head. | -NA- | 88 Mtrs. | -NA- |
| | ➤ Standby Pump output. | -NA- | 2280 LPM | -NA- |
| | ➤ Standby Pump head. | -NA- | 88 Mtrs. | -NA- |
| | ➤ Auto Starting/Manual stopping. | -NA- | Provided | -NA- |
| | ➤ Pump house access. | -NA- | Provided | -NA- |
| | • Terrace Level | | | |
| | ➤ Discharge of pump. | 900 LPM | 900 & 180 LPM | MR |
| | ➤ Head of pump. | 40 m | Provided | MR |
| | ➤ Power supply. | Required | Provided | MR |
| | ➤ Auto starting of pump. | Required | Provided | MR |
| 14. | Captive water storage for firefighting. | | | |
| | • Underground tank capacity. | 75,000 ltrs | Provided | MR |
| | ➤ Draw-off connection. | -NA- | -NA- | -NA- |
| | ➤ Fire Service Inlet. | -NA- | -NA- | -NA- |
| | ➤ Access to tank. | -NA- | -NA- | -NA- |
| | • Overhead tank capacity. | 10,000 ltrs | Provided | MR |
| 15. | Exit Signage. | Required | Provided | MR |
| 16. | Provision of Lifts. | | | |
| | • Pressurization of lift shaft. | -N/A- | -N/A- | -N/A- |
| | • Pressurization of lift lobby. | -N/A- | -N/A- | -N/A- |
| | • Communication in lift car. | -N/A- | -N/A- | -N/A- |
| | • Fireman's switch. | -N/A- | -N/A- | -N/A- |
| | • Lift signage. | -N/A- | -N/A- | -N/A- |
| 17 | Standby Power Supply | Required | Provided | MR |

| | | | | |
|-------------------------------|---|--|----------|-------|
| 18. Refuge Area | | | | |
| | • Total area | -N/A- | -N/A- | -N/A- |
| | • Location | -N/A- | -N/A- | -N/A- |
| 19. Fire Control Room. | | | | |
| | • Detector System Panel. | -N/A- | Provided | -N/A- |
| | • Flow Switch Panel. | -N/A- | -N/A- | -N/A- |
| | • PA system Panel. | -N/A- | -N/A- | -N/A- |
| | • Battery backup | -N/A- | Provided | -N/A- |
| | • Building floor plan | -N/A- | -N/A- | -N/A- |
| 20. | Special Fire Protection System for the Protection of special Risk, if any. | ABC type fire extinguishers provided near electrical panel | | MR |

The Fire protection systems provided in the premises were checked / operated at random and found functional at the time of inspection.

In view of deemed compliance of the minimum standards on fire prevention and fire safety required under the rules, renewal of the FSC issued vide letter no. F6/DFS/MS/EH/2020/SZ/94 dated 15/06/2020, under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly DFA is put up for approval and signature please.

Signature of the Inspection Officer
Name: Sh. Manoj Kumar Sharma
Design: DO (South)

Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Design: ADO (BCP)

CFO (HQ)

Please speak.
8/6/2023

DO (South)

Spoken in your office
on 7/6/2023 date corrected.
Mistakenly date over rltg
is 7/6/23 pl.

CFO

12/6

12/6/2023
Director
12/06/23

ADO/OIP - on 4/2