

2-13  
c46

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**


No.F6/DFS/MS/EH/NDZ/2023/190

Dated:- 14.06.2023

**FIRE SAFETY CERTIFICATE**

Certified that the Punjab Grill (A unit of Delhi Photo Company) at 78, Janpath, Connaught Place, New Delhi in a building comprised of Ground + Mezzanine + 02 upper floor restaurant running at Ground floor only & storage at Mezzanine floor, owned /occupied by Punjab Grill, was earlier granted FSC by this department vide letter No.F6/DFS/MS/EH/NDZ/2020/142 dated 08.10.2020. Now, the premises was re-inspected by the officer concerned of this department on 08/06/23 in the presence of Manager and found that the said restaurant has deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Assembly Building (Group D) restaurant running at Ground floor only and store at Mezzanine floor and valid up to 31.03.2026 from the date of issue in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on ...14/06/2023..... at New Delhi by.

  
(Anur Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi online ID No. 2023040605474 dated 18.05.23.
2. The Executive Engineer (building), NDMC Palika Kendra, New Delhi.
3. The Manager, Punjab Grill (A unit of Delhi Photo Company), 78, Janpath, Connaught Place, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

1. Name & address of the building Punjab Grill (A unit of Delhi Photo Company) at 78, Janpath, Connaught Place, New Delhi
2. Type of occupancy:- Assembly Building Group-D  
Gr. + Mezzanine + 02 upper floor  
Restaurant running at Ground floor only & store at Mezzanine floor
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/EH/NDZ/2020/142 dated 08.10.2020
5. Fire safety directives No.- N/A
6. Date of inspection:- 08/06/2023
7. Name of the inspecting officer:- Sh. Rajinder Atwal (DO/CD) & Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer From the building side:- (Manager)
9. Year of construction:- Old Heritage Bldg.
10. Applicant's letter No.- Online id 2023040605474 dated 18.05.23

Old case

S. No	Minimum Standards on fire Prevention and fire safety U/R 33	Requirements/ existing fire safety arrangements	Provided at site	Remarks MR/NMR
<b>1. Access to Building</b>				
	1) Road width	09 mtr.	09 mtr. ✓	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2. Number, Width Type &amp; Arrangement of Exits</b>				
A. Number of staircases				
	1. Upper floors	01 nos	02 ✓	MR ✓
	2. Basements	N/A	N/A	N/A
B. Width of staircase				
	1. Upper floors ( mezzanine )	1.3 mtr.	1.3 mtr. ✓	MR
	2. Basements	N/A	N/A	N/A
C. Protection of exits				
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Required	01	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1.06 mtr. x 2	1.16 mtr. x 2 ✓	MR ✓
<b>3. Compartmentation</b>				
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4. Smoke Management System</b>				
	1) Basements	12 ACPH	N/A	N/A
	2) Upper floors	12 w/c per hour	Exhaust fan	MR
<b>5. Fire Extinguishers</b>				
	1) Total numbers	10 Nos.	10 Nos. ✓	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR ✓
<b>6. First-Aid Hose Reel</b>				

✓

26/06/23



N/20

	1) Total number of each floor	01	01 ✓	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	N/A	N/A	N/A
<b>10</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors( mez. )	Required	Provided	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
<b>12</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	Required	450 & 180 LPM	MR
	b) Head of pump	Required	30 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided ✓	MR
<b>14.</b>	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR

W. 10/

N/21

	d) Over head tank capacity	5,000 ltr.	5,000 ltr. /	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no. F6/DFS/MS/EH/NDZ/2020/142 dated 08.10.2020, under rule 35(6) of the Delhi Fire Service rules 2010. Accordingly, DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer

*[Handwritten Signature]*  
9/6/23

Name :- Rajinder Atwal  
Designation :- DO (CD)

Signature of the Inspecting Officer

*[Handwritten Signature]*  
9/6/23

Name :- Ravinder Singh  
Designation :- ADO (CC)

*[Handwritten Signature]*  
Dy. C.O. (CD)

*[Handwritten Signature]*  
12/06/23

*[Handwritten Signature]*  
CFO  
12/06/2023  
Director  
17/06/23

*[Handwritten Signature]*  
put up Agri Est  
as FT

*[Handwritten Signature]*  
ADP/CC