



C-59

77
Azadi Ka
Amrit Mahotsav

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No F.6/DFS/MS/EH/2023/NDZ/197

Dated: 19/06/2023

FIRE SAFETY CERTIFICATE

Certified that the Rockers Resto N Bar running at ground floor of the building comprised of basements, ground plus two upper floors located at SG-45, 46, 47, 48, Plot No. 9D, Adity Mega Mall, CBD Shahdara, Delhi-110032, owned/occupied by A Unit of Brothers Spirits and Co. was issued FSC vide letter No. F 6/DFS/MS/2019/NDZ/1877 dated 30/09/19. The premises was re-inspected by the officer concerned of this department on dated 12/06/2023 in the presence of Mr. Madhav Singhal and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy Group 'D' "Assembly" Valid up to 31/03/2026 in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on ...19/06/2023... at New Delhi by


(ATUL GARG)
DIRECTOR
o/c DELHI FIRE SERVICE

To,

1. Sh. MadhavSinghal
Rockers Resto N Bar at SG-45, 46, 47, 48, Plot No. 9D, Adity Mega Mall, CBD Shahdara,
Delhi-110032
2. The Joint Commissioner of Police (Lic.),
1st Floor Police Station, Defense Colony, New Delhi
MHA ID No. 2023060710451

Conditions for the validity of Fire Safety Certificate

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
6. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

- | | |
|---|--|
| 1. Name & address of the building | Rockers Resto N Bar
(A Unit of Brothers Spirits and Co.)
SG-45, 46, 47, 48, Plot No. 9D, Aditya Mega Mall
CBD Shahdara Delhi-110032 |
| 2. Building is comprised of | Basement, Ground plus two upper floors
(Restaurant is running at ground floor only) |
| 3. Type of Occupancy | Assembly (Restaurant) |
| 4. Type of Case | Renewal |
| 5. Details of Previous NOC letter | F.6/DFS/MS/2019/NDZ/1877 dt 30/09/19 |
| 6. Fire Safety directive letter No | NBC Part IV |
| 7. Date of Inspection | 12/06/2023 |
| 8. Name of the Inspecting officers | ADO (Shd.), Deepak Kumar |
| 9. Name and designation of Officer from the building side | Mr. Madhav Singhal |
| 10. Year of Construction | 2006 |
| 11. Applicant's letter No | 2023060710451 dated 08/06/2023 |

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part IV Requirement	Provided at Site	Remarks MR/NM/R
01	Access to Building			
	• Road width	09 mtr.	45 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	B. Width of Staircases			
	• Upper floor	N/A	N/A	N/A
	• Basement	N/A	N/A	N/A
	c. Protection of Exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of Continuous Staircases to Terrace	N/A	N/A	N/A
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	2.00 M	2.00 M x 2	MR ✓
	g. Number of Door	02 no.	02 no.	MR
03	Compartmentation			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	N/A	N/A	N/A
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers	N/A	N/A	N/A
04	Smoke Management System			
	• Basement	N/A	N/A	N/A
	• Upper floor	N/A	N/A	N/A
05	Fire Extinguishers			
	• Total numbers	06 nos.	08 nos.	MR
	• Types	ABC /CO ₂	ABC /C O ₂	MR
	• IS marking	ISI marked	Provided	MR

- N/A -

06	First-Aid-Hose Reels.			
	Total numbers on each floor Near restaurant	01 nos	01 nos	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	05 mm	05 mm	MR
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors	N/A	N/A	N/A
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	N/A	N/A	N/A
	• Hooter	N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	N/A	N/A
	• sprinkler above false ceiling	N/A	Provided	MR
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01 no.	Provided	MR
	• Hose box	01 no.	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	Provided	N/A
	• Hose box	N/A	Provided	N/A
13	Pumping Arrangements.			
	➤ Ground Level			
	• Discharge of main pump	N/A	N/A	N/A
	• Head of main pump	N/A	N/A	N/A
	• Number of main pumps	N/A	N/A	N/A
	• Jockey pump out put	N/A	N/A	N/A
	• Jockey pump head	N/A	N/A	N/A
	• Standby pump out pu	N/A	N/A	N/A
	• Standby pump head	N/A	N/A	N/A
	• Auto starting /manual stopping	N/A	N/A	N/A
	• Pump house access	N/A	N/A	N/A
	➤ Terrace Level			
	• Discharge of pump	450 LPM	450 LPM	MR (deduct)
	• Head of the pump	40 M	40 M	MR
	• Power supply	Required	Provided	MR
	• Auto starting of pump	Required	Provided	MR
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity	N/A	N/A	N/A
	• Draw-off connection	N/A	N/A	N/A
	• Fire service inlet	N/A	N/A	N/A
	• Access to tank	Required	Provided	MR
	• Overhead tank capacity	20,000 ltr	20,000 ltr	MR
15	Exit Signage.	Required	Provided	MR


✓ / 20/

16	Provision of Lifts.			
	• Pressurization of lift shaft	N/A	N/A	N/A
	• Pressurization of lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift signage	N/A	N/A	N/A
17	Standby Power Supply	Required	Provided	MR
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of Special Risks, if Any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F.6/DFS/MS/2019/NDZ/1877 dated 30/09/19 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.

Eating House has installed separate fire system, if you agree may considered for Fire Safety Certificate.


 Signature of the Inspecting Officer
 Name : Deepak Kumar
 Designation : A. D.O. (Shah)

~~D.O. (NDZ)~~ DFA pl.

~~Signature~~

By: C.F.O. (NDZ)

Signature
13/06/23

C.F.O. Singh
13/06/2023

Director
Signature
19/06/23
A.D.O. (Shah)