


No. F6/DFS/MS/School/WZ/2023/ 431

Dated:- 21/06/2023

**FIRE SAFETY CERTIFICATE**

Certified that the Govt. Sarvodaya Bal Vidyalaya (School ID-1413013), Located at Sector-5, Rohini, Delhi-110085, comprised of Ground + 03 Upper Floors & 01 MP Hall in 2<sup>nd</sup> floor, owned/ occupied by Govt. Sarvodaya Bal Vidyalaya (School ID-1413013) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of Fire Service on 20.05.2023 in the presence of Sh. Shashank Sahu, A.E., (E), PWD and that the building/premises is fit for occupancy class " Educational Building" Group B with effect from 21/06/2023 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 21/06/2023... at New Delhi by.

  
(Addl Chrg)  
Director  
Delhi Fire Service

Copy to:-

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054
2. The Assistant Engineer (E), PWD Sub Division – 2, Ed. Elect. Edn. 1 Div. (N), Sector – 16, Rohini, Delhi-110089.
3. The Principal, Govt. Sarvodaya Bal Vidyalaya (School ID-1413013), Sector-5, Rohini, Delhi-110085.

**Following fire safety directives must be adhered to:-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

1124

## INSPECTION REPORT

1. Name & address of the building: **Sarvodaya Bal Vidyalaya (School ID-1413013) Located at Sector-5, Rohini, Delhi-110085.**
2. Type of Occupancy : Educational,
3. Type of Case : New Block, (G + 03 Upper Floors & 01 MP Hall in 2<sup>nd</sup> Floor)
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : F.6/DFS/MS/BP/2021/505 dated 07.12.2021 for 02 basement + Ground + 03 Upper floors But existing building is comprised of Ground + 03 Upper floors only
6. Date of inspection : 20.05.2023
7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
8. Name and designation of Officer from the building side : Sh. Shashank Sahu, A.E. (E), PWD
9. Year of Construction : 2021-22
10. Applicant's letter No. : email dated 03.10.2022

S No	Minimum standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	06	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m each	2.0 m each	MR
		NA	NA	NA
	• Basements			
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	06	Provided	MR
	d. No of continuous staircase to terrace	1.5 m	Provided	MR
	e. Width Of Corridor	1.2 m	Provided	MR
	f. Door Size	M P Hall - 2.0 m x 2	M P Hall - 2.0 m x 2	
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	50 nos.	80 nos.	MR
	• Types	ABC & CO <sub>2</sub>	ABC-40/CO <sub>2</sub> -40	MR
	• IS marking	ISI marked	Provided	MR

6.	First - Aid Hose Reels			
	• Total numbers on each floor	03	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	450 lpm x 2	MR
	➤ Head of the pump	40Mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000Ltrs.	Provided.	MR
		Required	Provided	MR
15.	Exit Signage			
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply			
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA

Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA
--	----	----	----

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view substantial compliance of the minimum standards on fire prevention and fire safety requirements under the rules, grant of Fire safety Certificate is recommended under rule 35 of the Delhi Fire service Rules 2010 under the DFS Act 2007.

*[Signature]*  
 Aman Kumar Lathar  
 ADO (JWP)

~~DO/W~~

This department has issued fire safety guidelines for its basements, ground plus three upper floors and this deptt. letter No. F2/DFE/MS/330/2021/505 dated 21/2/22. As per the inspection report of ADO (JWP), the school management have constructed ground plus three upper floors & inspected as per NBC-part IV. Submitted for information & approval please.

*[Signature]*  
 31/5/2023

~~CFD~~

Ask for undertaking from School authorities or PWD regarding the deviation in r/o school bldg as per earlier prop and approval for construction of school bldg. Then PWD will examine the fire fighting arrangements as per Rule.

*[Signature]*  
 1/6/2023

~~By CFO (MKC)~~

*[Signature]*  
 2/6

ADO (JWP) AS per direction, a letter of clarification regarding the deviation in building structure received (by-hand) from AE (Elect.) PWD, Sub Division of Edu. (E/ed. Edu. & Div. (W), Sector-14, Rohini, Delhi-89 and same is placed opposite as C-56

Submitted for your kind information & further action p.p.  
 P.F.O.  
*[Signature]*  
 10/6/23