

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI- 110001

No. F.6/DFS/MS/Petrol/2023/SZ/ 305

Dated 22/06/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s BP Green Park, Bharat Petroleum Corporation Limited Retail Outlet (COCO) located at S-19, Green Park Extension, New Delhi, comprised of Single Storey building was issued FSC by this department vide letter no F6/DFS/MS/Petrol/2020/SZ/244 Dated 13/07/2020. The premises was re-inspected by the officer concerned of this department on 28/05/2023 in the presence of Mr. Shailza Sandhu (Manager) of the said filling station and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Group-J, Hazardous Building** with effect from 22/06/2023 for a period of three years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010.

Issued on 22/06/2023 at New Delhi by

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to: -

1. The Administrative Officer, South Zone, South MCD, Green Park, New Delhi-110016
2. The Manager, BP Green Park (BPCL Retail Outlet), S-19, Green Park Extn., New Delhi -61

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. All the staff members must know the correct method of operation of fire fighting system.
4. Any deviation, with regard to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.

INSPECTION REPORT



1	Name & Address of the Building	M/s Bharat Petroleum Corporation Ltd. (BP Green Park) located at S-19, Green Park Extension, New Delhi-110061		
2	Type of Occupancy	Hazardous Building (Group-J)		
3	Building Comprised of	Ground floor only		
4	Type of Case	Renewal		
5	Details of Previous NOC	F6/DFS/MS/Petrol/2020/SZ/244 Dated 13/07/2020		
6	Fire Safety Directives Letter No	Nil		
7	Date of Inspection	28-05-2023		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Shailza Sandhu		
10	Year of construction			
11	Applicant letter No	Outdoor diary No. 2083 Dated 19-05-2023		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	As per Old NOC	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	Required -NA- -NA-	Approachable -NA- -NA-	MR ✓ -NA- -NA-
2	Number, width, type and arrangements of exits.			
	a. Number of Staircase			
	<ul style="list-style-type: none"> • Upper floors • Basement floor 	-NA- -NA-	-NA- -NA-	-NA- -NA-
	b. Width of Staircase		-NA-	
	<ul style="list-style-type: none"> • Upper floors • Basement floor 	-NA- -NA-	-NA- -NA-	-NA- -NA-
	c. Protection of exits		-NA-	
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	-NA- -NA-	-NA- -NA-	-NA- -NA-
	d. No. of continuous staircase to terrace	-NA-	-NA-	-NA-
	e. Width of corridor	-NA-	-NA-	-NA-
	f. Door size	-NA-	-NA-	-NA-
3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire dampers 	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
4	Smoke Management system.		-NA-	
	<ul style="list-style-type: none"> • Basement • Upper floors 	-NA- -NA-	-NA- -NA-	-NA- -NA-
5	Fire Extinguishers.			
	• Total numbers		23 nos	MR ✓
	• Types	ABC/CO2/DCP	CO ₂ (4.5 kg)-02, DCP(10 kg)-16, DCP(50 kg)-1, Foam-04	MR
	• ISI Marking	Required	Provided	MR ✓
6	First Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose-reel hose • Nozzle Diameter 	-NA- -NA- -NA-	-NA- -NA- -NA-	-NA- -NA- -NA-

M/s Bharat Petroleum Corporation Ltd. (BP Green Park) S-19, Green Park Extension, New Delhi-110061.

7	Automatic Fire Detection and Alarming system.			
	• Type of detectors	-NA-	-NA-	-NA-
	• Location of Main Panel	-NA-	-NA-	-NA-
	• Location of Repeater Panel	-NA-	-NA-	-NA-
	• Alternate source of power	-NA-	-NA-	-NA-
	• Hooter's location	-NA-	-NA-	-NA-
8.	MOEFA	-NA-	-NA-	-NA-
9.	Public Address System	-NA-	-NA-	-NA-
10.	Automatic Sprinkler System			
	• Basement	-NA-	-NA-	-NA-
	• Upper floors	-NA-	-NA-	-NA-
	• Sprinkler above false ceiling	-NA-	-NA-	-NA-
11.	Internal Hydrants.			
	• Size of Riser / Down-comer	-NA-	-NA-	-NA-
	• Number of Hydrant per floor	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
12.	Yard Hydrants.			
	• Total number of hydrants.	-NA-	-NA-	-NA-
	• Hose box.	-NA-	-NA-	-NA-
13.	Pumping arrangements.			
	• Ground Level			
	➤ Discharge of main pump	-NA-	-NA-	-NA-
	➤ Head of main pump	-NA-	-NA-	-NA-
	➤ Number of main pumps	-NA-	-NA-	-NA-
	➤ Jockey Pump output	-NA-	-NA-	-NA-
	➤ Jockey Pump head	-NA-	-NA-	-NA-
	➤ Standby Pump output	-NA-	-NA-	-NA-
	➤ Standby Pump head	-NA-	-NA-	-NA-
	➤ Auto Starting/Manual Stopping.	-NA-	-NA-	-NA-
	• Terrace Level			
	➤ Discharge of pump	-NA-	-NA-	-NA-
	➤ Head of pump	-NA-	-NA-	-NA-
	➤ Power supply.	-NA-	-NA-	-NA-
	➤ Auto starting of pump	-NA-	-NA-	-NA-
14.	Captive water storage for fire-fighting.			
	• Underground tank capacity	-NA-	-NA-	-NA-
	➤ Draw-off connection.	-NA-	-NA-	-NA-
	➤ Fire Service Inlet	-NA-	-NA-	-NA-
	➤ Access to tank	-NA-	-NA-	-NA-
	• Overhead tank capacity	-NA-	-NA-	-NA-
15.	No Smoking Signage (Hindi & English)	Required	Provided (Hindi & English)	MR
16.	Provision of Lifts.			
	• Pressurization of lift shaft.	-NA-	-NA-	-NA-
	• Pressurization of lift lobby	-NA-	-NA-	-NA-
	• Communication in lift car.	-NA-	-NA-	-NA-
	• Fireman's switch.	-NA-	-NA-	-NA-
	• Lift signage	-NA-	-NA-	-NA-
17	Standby Power Supply	-NA-	-NA-	-NA-
18.	Refuge Area			
	• Total area	-NA-	-NA-	-NA-
	• Location	-NA-	-NA-	-NA-

19.	Fire Control Room.			
	• Detector System Panel	-NA-	-NA-	-NA-
	• Flow Switch Panel	-NA-	-NA-	-NA-
	• PA system Panel	-NA-	-NA-	-NA-
	• Battery backup	-NA-	-NA-	-NA-
	• Building floor plan	-NA-	-NA-	-NA-
20.	Special Fire Protection System for the Protection of special Risk, if any.	NA	Sand Fire buckets (30 nos) provided	MR ✓

The fire protection system such as fire extinguisher of different type and capacity, Fire buckets filled with loose dry sand & water provided at suitable places in the retail outlet area were checked and found functional at the time of inspection. "No Smoking" sign board were found displayed both Hindi & English at conspicuous places. No loose electrical wiring was seen in the premises.


Keeping in view of the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under rules, renewal of the FSC issued vide letter No. F6/DFS/MS/Petrol/2020/SZ/244 Dated 13/07/2020, under rules 37 of the Delhi Fire Service Rules 2010 is recommended.


Accordingly, DFA is put up for approval and signature please.


 Signature of the Inspecting Officer
 Name: Sh. Rajesh Kumar
 Designation: ADO (BCP)

DO (SD)


 OTH DFS is renewing PP cases. clarify.


 01/06/2023

~~Director~~ DO (FPW) 

ADO (FPW) 

Sir, As per provisions of Clause 6.6.1.1 of NBC part 4, Petrol filling station are classified as Mercantile buildings. Accordingly applicable sub Rule under Rule 27 of DFS Rules in subrule-8. Submitted for.


 14/6/23

DO (FPW) 

Dy. CFO 