

FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS/SZ/2023/ 446

Dated: 27/06/2023

**FIRE SAFETY CERTIFICATE**

Certified that the building of Gaur Public School Located at A-20, Rajapuri, New Delhi 110059, comprised of Ground + One Upper Floor was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/School/2020/SZ/200, dated 22/06/2020. The premise was re-inspected by the officer concerned of this department on 13/06/2023 in the presence of Ms. Renu Sharma (Principal). All the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deem complied with the fire prevention and fire safety requirements in accordance with DOI 3298-3398 dated 1-3-2011 issued by the Director of Education and that the building/ premises is fit for occupancy class "Educational" with effect from 27/06/23 for a period of three years, subject to compliance of the condition given below.

Issued on 27/06/2023 at New Delhi by

  
Anil Garg  
Director  
Delhi Fire Service

Copy to -

1. The Principal, Gaur Public School, at A-20, Rajapuri, New Delhi - 110059.
2. Directorate of Education Old Secretariat Delhi - 110054.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

INSPECTION REPORT

- 1 Name & address of the building: Gaur Public School Located at A-20, Rajapuri, New Delhi - 110059
- 2 Type of Occupancy: Educational (Ground + One Upper Floor)
- 3 Type of Case: Renewal
- 4 Details of previous NOC: 16/DI/S/MIS/School/2020/SZ/200, dated 22/06/20
- 5 Fire Safety directives Letter No: DOI 3298-3398 dated 01-07-2011
- 6 Date of inspection: 13/06/2023
- 7 Name of the Inspecting Officer: ADO (DWK)
- 8 Name and designation of Officer:  
from the building side: Ms. Renu Sharma (Principal)
- 9 Year of Construction: 2005
- 10 Applicant's letter No: Form J dated 01/06/2023

Total Area: 200 sq yrd
Covered Area: 200 sq yrd
Class rooms: 07
No. of students: 152

S No	Minimum standards on fire prevention and fire safety U/R 37	As per N/9, N/10 & N/11	Provided at site	Remarks MR/NMR
1	Access of building			
	• Road width	06 mtr	Provided	MR
	• Gate width	4.5 mtr	Directly accessible from road	MR
	• Width of internal road	NA	NA	NA
2	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	01 No.	01	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m	1m to 1.5m	MR (Being old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1 m	80 cm to 1m	MR (Being old case)
	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	NA	NA	NA



N/14

15	Exit Signage		NA	NA	NA
16	Provision of Lifts				
	➤ Pressurization of Lift Shaft		NA	NA	NA
	➤ Pressurization of lift lobby		NA	NA	NA
	➤ Communication in lift Car		NA	NA	NA
	➤ Fireman's Grounding Switch		NA	NA	NA
	➤ Lift Signage		NA	NA	NA
17	Standby power supply		NA	NA	NA
18	Refuge Area				
	➤ Total area		NA	NA	NA
	➤ Location		NA	NA	NA
19	Fire control room				
	➤ Detector system panel	NA		NA	NA
	➤ Flow Switch Panel	NA		NA	NA
	➤ PA System Panel	NA		NA	NA
	➤ Battery backup	NA		NA	NA
	➤ Building Floor Plans	NA		NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any.	Required	ABC fire extinguisher provided near electric meter		MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter No 16/DIS/MS/School/2020/S/200, dated 22/06/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

15/6/23

Signature of the Inspecting Officer  
Name Uday Kumar Singh  
Designation DDO/DWR

D/SW Please speak by 16/6/23

Spoken to ADO (Dwarka) on dated 19.6.2023 and ADO

Dwarka explained that the width of staircase is varying from 1m to 1.5m. It is recommended that the same

may be accepted being an old case.