

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE  
NEW DELHI-110001

No. F.6 DFS/MS/School/2023/SZ/ 437

Dated: 27/06/2023

**FIRE SAFETY CERTIFICATE**

Certified that the GGSSS (ID 1923047) & GBSSS (ID 1923011) Sector 5, Dr. Ambedkar Nagar, New Delhi -110062 comprised of 01 Block, Ground plus Two upper floors owned/occupied by Directorate of Education, Govt. of NCT of Delhi was issued FSC by this department vide letter no. F6/MS/DFS/School/2014/SZ/1551 dated 11/12/2014 for Ground plus one upper floor. The premises was re-inspected by officer concerned of this department on 16/06/2023 in presence of Mrs. Neeta Varshneya (Principal) and found that the said school building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "Educational Building Group – B" with effect from 27/06/2023 for a period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of Delhi Fire Service Rules 2010.

Issued on 27/06/2023 at New Delhi by

(ATUL GARG)  
DIRECTOR  
DELHI FIRE SERVICE

Copy to:-

1. The Assistant Engineer (E) DITDC LMT, Srinivaspur, Lajpat Nagar, Near Cambridge School, Ring Road, New Delhi 110065
2. The Principal, GGSSS (ID 1923047) & GBSSS (ID 1923011) Sector 5, Dr. Ambedkar Nagar, New Delhi -110062

**Conditions for the validity of Fire Safety Certificate**

1. All the means of escape/entry/exit shall be kept free from any obstruction
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management
3. All the staff members must know the correct method of operation of firefighting system
4. This certificate cannot be treated as regularization of unauthorized construction, if any
5. The owner/ occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry."



# INSPECTION REPORT

1	Name & Address of the Building	GGSSS (ID 1923047) & GBSSS (ID 1923011) Sector 5, Dr. Ambedkar Nagar, New Delhi		
2	Type of Occupancy	Educational, Group-B		
3	Building Comprised of	One Block, Ground plus 02 Upper Floor		
4	Type of Case	Addition alteration		
5	Details of Previous NOC	F6/MS/DFS/School/2014/SZ/1551 dated 11/12/2014 for Ground plus one upper floor		
6	Fire Safety Directives Letter No	UBBL 2016		
7	Date of Inspection	16/06/2023		
8	Name of the Inspecting Officers	Sh. Rajesh Kumar ADO (BCP)		
9	Name & Designation of Officers from the building side	Mrs. Neeta Varshneya (Principal)		
10	Year of construction	2023		
11	Applicant letter No	Email dated 13/06/2023		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	UBBL-2016 requirements	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	<ul style="list-style-type: none"> <li>Road width</li> <li>Gate width</li> <li>Width of internal road</li> </ul>	Required -NA- -NA-	9 mtr -NA- -NA-	MR -NA- -NA-
2	Number, width, type & arrangement of exits.			
	a) Number of Staircase			
	<ul style="list-style-type: none"> <li>Upper floors</li> <li>Basement floor</li> </ul>	03 Nos -NA-	03 Nos -NA-	MR -NA-
	b) Width of Staircase			
	<ul style="list-style-type: none"> <li>Upper floors</li> <li>Basement floor</li> </ul>	1.50m each -NA-	1.50 m each -NA-	MR -NA-
	c) Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Pressurization</li> </ul>	-NA- -NA-	-NA- -NA-	-NA- -NA-
	d) No. of continuous staircase to terrace	03 Nos	03 Provided	MR
	e) Width of corridor	-NA-	-NA-	-NA-
	f) Door size	1.0 mtr	1.0 mtr	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> <li>Fire check door</li> <li>Sealing of electrical shafts</li> <li>Fire rating of shaft door</li> <li>Water curtain</li> <li>Fire dampers</li> </ul>	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
4	Smoke Management system.			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper floors</li> </ul>	-NA- -NA-	-NA- -NA-	-NA- -NA-
5	Fire Extinguishers.			
	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI Marking</li> </ul>	50 No's ABC / co2 ISI mark	72 Nos ABC / Co2 Type Provided	MR MR MR
6	First Aid Hose Reels.			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose-reel hose</li> <li>Nozzle Diameter</li> </ul>	03 at each 30 mm 5 m	Provided Provided Provided	MR MR MR
7	Automatic fire detection & alarming system.			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's location</li> </ul>	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-	-NA- -NA- -NA- -NA- -NA-
8	MOEFA	-NA-	-NA-	-NA-
9	Public Address System	-NA-	-NA-	-NA-



10.	<b>Automatic Sprinkler System</b>				
	• Basement	-NA-	-NA-		-NA-
	• Upper floors	-NA-	-NA-		-NA-
	• Sprinkler above false ceiling	-NA-	-NA-		-NA-
11.	<b>Internal Hydrants.</b>				
	• Size of Riser/Down-comer	-NA-	-NA-		-NA-
	• Number of Hydrant per floor	-NA-	-NA-		-NA-
	• Hose box	-NA-	-NA-		-NA-
12.	<b>Yard Hydrants.</b>				
	• Total number of hydrants	-NA-	-NA-		-NA-
	• Hose box	-NA-	-NA-		-NA-
13.	<b>Pumping arrangements.</b>				
	• <b>Ground Level</b>				
	➢ Discharge of main pump	-NA-	-NA-		-NA-
	➢ Head of main pump	-NA-	-NA-		-NA-
	➢ Number of main pumps	-NA-	-NA-		-NA-
	➢ Jockey Pump output	-NA-	-NA-		-NA-
	➢ Jockey Pump head	-NA-	-NA-		-NA-
	➢ Standby Pump output	-NA-	-NA-		-NA-
	➢ Standby Pump head	-NA-	-NA-		-NA-
	➢ Auto Starting / Manual Stopping	-NA-	-NA-		-NA-
	➢ Pump house access	-NA-	-NA-		-NA-
	• <b>Terrace Level</b>				
	➢ Discharge of pump	450 LPM	2 x 450 LPM		MR
	➢ Head of pump	40 m	Provided		MR
	➢ Power supply	Required	Provided		MR
	➢ Auto starting of pump	Required	Provided		MR
14.	<b>Captive water storage for fire fighting.</b>				
	• Underground tank capacity	-NA-	NA		-NA-
	➢ Draw-off connection	-NA-	-NA-		-NA-
	➢ Fire Service Inlet	-NA-	-NA-		-NA-
	➢ Access to tank	-NA-	-NA-		-NA-
	• Overhead tank capacity	10,000 ltrs each	Provided		MR
15.	<b>Exit Signage.</b>	Required	Provided		MR
16.	<b>Provision of Lifts.</b>				
	• Pressurization of lift shaft	-NA-	-NA-		-NA-
	• Pressurization of lift lobby	-NA-	-NA-		-NA-
	• Communication in lift car	-NA-	-NA-		-NA-
	• Fireman's switch	-NA-	-NA-		-NA-
	• Lift signage	-NA-	-NA-		-NA-
17.	<b>Standby Power Supply</b>	-NA-	-NA-		-NA-
18.	<b>Refuge Area</b>				
	• Total area	-NA-	-NA-		-NA-
	• Location	-NA-	-NA-		-NA-
19.	<b>Fire Control Room.</b>				
	• Detector system panel	-NA-	-NA-		-NA-
	• Flow switch panel	-NA-	-NA-		-NA-
	• PA system panel	-NA-	-NA-		-NA-
	• Battery backup	-NA-	-NA-		-NA-
	• Building floor plan	-NA-	-NA-		-NA-
20.	<b>Special Fire Protection System for the Protection of special Risk, if any.</b>	-NA-	-NA-		-NA-

The fire protection system provided in the building were randomly checked and found functional at the time of inspection

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010

Accordingly, DFA is put up for approval and signature please

14  
21/6/27

Signature of the Inspecting Officer  
Name Sh. Rajesh Kumar  
Design ADO (BCP)

10 (SP)

must  
m/b.

CFO

22/6/2027

Director

22/6/27 FI PS

any BLO

As approved, F-1 letter is put up for  
your signature P1

14  
26/6

Director 26/6/27

OK