

C-8

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/EH/NDZ/2023/ 206

Dated: 30/06/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s Al Jawahar Restaurant at property No. 8, 12, and 15, Bazar Matia Mahal, Jama Masjid, Delhi, in a building comprised of Ground + Mezzanine + 03 upper floors, restaurant running at Ground & mezzanine floor only, first floor (owner residence), 2nd & 3rd floor (Guest House). The premises was inspected by the officer concerned of this department on 27/06/2023 in the presence of Mr. Akhtar Qureshi and found that the said restaurant premises has complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Assembly Building (Group D) restaurant at Ground & Mezzanine floor only and valid up to 31 March 2026 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 30/06/2023..... at New Delhi by.


(Anil Garg)
DIRECTOR
Delhi Fire Service
9/6/2023

Copy to:-

1. The Commissioner, MCD, Civic Centre, New Delhi : to kindly ensure the occupancy as detailed above and deviation in construction if any.
2. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi.
Online Id no. 2023060910586 dated 09.06.2023.
3. The Manager, Al Jawahar Restaurant, Shop No 8, 12, and 15, Bazar Matia Mahal, Jama Masjid, Delhi.

Conditions for the validity of Fire Safety Certificate

1. The FSC is valid for restaurant at ground and mezzanine floor.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained fire fighting staff should be available round the clock.
5. The compliance with regards to electrical installation, structural stability, set back area , occupancy and any deviation in construction etc. shall be verified from authority concerned.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
10. Any flammable material for interior decoration is prohibited.

INSPECTION REPORT

1. Name & address of the building **M/s Al Jawahar Restaurant, Property No. 8,12, and 15, Bazar Matia Mahal, Jama Masjid, Delhi.**
2. Type of occupancy:- **Assembly Building Group-D**
Ground + Mezzanine + 03 upper floor
Restaurant running at Ground & Mezzanine floor
first floor (Owner Residence), 2nd & 3rd floor (Guest House)
3. Type of case:- **New**
4. Details of previous FSC:- **Nil**
5. Fire safety directives No.- **N/A**
6. Date of inspection:- **27/06/2023**
7. Name of the inspecting officer:- **Sh. Rajinder Atwal (DO/CD)**
8. Name & designation of officer
From the building side:- **Mr. Akhtar Quareshi**
9. Year of construction:- **1965**
10. Applicant's letter No:- **Online Id no. 2023060910586 dated 09.06.2023.**

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	09 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02 nos	02 nos	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors (mezzanine)	1.5 mtr.	1.6 mtr, 1.5 mtr	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01	MR
	E. Width of corridor	1.5 mtr.	1.5 mtr.	M/R
	F. Door size	1.5 mtr. x 2	1.5 mtr. x 2	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 a/c per hour	Exhaust fan	MR
5.	Fire Extinguishers			
	1) Total numbers	04 Nos.	06 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR


		Required	Provided	MR
	3) ISI marking			
6.	First-Aid Hose Reel			
	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	Provided	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	Provided	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants per floor	01 no.	01 no.	MR
	3) Hose box	Required	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	900 LPM	MR
	b) Head of pump	30 mtr.	30 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	Required	Provided	MR
	c) Access to tank	Required	Provided	MR

	d) Over head tank capacity	20,000 ltr.	24,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection. The guest house namely Al sana Guest House is located at second and third floor and having separate entry /exit. The FSC to the guest house has been issued vide letter no. F/6/DFS/MS/GH/NDZ/2021/334 dated 25.08.2021.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety for the restaurant at ground and mezzanine floor required under the rules, if agreed, the Fire Safety Certificate under rule 35 of Delhi Fire Service Rules-2010 is recommended for approval.

Signature of the Inspecting Officer


 27/6/23
 Name :- Rajinder Atwal
 Designation :- DO (CD)

Dy. C.F.O (NDZ) - on leave

C.F.O Mugh
 27/6/2023

Director/NDZ
 20/6/23

DO/CD

As approved, F.T letter is for
 for signatures please.

Director/NDZ
 21/6/23

Uploaded