

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/Audi/2023/SZ/ 319

Dated 03/07/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s Auditorium Building located at Chinmaya, Mission, 89, Lodhi Road, New Delhi-110003, comprised of Basement, Ground Plus Two upper but Auditorium at first floor only) owned / occupied by Sir Chinmaya Mission was issued Fire Safety Certificate by this department vide letter No F6/DFS/MS/Audi/2020/SZ/262 dated 17/07/2020. The premises was re-inspected by the officer concerned of Fire Service on 23/06/2023 in the presence of Sh Umesh (Public Relation Officer) and found that the said premises have deemed complied with the fire prevention and Fire Safety requirement in accordance with rule 33 of the Delhi Fire Service rules, 2010 and that the premises is fit for occupancy Class Group "D" Assembly (Auditorium) as above with effect from 03/07/2023 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under 38 of the Delhi Fire Service rules, 2010.

Issued on 03/07/2023 at New Delhi by


(AJUL GARG)
DIRECTOR
Delhi Fire Service
o/e

Copy to -

1. Sh. Umesh (Public Relation Officer), M/s Chinmaya, Mission, 89, Lodhi Road, New Delhi-110003
2. The Addl. Commissioner of Police (Lic.), 1st Floor, PS Defence Colony, New Delhi-110049

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times
3. Any loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management
4. All the staff members must know the correct method of operation of fire fighting system
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form J [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhi.govt.nic.in

- 1 Name & address of the building : M/s Auditorium Building located at Chinmaya Mission, 89, Lodhi Road, New Delhi-110003.
- 2 Type of Occupancy : Assembly Building (Auditorium)
- 3 Building Comprised of : Basement + Ground +02 Floor
: Basement- Storage & service,
: Ground floor- Open Hall
: 1st Floor- Auditorium having 430 seats.
: 2nd Floor- offices & Residence of Swamiji
Renewal
- 4 Type of Case
- 5 Details of previous NOC : F6/DFS/MS/Audi/2020/SZ/262 dated 17/07/2020
- 6 Fire Safety directives Letter No : F6/DFS/MS/BP/94/902 dated 16/06/1994
- 7 Date of inspection : 23/06/2023
- 8 Name of the Inspecting Officer : Sh. Santosh Kumar, A.D.O (S.J)
- 9 Name and designation of Officer from the building side : Sh. Umesh (Public Relation Officer)
- 10 Year of Construction : 1996
- 11 Applicant's letter no : Outdoor Diary No 2865 dated 16/06/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	Old NOC Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9.0 mtrs	15 mtrs	MR
	• Gate width	5.0 mtrs	5.0 mtrs	MR
	• Width of internal road	N/A	N/A	N/A
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	GF to FF= 03 Nos FF to SF= 02 Nos	GF to FF= 03 Nos FF to SF= 02 Nos	MR
	• Basements	2 Nos	2 Nos	MR
	b. Width of staircases			
	• Upper floors	Required	2 nos. 2.40m each upto SF & 1 no. 1.5 mtrs upto FF	MR (old case)
	• Basements	Required	1.70 mtrs & 2.40 mtrs	MR (old case)
	c. Protection of exits			
	• Fire check door	Required	Provided at basement floor only	MR
	• Pressurization	N/A	N/A	N/A
	d. No of continuous staircase to terrace	Required	04 nos	MR
	e. Width Of Corridor	1 no	Provided	MR
	f. Door Size	1.2 mtrs each	3 exit gates at 1 st floor (1.6m, 1.6m & 1.50m)	MR
3.	Compartmentation			
	• Fire check door	Required	Provided in basement	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	N/A	N/A	N/A
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4.	Smoke managements System			
	• Basements	30 ACPH	Provided	MR
	• Upper floors	12 ACPH	Exhaust fan provided	MR
5.	Fire Extinguishers			
	• Total numbers	12 Nos	14 Nos	MR
	• Types	ABC/co2	Provided	MR
	• ISI marking	Required	Provided	MR

6	First - Aid Hose Reels			
	• Total numbers on each floor	Required	1 no. & 2 nos additional in Auditorium	MR
	• Length of hose reel hose	30 mtrs	30 mtrs	MR
	• Nozzle diameter	5 mm	5mm	MR
7	Automatic fire detection and alarming system			
	• Type of detector	Required	Smoke type	MR
	• Location of Main Panel	Required	Ground Floor	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Audible in entire building	Audible in entire building	MR
8	MOEFA	Required	Provided	MR
9	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	Required	Provided at stage only	MR
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	150mm	150mm	MR
	• Number of hydrants per floor	1 no	Provided	MR
	• Hose Box	1 no	Provided	MR
12	Yard Hydrants			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
3	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	N/A	N/A	N/A
	➤ Head of main pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby Pump out put	N/A	N/A	N/A
	➤ Standby Pump Head	N/A	N/A	N/A
	➤ Auto Starting/Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace level			
	➤ Discharge of pump	900 + 180 LPM	900 + 180 LPM	MR
	➤ Head of the pump	40 m	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14	Captive water Storage for fire fighting			
	• Underground tank capacity	1,00,000 ltr	Provided	MR
	➤ Draw of connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	20,000 ltr	Provided	MR

		Required	Provided	MR
15	Exit Signage			
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	N/A	N/A	N/A
	➤ Pressurization of lift lobby	N/A	N/A	N/A
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection.

Further, the party has complied all the observation/ shortcoming already issued & communicated by this department vide letter no. F6/DFS/MS/Auditorium/SZ/2023/53 dated 17/03/2023.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/Audi/2020/SZ/262 dated 17/07/2020 renewal under rule 37 of the Delhi Fire Service rules 2010 is recommended.

Santosh Kumar
26.06.23

Signature of the Inspecting Officer
Name : Santosh Kumar
Designation: A.D.O. (S.J.)

00/CS/S

msb