



C/68

75
आज़ादी का
अमृत महोत्सव

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001

No. F6/DFS/MS/EH/WZ/2023/196

Dated: 19 / 06 / 2023

FIRE SAFETY CERTIFICATE

Certified that the Haldiram Products Pvt. Ltd, Located at Ground Floor & Basement (for Storage purpose), 17-A Shivaji Marg, Main Najafgarh Road, Karampura Moti Nagar, New Delhi-110015, in a building comprised of Basement + Ground + 02 upper floors, owned/occupied by Haldiram Products Pvt. Ltd., was already issued FSC by this department Vide letter no. F6/DFS/MS/EH/2020/WZ/433 dated 27/10/2020. The Premises was re-inspected by the officer concerned of this department on 05/06/2023 in the presence of Sh. Sudhir Sharma and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and the premises/building is fit for occupancy class "Assembly" (Group - D) (Ground Floor & Basement (for storage purpose) Only) with effect from 19/06/2023 Upto 31.03.2026 in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. conditions printed overleaf.

Issued on ... 19/6/2023 ... at New Delhi by.

(Atul Garg)
Director

15/6/2023
15/6/2023

Copy to: -

1. Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. addlcp.lic-dl@nic.in
2. The Owner/occupier, M/s. Haldiram Products Pvt. Ltd Ground Floor, 17-A Shivaji Marg, Main Najafgarh Road, Karampura Moti Nagar, New Delhi-110015.
(Reference Online ID-No. 2023052609688 dated 26/05/2023).
3. Dy. Health Officer, West Zone, MCD, Shivaji Enclave, Raja Garden, New Delhi-110027. (dhwestzone@gmail.com).

INSPECTION REPORT

1. Name & address of the building	Haldiram Products Pvt. Ltd, Located at 17-A Shivaji Marg, Main Najafgarh Road, Karampura Moti Nagar, New Delhi-110015.
2. Type of Occupancy	Eating House /Assembly Occupancy
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/EH/2020/WZ/433 dated 27/10/2020
5. Fire Safety directives letter No	F6/DFS/MS/BP/2014/1702 dated 25/07/2014
6. Date of inspection	05/06/2023
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Sudhir Sharma
9. Year of Construction	2010 (As per previous insp. report dtd.- 21/10/2020)
10. Applicant's letter No.	Online Application ID No. 2023052609688 dated 26/05/2023

The Said Restaurant is running at Ground floor & Basement uses for storage purpose, in a Building Comprised of Basement + Ground + 02 upper floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	As per Rule 35 (6) DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	09 m	60 m Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	As per sanctioned plan	Provided	MR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	NA	At Ground floor	NA
	• Basements	02	02 Provided	MR
	b. Width of staircases			
	• Upper Floors	NA	NA	NA
	• Basements	1.50 mtr.	Provided	MR
	c. Protection of exits			
	• Fire check door	Required in Basement	Provided	MR
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	f. Width of Corridor	1.50 mtr.	Halls only	MR
	g. Door Size	2 m x 2 for restaurant	Provided	MR
3	Compartmentation.			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	Required	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	10	12 Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

Signature

Signature

6	First-Aid Hose Reels.			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	G.F	Provided	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• Upper Floor	NA	Provided	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	02	Provided	MR
	• Hose Box	02	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	04	Provided	MR
	• Hose Box	04	Provided	MR
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	2280 LPM	Provided	MR
	➤ Head of Main pump	50 MH	Provided	MR
	➤ Number of main pumps	01	Provided	MR
	➤ Jockey Pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	50 MH	Provided	MR
	➤ Standby Pump out put	2280 LPM	Provided	MR
	➤ Standby Pump Head	50 MH	Provided	MR
	➤ Auto Starting/ Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	900 LPM	Provided	MR
	➤ Head of the pump	50MH	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	50,000 ltrs	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR

Provision of Lifts.				
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/EH/2020/WZ/433 dated 27/10/2020 renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

[Signature]
06/06/2023

Signature of the Inspecting Officer
Name: - Sarabjeet Singh
Designation: - ADO (MN)

[Signature]
16/6/2023

[Signature]
Dy CEO (sk/mkc)

[Signature]
06/06/2023

[Signature]
Dt. 15/6/2023

[Signature]
CFO

Mention the date of validity as per new policy of Restaurants / Eating House.

[Signature]
21/6/2023

[Signature]
Dy CFO (sk/mkc)

[Signature]