



No.F6/DFS/MS/School/NDZ/2023/ 453

Dated: 03/07/2023

**FIRE SAFETY CERTIFICATE**

Certified that the Pt. Yadram Secondary Public School, Located at Dispensary Chowk, Tanki Road, Near P.N.B. Bank, Bhajanpura, Delhi-110053, building comprised of Ground, First floor, Second floor & Third floor but school is running on Ground, First floor & Second floor only owned / occupied by Pt. Yadram Secondary Public School, was issued FSC vide letter No. F6/DFS/MS/School/2018/482 dated 22.03.2018. The School building was re-inspected by the officer concerned of this department on 16/06/2023 in presence of Mr. Lokesh Vats (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building is fit for occupancy class "Educational" (Group-B) with effect from 03/07/2023 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rule 2010.

Issued on 03/07/2023 at New Delhi by.

(ATUL GARG)

DIRECTOR

DELHI FIRE SERVICE

c/c @

**Copy to:-**

1. The Principal, Bright Pt. Yadram Secondary Public School, Dispensary Chowk, Tanki Road, Near P.N.B. Bank, Bhajanpura, Delhi-110053.
2. The Dy. Director of Education, B- Block, Yamuna Vihar, Delhi-110053.

**Conditions for the validity of Fire Safety Certificate**

1. Fire Safety Certificate is valid for Ground & 2 upper floor only.
2. The owner /occupier shall apply for renewal of this fire safety certificate to the Director in form J' [sub rule(1) of rule 37] along with a copy of this certificate, six months prior to its expiry
3. All the means of escape shall be kept free of all the type of obstruction all the time.
4. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
5. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
6. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
7. This Fire Safety Certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).

## INSPECTION REPORT

1	Name & address of the building	Pt. Yadram Secondary Public School located at Dispensary Chowk, Tanki Road, Near P.N.B. Bank, Bhajanpura, Delhi-110053.		
2	Building is comprised of	Ground + 3 upper floor only but 3 <sup>rd</sup> floor sealed. (School Running at Ground, First floor & Second floor)		
3	Type of occupancy	Group B - Educational Building		
4	Type of case	Renewal		
5	Details of previous FSC	F6/DFS/MS/School/2018/482 dated 22.03.2018		
6	Fire safety directives letter no.	NBC Part-IV		
7	Date of inspection	15/06/2023		
8	Name of the inspecting officers	Yashwant Singh Meena ADO (L.N)		
9	Name of the designation of officer from the building side	Mr. Lokesh Vats (Manager)		
10	Year of construction	1992		
11	Applicant's letter no.	Outdoor Diary No.2644 dated 08/06/2023		
S.No	Minimum standard of fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to Building:</b>			
A	Road width	6.0 mtrs.	8.0 mtrs.	MR
B	Gate width	NA	NA	NA
C	Width of internal road	NA	NA	NA
2	<b>Number, Width, Type and Arrangement of Exits:</b>			
A	<b>Number of staircases</b>			
a	Upper floor	02 nos.	02 nos.	MR
b	Basement	NA	NA	NA
B	<b>Width of staircases</b>			
a	Upper floor	1.50 mtrs	1.30 mtrs & 1.10 mtrs	MR (Old accepted) ✓
b	Basement	NA	NA	NA
C	<b>Protection of exits</b>			
a	Fire check door	NA	NA	NA
b	Pressurization	NA	NA	NA
D	No. of continuous staircases to terrace	01 no.	02 nos.	MR
E	Width of corridor	1.50 mtrs.	2.0 mtrs.	MR
F	Door size	1.0 mtrs	1.0 mtrs	MR
3	<b>Compartmentation:</b>			
A	Fire check door	NA	NA	NA
B	Sealing of electrical shafts	NA	NA	NA
C	Fire rating of shaft door	NA	NA	NA
D	Water curtain	NA	NA	NA
E	Fire dampers	NA	NA	NA
4	<b>Smoke Management System:</b>			
A	Basement	NA	NA	NA
B	Upper floor	NA	NA	NA

<b>5.</b>	<b>Fire Extinguisher:</b>				
	<b>A</b>	Total numbers	10 nos.	12 nos.	MR
	<b>B</b>	Types	ABC/CO <sub>2</sub>	ABC/CO <sub>2</sub>	MR
	<b>C</b>	ISI marking	ISI Marked	Provided	MR
<b>6</b>	<b>First-Aid-Hose Reel:</b>				
	<b>A</b>	Total numbers of each floor	02 nos.	02 nos.	MR
	<b>B</b>	Length of hose reel hose	30 mtrs.	30 mtrs.	MR
	<b>C</b>	Nozzle diameter	05 mm	05 mm	MR
<b>7</b>	<b>Automatic Fire Detection and Alarming System:</b>				
	<b>A</b>	Type of detectors	NA	NA	NA
	<b>B</b>	Location of main panel	NA	NA	NA
	<b>C</b>	Location of repeater panel	NA	NA	NA
	<b>D</b>	Alternate source of power	NA	NA	NA
	<b>E</b>	Hooters	NA	NA	NA
<b>8</b>	<b>MOEFA:</b>		NA	NA	NA
<b>9</b>	<b>Public Address System:</b>		NA	NA	NA
<b>10</b>	<b>Automatic Sprinkler System:</b>				
	<b>A</b>	Basement	NA	NA	NA
	<b>B</b>	Upper floor	NA	NA	NA
	<b>C</b>	Sprinkler above false ceiling	NA	NA	NA
<b>11</b>	<b>Internal Hydrants:</b>				
	<b>A</b>	Size of riser/down-comer	NA	NA	NA
	<b>B</b>	Number of hydrants per floor	NA	NA	NA
	<b>C</b>	Hose box	NA	NA	NA
<b>12</b>	<b>Yard Hydrants:</b>				
	<b>A</b>	Total number of hydrants	NA	NA	NA
	<b>B</b>	Hose box	NA	NA	NA
<b>13</b>	<b>Pumping Arrangements:</b>				
<b>1</b>	<b>Ground level</b>				
	<b>A</b>	Discharge of main pump	NA	NA	NA
	<b>B</b>	Head of main pump	NA	NA	NA
	<b>C</b>	Number of main pumps	NA	NA	NA
	<b>D</b>	Jockey pump out put	NA	NA	NA
	<b>E</b>	Jockey pump head	NA	NA	NA
	<b>F</b>	Standby pump out put	NA	NA	NA
	<b>G</b>	Standby pump head	NA	NA	NA
	<b>H</b>	Auto starting /manual stopping	NA	NA	NA
	<b>I</b>	Pump house access	NA	NA	NA
<b>2</b>	<b>Terrace Level</b>				
	<b>A</b>	Discharge of pump	450 LPM	450 LPM	MR
	<b>B</b>	Head of the pump	40 mtrs	40 mtrs	MR
	<b>C</b>	Power supply	Required	Provided	MR
	<b>D</b>	Auto starting of pump	Required	Provided	MR


W A

14 Captive Water Storage for Fire Fighting:				
A	Underground tank capacity	NA	NA	NA
B	Draw-off connection	NA	NA	NA
C	Fire service inlet	NA	NA	NA
D	Access to tank	NA	NA	NA
E	Overhead tank capacity	10,000 ltrs	10,000 ltrs	MR
15 Exit Signage:		Required	Provided	MR
16 Provision of Lifts:				
A	Pressurization of lift shaft	NA	NA	NA
B	Pressurization of lift lobby	NA	NA	NA
C	Communication in lift car	NA	NA	NA
D	Firemen's grounding switch	NA	NA	NA
E	Lift signage	NA	NA	NA
17 Standby Power Supply:		NA	NA	NA
18 Refuge Area:				
A	Total area	NA	NA	NA
B	Location	NA	NA	NA
19 Fire Control Room:				
A	Detector system panel	NA	NA	NA
B	Flow switch panel	NA	NA	NA
C	PA system panel	NA	NA	NA
D	Battery backup	NA	NA	NA
E	Building floor plans	NA	NA	NA
20 Special Fire Protection systems for protection of special Risks, if any:		NA	NA	NA

Note: - Building comprised of Ground, First floor, Second floor & 3<sup>rd</sup> floor but Management has given an undertaking dated 13.06.2023 placed at C-30 that they will not use 3<sup>rd</sup> floor for school purpose in any case 3<sup>rd</sup> floor sealed & photograph is attached at C-29.

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspections.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required in NBC (Part-IV) the FSC issued vide letter no. F6/DFS/MS/School/2018/482 dated 22.03.2018 is recommended to be renewed.

  
Signature of the Inspecting Officer  
Name Yashwant Singh Meena  
Designation ADO (L.N)

~~DO/RE~~ DFA please.  
21/06/2023  
Dy. CFO (ND2) on leave  
CFO (H.R.)  
22/06/2023  
Director (M)  
27/06/23

AD/IN  
F.T. Letter as backup for Sign. Please  
27/6/2023