

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110 001.**

No.F.6/DFS/MS/School/2023/SZ/459

Dated: 04/07/2023

FIRE SAFETY CERTIFICATE

Certified that the **Shiv Modern School**, (Previously known as Shiv convent School), WZ-68-A, Sant Garh, New Delhi-110018, comprised of ground floor plus three upper floors (two rooms only at third floor) was issued FSC by this department vide letter No. **F.6/DFS/MS/School/2019/SZ/1835 dated 23/09/2019**, owned/occupied by Shiv Modern School. The School building was re-inspected by the officer concerned of this department on 26/06/2023 in the presence of Mrs. Shikha (Head Mistress) and found that building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the building/ premises is fit for occupancy class Group-B "Educational Building" w.e.f. the date of issue of this certificate for a period of **three years** in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule-38 of the Delhi Fire Service Rules, 2010 printed as below.

Issued on.....04/07/2023..... at New Delhi.


 (ATUL GARG)
 DIRECTOR
 DELHI FIRE SERVICE
 24

Copy to:-

1. Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi-110054

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. The means of escape arrangements shall be kept unlocked & unobstructed for speedy evacuation of occupants in case of an emergency.
3. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
4. The trained staff should be available round the clock.
5. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
6. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in the Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building :	Shiv Modern School, WZ-68-A, Sant Garh, New Delhi-110018.
2. Building comprised of :	Ground plus three upper floors. (2 rooms only at 3 rd floor)
3. Type of Occupancy :	Educational
4. Type of Case :	Renewal
5. Details of Previous NOC :	F.6/DFS/MS/School/2019/SZ/1835 dated 23/09/2019
6. Fire Safety directives letter No :	N/A
7. Date of inspection :	26/06/2023
8. Name of Inspecting Officer :	A.D.O. R.K.yadav
9. Name and designation of officers From the building side :	Mrs. Shikha (Head Mistress)
10. Year of Construction :	Before 2010
11. Applicant's letter No. :	SMS/06/2023/331 dated 02/06/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	DR Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible 06 mtrs. N/A N/A	Provided N/A N/A	MR N/A N/A
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	02 no.'s N/A	Provided N/A	MR N/A
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	1.50 & .75 m	1.50 m (GF to FF & SF to TF). 1.10 m (GF to TF) & 90 m (FF to SF)	MR
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door Pressurization 	N/A N/A	N/A N/A	N/A N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	Required	Provided	M/R
	f. Class Room Door Size	1.50 m	Provided	M/R
		1.0 m	1.05 m	M/R
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A	N/A N/A N/A N/A	N/A N/A N/A N/A
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	N/A Required	N/A Natural ventilation provided	N/A M/R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	08 no's ABC/CO ₂ type ISI marked	Provided Provided Provided	M/R M/R M/R
6.	First-Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	One 30 m 5 mm	Provided Provided Provided	M/R M/R M/R

Handwritten signatures and initials at the bottom left of the page.

N/LC

Ref
19.

7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Ground Floor Sprinkler above false ceiling 	N/A	N/A	N/A
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	N/A	N/A
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
13.	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		450 LPM	Provided	M/R
		30 mtrs	Provided	M/R
		Required	Provided	M/R
		Required	Provided	M/R
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		10000 ltrs	Provided	M/R
15.	Exit Signage.	Required	Provided	M/R
16.	Provision of Lifts.	No Lift		
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
17.	Standby power supply	N/A	N/A	N/A

↳ ✓

Refuge Area.			
> Total Area	N/A	N/A	N/A
> Location	N/A	N/A	N/A
19.	Fire Control Room		
<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risks, if any:		N/A

The fire protection systems provided in the building were tested, checked and found functional at the time of inspection. The Shortcomings issued vide letter No.F6/DFS/MS/School/2022/SZ/632 dated 10/10/2023 has been complied.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter number F.6/DFS/MS/School/2019/SZ/1835 dated 23/09/2019 renewal under rule 37 of the Delhi Fire Service Rules 2010 is recommended.

R.K. Yadav
26/6/2023

Signature of Inspecting Officer
Name:- R.K. Yadav
Designation:- Asstt. Divisional Officer

Divisional Officer (South West)

[Signature]
27/6/23

CPD (SZ)
[Signature]
27/6/2023

Director
[Signature]
27/6/23

Asstt. R.K. Yadav / JMD

FT letter - pickup for sign plan

DIRECTOR
[Signature]
27/6/23

[Signature]
27/6/23