



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No. F6/DFS/MS/BNQT/2023/NDZ/313

Dated: 30/06/2023

FIRE SAFETY CERTIFICATE

Certified that the **Shivay Banquet Hall (A unit of Spar Hospitality)** is running on **1st Floor** only, located at **PD Area, Jhilmil Metro Station, Delhi-110095**, in a building comprised of Ground & One Upper Floor only owned / occupied by A unit of Spar Hospitality, was earlier issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/BNQT/2020 NDZ/211 Dated 19/06/2020. The premises was re-inspected by the officers concerned of this department on 14/06/2023 in the presence of Sh. Mayank Bansal and observed that all the Fire prevention and Fire Safety arrangements provided in the premises found in good working condition. The premises have therefore, deemed complied with rule 33 of the Delhi Fire Service rules, 2010 and that the building / premises is fit for occupancy Class "**Assembly**" (**Group-D**) (**Banquet Hall**) at 1st Floor only) **valid up to 31/03/2026** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of conditions under 38 of the Delhi Fire Service rules, 2010.

Issued on ...30/06/2023..... at New Delhi.

(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE.

Copy to :-

1. Sh. Mayank Bansal, Shivay Banquet Hall (A unit of Spar Hospitality) PD Area, Jhilmil Metro Station, Delhi-110095.
2. Joint Commissioner of Police (Lic.) P. S. Defence Colony, New Delhi-110024 w.r.t MHA portal id no. 2023053009947 dated 02/06/2023.
3. The Dy. Health Officer, MCD, Public Health Department, Shahdara North Zone, Patparganj, Delhi-110092. w.r.t MHA portal id no. 2023053009947 dated 02/06/2023.

Conditions for the validity of Fire Safety Certificate:-

1. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non- functional fire safety measure shall be at the responsibility of the management.
3. The trained fire- fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form / [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry.
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Shivay Banquet Hall (A unit of Spar Hospitality)
PD Area, Jhilmil Metro Station, Delhi-110095.
2. Building is comprised of : Ground & One upper floor.
(Banquet is running on First Floor only)
3. Type of Occupancy : Assembly (Banquet Hall)
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/ Bnqt./2022/NDZ/211 Dated 19/06/2020
6. Fire Safety directives Letter No.: NBC Part-IV
7. Date of inspection : 14/06/2023
8. Name of the Inspecting Officer : Yashwant Singh Meena ADO(L/N) & A.K. Jaiswal D.O (E.D.)
9. Name and designation of Officer from the building side : Sh. Mayank Bansal
10. Year of Construction : 2019
11. Applicant's MHA portal application No. 2023053009947 dated 02/06/2023

S.No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part IV Requirement	Provided at Site	Remarks
1	Access to building			
	• Road width	9 m	28 m	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	02	02	MR
	• Basement	NA	NA	NA
	b. Width of Staircases			
	• Upper Floor	2 m	2 m & 3.45 m	MR
	• Basement	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	N/A	N/A	N/A
	e. Width of Corridor	2 m	2 m x 2	N/A
	f. Door size	02	02	MR
3	Compartmentation			
	• Fire check Door	Required	Provided	MR
	• Sealing of electrical Shafts	Required	Sealed	MR
	• Fire rating of Shaft Door	02 hrs	02 hrs	MR
	• Water Curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
4	Smoke Management System			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	N/A	N/A
5	Fire Extinguishers			
	• Total Numbers	08 Nos.	10 Nos.	MR
	• Types	ABC & Co2	ABC & Co2	MR
	• IS Marking	ISI Marked	ISI Marked	MR

@ A 50

c

6	First-aid-Hose Reels			
	Total numbers of each floor	02	02	MR
	• Length of hose reel hose	30 m	30 m	MR
	• Nozzle diameter	05 mm	05 mm	MR
7	Automatic fire detection and alarming system			
	• Type of detectors	Heat & Smoke	Provided	MR
	• Location of main panel	N/A	N/A	N/A
	• Location of repeater panel	N/A	N/A	N/A
	• Alternate source of power	Battery & DG Set	Provided	MR
	• Hooter's Location	Different Location	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public address System	Required	Provided	MR
10	Automatic Sprinkler System			
	• Basement	N/A	N/A	N/A
	• Upper Floor	N/A	Provided	N/A
	• Sprinkler above false Ceiling	N/A	Provided	N/A
11	Internal Hydrants			
	• Size of rise/down-comer	150 mm	150 mm	MR
	• Number of Hydrants per Floor	01 nos.	01 nos.	MR
	• Hose Box	01 nos.	01 nos.	MR
12	Yard Hydrants			
	• Total number of Hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangement Provided by DMRC			
	• Ground Level			
	➢ Discharge of main Pump	2850 & 1800 LPM	2850 & 1800 LPM	MR
	➢ Head of Main Pump	70 m	70 m	MR
	➢ Number of main Pumps	02 nos.	02 nos.	MR
	➢ Jockey pump output	180 LPM x 2	180 LPM x 2	MR
	➢ Jockey pump head	70 m	70 m	MR
	➢ Standby pump output	2850 LPM	2850 LPM	MR
	➢ Standby pump head	70 m	70 m	MR
	➢ Auto starting/Manual stopping	Required	Provided	MR
	➢ Pump house access	Required	Provided	MR
	• Terrace Level			
	➢ Discharge of pump	N/A	N/A	N/A
	➢ head of the pump	N/A	N/A	N/A
	➢ Power supply	N/A	N/A	N/A
	➢ Auto Starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting Provided by DMRC			
	• Underground tank capacity	2,00,000 Ltrs.	2,00,000 Ltrs.	MR
	➢ Draw-off connection	Required	Provided	MR
	➢ Fire service inlet	Required	Provided	MR
	➢ Access to tank	Required	Provided	MR
	• overhead Tank capacity	N/A	N/A	N/A
15	Exit Signage	Required	Provided	MR

W 2 9/

N/21

16	Provision of Lifts			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	Required	Provided	MR
18	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were randomly tested, checked and found non functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/ Bnqt/2022/NDZ/211 Dated 19/06/2020 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Signature of the Inspecting Officer
Name : Yashwant Singh Meena
Designation : ADO (LN)

Signature of the Inspecting Officer
Name : Ashok Kumar Jaiswal
Designation : D.O. (East Div.)

Dy. C.F.O. (NDZ)

19/06/23

C.F.O. 20/06/2023

Director

on file

DOH/NDZ

26/6/23

ADO/LN.

महोदय,

P.D. क्षेत्र का फायर फाइटिंग सिस्टम चेक करने के लिए आप के हस्ताक्षर के लिए।
F.T. Letter आपके हस्ताक्षर के लिए।
आप के हस्ताक्षर के लिए।