

C-12

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/EH/SZ/2023/ 215

Dated 10/7/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s. Supershot (A unit of Paul Sales Pvt. Ltd.) running at Ground plus three upper floors of a building comprised of basement, ground plus three upper floors located at A-21/17, Naraina Industrial Area, Phase-2, Naraina, New Delhi-110028, owned/occupied by (A unit of Paul Sales Pvt. Ltd.) have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Delhi Fire Service on 05.07.2023 in presence of Sh. Arun Kumar (Owner) and the building/premises is fit for occupancy class Assembly (Restaurant) at Ground plus three upper floor only with effect from 10/7/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued on 10/7/2023 at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Online Application ID - 2023062711648 dated 30.06.2023

Conditions for the validity of Fire Safety Certificate: -

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non-functional of fire safety measures shall be at the risk & responsibility of the management.
3. The trained firefighting staffs should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. All the means of escapes /exits shall not be locked/bolted/blocked at any time for safe evacuation of the occupants in case of any emergency.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form "J" [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Supershot, A unit of Paul Sales Pvt. Ltd., A-21/17, Naraina Industrial Area, Phase-2, Naraina, New Delhi- 110028
2. Type of Occupancy : Assembly (Restaurant)
3. Building Composition : Said restaurant is running at Ground plus three upper floors of a building comprised of basement, ground plus three upper floors.
4. Type of Case : New Case
5. Details of previous NOC : N/A
6. Fire Safety directives letter No : N/A
7. Date of inspection : 05.07.2023
5. Name of the Inspecting Officers : Vedpal Chhikara, DO (SW) & P.V. Rathee, ADO (SRD)
8. Name and designation of officers from the building side : Sh. Arun Kumar, Owner
9. Year of Construction : 2011
10. Applicant's letter No. : Online application ID 2023062711648 dated 30.06.2023

	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per NBC part-IV/ UBBL	Provided at site	Remarks MR/NMR
1	Access to building			
	<ul style="list-style-type: none"> Road width 	06 mts	Provided	MR
	<ul style="list-style-type: none"> Gate width 	Required	Directly Assessable from road	MR
	<ul style="list-style-type: none"> Width of internal road 	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	<ul style="list-style-type: none"> Upper Floors 	02	Provided	MR
	<ul style="list-style-type: none"> Basements 	02	Provided	MR
	b. Width of staircases	-	-	-
	<ul style="list-style-type: none"> Upper Floors 	2 mtr & 1.50 mts	2 mtr & 1.57 mts	MR
	<ul style="list-style-type: none"> Basements 	2 mtr & 1.50 mts	2 mtr & 1.57 mts	MR
	c. Protection of exits	-	-	-
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	MR
	<ul style="list-style-type: none"> Pressurization 	N/A	N/A	N/A
	e. No. of continuous staircases to terrace	02	02	MR
	g. Width of Corridor	N/A	N/A	N/A
	h. Door Size	2 mts & 1.5 mts	2.35 & 1.56 mts	MR
3	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	MR
	<ul style="list-style-type: none"> Sealing of electrical shafts 	Required	Provided	MR
	<ul style="list-style-type: none"> Fire Rating of shaft door 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Water Curtain 	N/A	N/A	N/A
	<ul style="list-style-type: none"> Fire Dampers 	N/A	N/A	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements 	30 a/c per hour	Exhaust fan provided	MR
	<ul style="list-style-type: none"> Upper floors 	12 a/c per hour	Exhaust fan provided	MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	20	Provided	MR
	<ul style="list-style-type: none"> Types 	CO ₂ , ABC type	Provided	MR
	<ul style="list-style-type: none"> IS marking 	ISI marked	Provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	01	Provided	MR
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	Provided	MR
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	Provided	MR

7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	Smoke	Provided	MR
		Required With in restaurant area	Provided	MR
		N/A	N/A	N/A
		Required	Provided	MR
		N/A	N/A	N/A
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Entire Restaurant Sprinkler above false ceiling 	Required	Provided	MR
		N/A	Provided	N/A
		N/A	N/A	N/A
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100 mm	Provided	MR
		01	Provided	MR
		01	Provided	MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	N/A
		N/A	N/A	N/A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level 	---	---	---
	➤ Discharge of main Pump	2280 lpm	Provided	MR
	➤ Head of Main pump	60m	Provided	MR
	➤ Number of main pumps	01	Provided	MR
	➤ Jockey Pump out put	180 LPM	Provided	MR
	➤ Jockey pump head	60m	Provided	MR
	➤ Standby Pump out put	2280 LPM	2280 LPM	MR
	➤ Standby Pump Head	60m	60 m	MR
	➤ Auto Starting/ Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	<ul style="list-style-type: none"> Terrace level 	-----	-----	-----
	➤ Discharge of pump	450 LPM	750LPM Provided	MR
	➤ Head of the pump	40 mts	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank Overhead Tank capacity 	1,00,000 lts	1,00,000 lts	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		20,000 lts	20,000 Ltrs Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		Required	Provided	MR


N/10

17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	Required	Provided	MR
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	Two ABC type fire extinguisher found provided near elect. panel	MR

The fire protection systems provided in the building were test checked at random and found satisfactory at the time of inspection.

If agreed in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the Rules, it is recommended to grant fire safety certificate under Rule 35 of Delhi Fire Service Act- 2007 & Rules- 2010.



Accordingly, DFA is put up for approval & signature please.

 7/7/23


Signature of the Inspecting Officer
Name- Vedpal Chhikara
Divisional Officer (SW)


 7/7/23

Signature of the Inspecting Officer
Name- P.V. Rathee Divisional
Asstt. Div. Officer (S.Rd)

CFO (S2) 
10/7/2023
Director 
10/7/23

KI P3


A.T. Letter is placed for S/O, please

Director 
10/7/23

Uploaded
10/7/23