



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001

689
75
आजादी का
अमृत महोत्सव


No. F6/DFS/MS/School/WZ/2023/ 471

Dated:- 13/07/2023

FIRE SAFETY CERTIFICATE

Certified that the **Ganga International School** Located at **Hiran Kudna, Rohtak Road, Delhi-110041**, comprised of **Ground + 02 Upper Floor only** owned/occupied by **Ganga International School** was issued Fire Safety Certificate by this department vide letter No. **F6/DFS/MS/School/WZ/2020/201 Dated 23.06.2020**. The said premise was re-inspected by the officer concerned of this department on 28.06.2023 in the presence of Sh. Sunil Bhatia (Accounts) and found that the premises / building have deemed complied with the fire prevention and fire safety requirements in accordance D.O.E., GNCT of Delhi, Circular no.262-362 dated 17.01.2005 and that the premises/building is fit for occupancy class **"Educational Building" Group B** with effect from **13/07/2023** for a period of **three years**, subject to compliance of the conditions, printed below.

Issued on **13/07/2023**... at New Delhi by.


(Atul Garg)
Director
Delhi Fire Service

Copy to: -

1. The Director, Directorate of Education, GNCT of Delhi, Old Secretariat Delhi – 110054.
2. The Principal, Ganga International School, Hiran Kudna, Rohtak Road, Delhi-110041.

Q. 82
10/07/23

Following fire safety directives must be adhered to:-

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner /occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name and address of the building: **Ganga International School, Located at Hiran Kudna, Rohtak Road, Delhi-110041**
 2. Type of Occupancy : Educational (G + 02 Upper Floor only)
 3. Type of Case : Renewal
 4. Details of previous NOC : F6/DFS/MS/School/WZ/2020/201 Dated 23.06.2020
 5. Fire Safety directives Letter No. : D.O.E Circular no.262-362 dated 17.01.2005
 6. Date of inspection : 28.06.2023
 7. Name of the Inspecting Officer : Aman Kumar Lathar, ADO (JWP)
 8. Name and designation of Officer from the building side : Sh. Sunil Bhatia (Accounts)
 9. Year of Construction : 2009-10
 - 10 Applicant's letter No. : email dated 26.06.2023
- The building Complex is comprised of Ground + 02 Upper Floor (School Block) & Ground + 03 Upper Floor (Hostel Block)

S No	Minimum standards on fire prevention and fire safety U/R 33	D.O.E. Circular No. 262-362 Dated 17.01.2005/ as per FSC dated 23.06.2020	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	06 m	Provided	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 m	2.5 m x 2	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	Provided	MR
	e. Width Of Corridor	1.5 m	Provided	MR
	f. Door Size	1 m	Provided	MR
3.	Compartmentation		NA	
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types ISI marking 	40 nos. ABC & CO ₂ ISI marked	45 nos. Provided Provided	MR MR MR
6.	First – Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01 30 m 05 mm	Provided Provided Provided	MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8.	MOEFA	Required	Provided	MR
9.	Public Address System			
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	100 mm 01 01	Provided Provided Provided	MR MR MR
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	NA NA NA NA NA NA NA NA NA NA NA NA NA NA 450 lpm & 180 lpm 40 m Required Required	NA NA NA NA NA NA NA NA NA NA NA NA Provided Provided Provided Provided	NA NA NA NA NA NA NA NA NA NA NA MR MR MR MR
14.	Captive water Storage for fire fighting:			
	<ul style="list-style-type: none"> Under ground tank capacity Draw off connection Fire service inlet Access to tank Overhead Tank capacity 	50,000 ltrs. NA NA Required 5,000 ltrs. Required	Provided NA NA Provided Provided Provided	MR NA NA MR MR MR
15	Exit Signage			
16.	Provision of Lifts			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of lift lobby Communication in lift Car Fireman's Grounding Switch Lift Signage 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
17.	Standby power supply	NA	NA	NA

18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

Fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety requirements as per D.O.E. Circular no. 262-362 dated 17.01.2005, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/School/WZ/2020/201 Dated 23.06.2020 is recommended.

Accordingly DFA is put up for approval please.

Q11H
 05/07/23
 Aman Kumar Lathar
 ADO (JWP)

Date: 5/7/2023

~~20/07/23~~

~~20/07/23~~

~~CP~~
 6/7/2023

~~Director~~
 14/07/23

Sir, A.O.V. is added in your signature P.

~~Director~~
 14/07/23

Q11H
 14/07/23
 Aman Kumar Lathar

m