



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001**

No.F.6/DFS/MS/Hospital/ SZ/2023/ 332

Dated: 11/07/2023

**FIRE SAFETY CERTIFICATE**

Certified that M/s Dr. Rajinder Prasad Eye Centre located at AIIMS Complex, Ansari Nagar, New Delhi-110029, comprised of Ground plus Seven Upper Floors, owned / occupied by **All India Institute of Medical Sciences** was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/Hospital/2020/SZ/55 dated 21/01/2020. The premises was re-inspected by the officer concerned of this department on 26/06/2023 in the presence of Mr. Naresh Kumar Yadav (ASO) and found that the said building have deemed complied with the fire prevention and Fire Safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy "**Institutional**" Building (Group-C) with effect from 11/07/2023 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 11/07/2023 at New Delhi by.

  
(ATUL GARG)  
DIRECTOR

Delhi Fire Service  
o/c

Copy to :-

1. Mr. Naresh Kumar Yadav (Asstt. Security Officer), All India Institute of Medical Sciences, Ansari Nagar, New Delhi-110029.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The Basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [WWW.dfs.Delhigovt.nic.in](http://WWW.dfs.Delhigovt.nic.in)



# INSPECTION REPORT

1. Name & address of the building: M/s Dr. Rajinder Prasad Eye Centre, AIIMS : Complex, Ansari Nagar, New Delhi-110029.
2. Type of Occupancy : Institutional Building "Group-C" (Hospital)
3. Building Comprised of : OPD= G+1 & Ward Block= Ground +7 Upper Floors.
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/Hospital/2020/SZ/55 dated 21/01/2020
6. Fire Safety directives Letter No.: F6/MS/FAC/DDA/85-344 dated 20/08/1985
7. Date of inspection : 26/06/2023
8. Name of the Inspecting Officer : Santosh Kumar AD.O.(SJ)
9. Name and designation of Officer from the building side : Mr. Naresh Kumar Yadav (ASO)
10. Year of Construction : 1978-79
11. Applicant's letter received through email ID- dated 07/05/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	9 mtr	MR
	• Gate width	NA	NA	NA
	• Width of internal road	6m	6m on two sides	MR(Old Case)
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	OPD Blk=1 No Ward Blk=4 Nos	OPD Blk=1 No Ward Blk=4 Nos	MR (Old Case)
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	OPD Blk=1.5m Ward Blk=1.2m, 1.2m, 1.28m & 1.5m	OPD Blk=1.5m Ward Blk=1.2m, 1.2m, 1.28m & 1.5m	MR (Old Case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	One Provided	MR
	e. Width Of Corridor	NA	2 mtr	NA
	f. Door Size	1 m	1m & 1.25m	MR
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	72 Nos	90 Nos	MR
	• Types	ABC/CO <sub>2</sub> & WCO <sub>2</sub>	ABC, CO <sub>2</sub> WCO <sub>2</sub>	MR
	• ISI marking	ISI	Provided	MR

6.	First - Aid Hose Reels			
	• Total numbers on each floor	OPD Blk=1 No Ward Blk=4Nos	OPD Blk=1 No Ward Blk=4Nos	MR
	• Length of hose reel hose	30 mtr	30m	MR
	• Nozzle diameter	5 mm	5 mm	MR
7.	Automatic fire detection and alarming system			
	• Type of detector	Heat & Smoke	Provided	MR
	• Location of Main Panel	Ground Floor	Provided	MR
	• Location of Repeater Panel	NA	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	All Areas	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	OPD Blk=1 No Ward Blk=4 Nos	OPD Blk=1 No Ward Blk=4 Nos	MR
	• Hose Box	OPD Blk=1 No Ward Blk=4 Nos	OPD Blk=1 No Ward Blk=4 Nos	MR
12.	Yard Hydrants			
	• Total number of hydrants	NA	02 Nos	NA
	• Hose Box	NA	02 Nos	NA
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	2850 LPM	2850 LPM	MR
	• Head of main pump	70 m	70 m	MR
	• Number of main pumps	One	Two	MR
	• Jockey pump out put	300 LPM	300 LPM	MR
	• Jockey pump head	70 m	70 m(each)	MR
	• Standby Pump out put	2850 LPM	2850 LPM	MR
	• Standby Pump Head	70m	70m	MR
	• Auto Staring/Manual stopping	Required	Provided	MR
	• Pump House Access	Required	Provided	MR
	• Terrace level			
	• Discharge of pump	NA	NA	NA
	• Head of the pump	NA	NA	NA
	• Power supply	NA	NA	NA
	• Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	2,00,000 ltr	3,50,000 ltr	MR
	• Draw of connection	Required	Provided	MR
	• Fire service inlet	Required	Provided	MR
	• Access to tank	Required	Provided	MR
	• Overhead Tank capacity	30,000 ltr	30,000 ltr	MR




N-16

15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any:	LT, HT & Transformers provided with Co2 flooding		MR

The fire protection systems provided in the building/premises were checked, test at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/Hospital/2020/SZ/55 dated 21/01/2020 renewal under rule 37 of the Delhi Fire Service rules 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

  
 Signature of the Inspecting Officer  
 Name : Santosh Kumar  
 Designation : A.D.O.

Do/ (Signature)  
 MUSE  
 5/7/23  
 CPO  
 6/7/2023  
 Director  
 4/7/23

A.D.O.