

No. F6/DFS/MS/Ind./WZ/2023/ 337

Dated:- 14/07/2023

**FIRE SAFETY CERTIFICATE**

Certified that the M/s. **Relaxo Footwears Limited**, Located at **F-7, Udyog Nagar, Rohtak Road, New Delhi-110041**, comprised of Basement + Ground + Mezzanine floor + 1<sup>st</sup> floor only was issued Fire Safety Certificate by this department vide letter No. **F6/DFS/MS/88/BP/854** dated **20.06.1988**. The said premises was re inspected by the officer concerned of this department on **06.07.2023** in the presence of Sh. Sudhir (Deputy Manager, HR) and found that the premises have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the building/premises is fit for occupancy class "Industrial" Group G with effect from 14/07/2023 for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, printed below.

Issued on 14/07/2023 at New Delhi by.

(Aul Garg)  
Director

**Copy to: -**

1. Sh. Manoj Kumar Goel, M/s. Relaxo Footwears Limited, F-7, Udyog Nagar, Rohtak Road, New Delhi-110041.

**Following Fire Safety Directive must be adhered to :-**

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional if fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupation, electric installation etc. may be got verified from the concerned authorities. In case of deviation the NOC be treated as Null & Void.
5. The Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction / unauthorized use of land if any.
6. All comments / directions of licensing Department shall always be permitted and followed.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
8. The owner / occupier shall apply for renewal of this Fire Safety Certificate to the Director in 'Form J' (sub Rule (1) of Rule 37) along with copy of the certificate, six months prior to its expiry.
9. The Basement shall be used as per BBL.

**INSPECTION REPORT**

1. Name & address of the building : **M/s. Relaxo Footwears Limited Located at F-7, Udyog Nagar, Rohtak Road, New Delhi- 41**
2. Type of Occupancy : **Industrial, Group-G**
3. Type of Case : **Renewal (B + G + Mezz. floor + 1<sup>st</sup> floor)**
4. Details of previous NOC : **F6/DFS/MS/88/BP/854 dated 20.06.1988**
5. Fire Safety directives Letter No. : **F6/DFS/MS/84/374 dated 03.05.1984**
6. Date of inspection : **06.07.2023**
7. Name of the Inspecting Officer : **Aman Kumar Lathar, ADO (JWP)**
8. Name and designation of Officer from the building side : **Sh. Yogesh (Electrical Engineer) & Sandeep Arora (GM- HR)**
9. Year of Construction : **1984**
10. Applicant's letter no. : **email dated 17.03.2023**

S No	Minimum standards on fire prevention and fire safety U/R 33	As per guideline dated 03.05.1984/ as per previous FSC dated 20.06.1988	Provided at site	Remarks MR/NMR
1.	<b>Access of building</b>			
	• Road width	09 m	Provided	MR
	• Gate width	As per guideline not mentioned	Provided	MR
	• Width of internal road	NA	NA	NA
2.	<b>Number, width, Type &amp; Arrangements of exits</b>			
	a. Number of staircases			
	• Upper floors	As per guideline not mentioned	02	MR
	• Basement	As per guideline not mentioned	03	MR
	b. Width of staircases			
	• Upper floors	As per guideline not mentioned	1.5 m x 1 & 1.20 m x 1	MR being old case
	• Basements	As per guideline not mentioned	1.5 m x 1, 1.20 m x 1 & 1.10 m x 1	MR being old case
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01	02	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	Required	Provided	MR
3.	<b>Compartmentation</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	<b>Smoke managements System</b>			
	• Basements	Required	Provided (Exhaust Fan)	MR
	• Upper floors	Required	Openable Window	MR
5.	<b>Fire Extinguishers</b>			
	• Total numbers	15 nos.	Provided	MR
	• Types	ABC, foam & CO <sub>2</sub>	Provided	MR
	• IS marking	ISI marked	Provided	MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor	02	Provided	MR
	• Length of hose reel hose	30 m	Provided	MR
	• Nozzle diameter	05 mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	As per guideline not mentioned	Smoke/Heat	MR
	• Location of Main Panel	As per guideline not mentioned	Provided at GF	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	NA	Provided	NA
	• Number of hydrants per floor	NA	Provided	NA
	• Hose Box	NA	Provided	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements:			
	• Ground Level	NA	NA	NA
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	As per guideline not mentioned	450 lpm	MR
	➤ Head of the pump	NA	40 m	MR
	➤ Power supply	NA	Provided	MR
	➤ Auto starting of pump	NA	Provided	MR
14.	Captive water Storage for firefighting:			
	• Underground tank capacity	50,000 ltrs.	Provided	MR
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	As per guideline not mentioned	5000 ltrs.	MR
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA

19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building were checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety requirements under the rules, renewal of Fire Safety Certificate issued vide letter no. F6/DFS/MS/88/BP/854 dated 20.06.1988 is recommended under rule 37 of the Delhi Fire Service Rule, 2010 under DFS Act 2007.

Accordingly DFA is put up for approval please.

*Q111th*  
11/07/23  
Aman Kumar Lathar  
ADO (JWP)

*20 (w)*

*dp*  
11/07/2023

DCO (MKE)  
M.K. CHATTOPADHYAY

7.....  
7/2023

*CFO*

*11/07/2023*  
12/7/2023

*Director*  
*M*  
12/07/23

*Amu/BWP*

*Su*

*F.T. letter is put-up for your signature to.*

*Director*  
*M*  
14/07/23

*Q111th*  
14/07/23  
ADO (JWP)

*mu*