

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/EH/NDZ/2023/ 328

Dated 07.07.2023

FIRE SAFETY CERTIFICATE

Certified that the **Connaught Plaza Restaurants Private Limited**, located at Ground floor ECE House 28, K.G. Marg, New Delhi in a building comprises of Ground + 01 upper floor, restaurant at ground floor only, was inspected by officers concerned of this department on 30/06/2023 in the presence of **Mr. Dheeraj** and found that the said premises has complied with the fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Assembly Building (Group D) for Restaurant at ground floor only** and valid up to **31.03.2026** from the date of issue in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued. 07.07.2023 at New Delhi by.


(Atul Garg)
DIRECTOR
Delhi Fire Service


Copy to:-

1. The Chief Architect, NDMC, Plakika Kendra, New Delhi.
2. The Addl. Commissioner of Police (Lic.), Licensing Unit, Defense Colony Police Station, New Delhi ID no. 2023062311438, 2023062011212 dated 23/06/2023.
3. The Manager, **Connaught Plaza Restaurants Private Limited** located at Ground floor ECE House 28, K.G. Marg, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. **This FSC is valid only for restaurant at ground floor.**
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained firefighting staff should be available round the clock.
5. Any deviation w.r.t. construction, use of occupancy, height of building, electric installation, set back area etc. shall be checked & verified by the concerned authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
10. Any flammable material for interior decoration shall strictly be prohibited.

INSPECTION REPORT

1. Name & address of the building: Connaught Plaza Restaurants Private Limited
located at Ground floor, ECE House 28, K.G.
Marg, New Delhi. (Gr. + 01 upper floors)
2. Type of occupancy:- Assembly Building Group-D
, Restaurant at Gr. Floor only.
3. Type of case:- : New ✓
4. Details of previous FSC:- N/A
5. Fire safety directives No.- N/A
6. Date of inspection:- 30/06/23
7. Name of the inspecting officer:- Sh. Rajinder Atwal (DO/CD) &
Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer
from the building side:- Mr. Dheeraj
9. Year of construction:- Old Heritage Bldg.
10. Applicant's letter No:- ID no. 2023062311438, 2023062011212 dated
23/06/2023.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr	Provided ✓	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	2x 1.5 mtr.	2x1.50 mtr. ✓	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 ACPH	Exhaust fan	MR
5.	Fire Extinguishers			
	1) Total numbers	04 Nos.	04 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR


6.	First-Aid Hose Reel			
	1) Total number	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	Provided	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	Provided	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants	01	01	MR
	3) Hose box	01	01	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	30 mtr.	30 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A

	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	20,000 ltr.	40,000 ltr. /	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	Required	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: ABC & Co2			MR

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.


Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules, if agreed, we may issue Fire Safety Certificate (FSC) to said restaurant. Accordingly, DFA is prepared and put up for kind perusal and sig. please.

Signature of the Inspecting Officer


 3/7/23

Name :- Sh. Rajinder Atwal
Designation :- DO/CD

Signature of the Inspecting Officer


 3/7/23


Name :- Ravinder Singh
Designation :- ADO (CC)

 3/7/23

C.F.O.

 3/7/23

 3/7/23

 3/7/23

Am/4