



C-46

75
Azadi Ka
Amrit Mahotsav

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001**

No. F.6/DFS/MS/Banquet/2023/NDZ/29

Dated: 14/7/2023

FIRE SAFETY CERTIFICATE

Certified that the Gurmeet's Banquet Hall running at First floor of the building comprised of basements, ground plus three upper floors located at First floor, SF-1,5,6,7,8,9 &10, Aditya Mega Mall, CBD Shahdara, Delhi-110032, owned/occupied by Golden Rose Decore And Events Pvt. Ltd. was issued FSC vide letter No. F.6/DFS/MS/Banquet/2019/1045 dated 17/05/2019. The premises was re-inspected by the officer concerned of this department on dated 24/06/2023 in the presence of Mr. Kulwinder (Manager) and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with rule 33 of Delhi Fire Service Rules, 2010 and that the building/premises is fit for occupancy Group 'D' "Assembly" with effect from 14/7/2023 is valid up to 31/03/2026 in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 & also conditions printed below.

Issued on 14/7/2023 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

To,

1. The Manager
SF-1,5,6,7,8,9 &10, Aditya Mega Mall, CBD Shahdara, Delhi-110032
2. The Joint Commissioner of Police (Lic.),
1st Floor Police Station, Defense Colony, New Delhi
MHA ID No. 2023061310813

Conditions for the validity of Fire Safety Certificate

1. FSC is valid only for Banquet Hall.
2. All the means of escape shall be kept free of all type of obstruction all the time.
3. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
4. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
5. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
6. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction /unauthorized use of land if any.
7. The owner / occupier shall apply for renewal of this Fire Safety Certificate of the Director in Form 'J' [sub rule (1) of rule (37)] along with a copy of this Certificate, Six Months prior to its expiry.
8. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

N/23

1. Name & address of the building : Gurmeet's Banquet hall (A Unit of Golden Rose Decore and Events (P) Ltd.) at Adity Mega Mall First Floor SF-1,5,6,7,8,9 &10 CBD Ground Shahdara, Delhi110032
2. Building is comprised of : Banquet is running of first floor of the building which is comprised of Basement, ground plus three upper floors
3. Type of Occupancy : Assembly (Banquet Hall)
4. Type of Case : Renewal
5. Details of Previous NOC letter : F.6/DFS/MS/Banquet/2019/1045 dated 17/05/2019
6. Fire Safety direction letter No : NBC Part-IV
7. Date of Inspection : 24/06/2023
8. Name of the Inspecting officers : ADO (Shd.), Deepak Kumar
9. Name and designation of Officer from the building side : Mr. Kulwinder (Manager)
10. Year of Construction : 2007
11. Applicant's letter No : 2023061310813, Dated- 19/06/2023

Sr. No.	Minimum Standards on Fire Prevention and Fire Safety U/R33	NBC Part-IV Requirement	Provided at Site	Remarks MR/NMR
01	Access to Building.			
	• Road width	06 mtr.	20 mtr.	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
02	Number, Width, Type and Arrangement of Exits.			
	a. Number of Staircases			
	• Upper Floor	02 nos.	02 nos.	MR
	• Basement	02 nos.	02 nos.	MR
	B. Width of Staircases			
	• Upper Floor	1.50 mtr.	1.50 mtr. each	MR
	• Basement	N/A	N/A	N/A
	c. Protection of exits			
	• Fire check door	N/A	N/A	N/A
	• Pressurization	N/A	N/A	N/A
	d. No. of continuous staircases to terrace	02 nos	02 nos	MR
	e. Width of Corridor	N/A	N/A	N/A
	f. Door Size	02 mtr.	02 mtr & 2.9 mtr	MR
	g. No. of doors	02 mtr.	02 mtr.	MR
03	Compartmentation.			
	• Fire check door	N/A	N/A	N/A
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire rating of shaft door	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire Dampers	N/A	N/A	N/A
04	Smoke Management System.			
	• Basement	Required	Ventilated	MR
	• Upper floor	Required	Ventilated	MR
05.	Fire Extinguishers.			
	• Total numbers	04 nos.	06 nos.	MR
	• types	ABC /CO ₂	ABC /CO ₂	MR
	• IS marking	ISI marked	ISI marked	MR

06	First-Aid-Hose Reels.			
	Total numbers on each floor • Length of hose reel hose • Nozzle diameter	01 No.	01 No.	MR (Dedicated)
		30 mtr.	30 mtr.	MR (Dedicated)
		05 mm	05 mm	MR (Dedicated)
07	Automatic Fire Detection and Alarming System.			
	• Type of detectors • Location of main panel • Location of repeater panel • Alternate source of power • Hooter's location	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
08	MOEFA	Required	Provided	MR
09	Public Address System.	N/A	N/A	N/A
10	Automatic Sprinkler System.			
	• Basement	N/A	N/A	N/A
	• upper floor	N/A	Provided	MR
	• sprinkler above false ceiling	N/A	N/A	N/A
11	Internal Hydrants			
	• size of riser/down-comer	100 mm	100 mm	MR (Dedicated)
	• Number of hydrants per floor	01 No.	01 No.	MR (Dedicated)
	• Hose Box	01 No.	01 No.	MR (Dedicated)
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	N/A
	• Hose Box	N/A	N/A	N/A
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	N/A	N/A	N/A
	➤ Head of Main Pump	N/A	N/A	N/A
	➤ Number of main pumps	N/A	N/A	N/A
	➤ Jockey pump out put	N/A	N/A	N/A
	➤ Jockey pump head	N/A	N/A	N/A
	➤ Standby pump out put	N/A	N/A	N/A
	➤ Standby pump Head	N/A	N/A	N/A
	➤ Auto Starting /Manual stopping	N/A	N/A	N/A
	➤ Pump House Access	N/A	N/A	N/A
	• Terrace Level			
	➤ Discharge of pump	900 Lpm.	900 Lpm.	MR (Dedicated)
	➤ Head of the Pump	40 M	40 M	MR (Dedicated)
	➤ Power supply	Required	Provided	MR (Dedicated)
	➤ Auto Starting of pump	Required	Provided	MR (Dedicated)
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity			
	➤ Draw-off connection	N/A	N/A	N/A
	➤ Fire service inlet	N/A	N/A	N/A
	➤ Access to tank	N/A	N/A	N/A
	• Overhead Tank capacity	15,000 Ltr.	15,000 Ltr	MR (Dedicated)
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication in lift car	N/A	N/A	N/A
	• Firemen's grounding switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A

N/23

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector system panel	N/A	N/A	N/A
	• Flow switch panel	N/A	N/A	N/A
	• PA system panel	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/checked and found functional at the time of inspection.

Keeping in view the deemed compliance of the minimum standards on fire prevention and fire safety measures as required under the rules the FSC issued vide letter no. F.6/DFS/MS/Banquet/2019/1045 dated 17/05/2019 renewal under rule 35 of the Delhi Fire Service Rule, 2010 is recommended.

Banquet Hall has installed dedicated fire system, if you agree may considered for Fire Safety Certificate.

Deepak
03/07/2023.

Signature of the Inspecting Officer
Name - Deepak Kumar
Designation - ADO (Shd.)

Received on 11/07/2023

~~DO (ED)~~ where is previous paper?

~~ADO/ Shd.~~

ADP
11/07/2023

Size, Previous paper attached.

~~DO (ED)~~, *ADP*
12/07/2023

Deepak
12/07/2023.

~~by C.F.O. (NSZ)~~

ADP
12/07/2023

C.F.O. *ADP*
13/07/2023

Director *ADP*
17/07/2023

ADP
14/07/2023 P.T.O.