



7. C. 25
Azadi Ka
Amrit Mahotsav

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/School/2023/SZ/ 481

Dated: 14 /07 /2023

FIRE SAFETY CERTIFICATE

Certified that the Navyug Sr. Sec. School, Laxmi Bai Nagar, New Delhi, comprised of Ground & One Upper Floors (Three blocks all are interconnected) FSC was issued by this department vide letter No. F.6/DFS/MS/School/2020/SZ/179 dated 11/05/2020. The said premises was re-inspected by the officer concerned of this department on 22.06.2023 in the presence of Sh. Mahinder Singh Shokeen (Fire Officer, NDMC) and found that school building have deemed complied with the fire prevention and fire safety requirement in accordance with Directorate of Education circular no.262 to 362 dated 17/05/2005 issues by Govt. of NCT of Delhi and that the school building is fit for occupancy class " Education Building" Group-B, as above with effect from 14/07/2023 for a period of three years in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 14/07 /2023 at New Delhi by


(ATUL GARG)
DIRECTOR
Delhi Fire Service
o/c

Copy to: -

1. The Principal, Navyug Sr. Sec., Laxmi Bai Nagar, New Delhi.
2. The Director of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape / entry / exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided there in shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of fire fighting system.
5. This Fire Safety Certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3. of UBBL-2016), if any.
6. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.Delhigovt.nic.in.

INSPECTION REPORT

1.	Name & address of the building	Navyug Sr. Sec. School, Laxmi Bai Nagar, New Delhi.		
2.	Type of Occupancy	Educational, Group-B(School)		
3.	Building Comprised of	Ground Plus One Upper Floor (Three blocks all are interconnected)		
4.	Type of Case	Renewal		
5.	Details of previous NOC	F.6/DFS/MS/School/2020/SZ/179 dated 11/05/2020		
6.	Fire Safety directives Letter No	DOE Circular 262 to 362 Dated 17/01/2005		
7.	Date of Inspection	22/06/2023		
8.	Name of the Inspecting Officer	Santosh Kumar, ADO (SJ)		
9.	Name and Designation of Officer from the building side	Sh. Mahinder Singh Shokeen (Fire Officer, NDMC)		
10.	Year of Construction	1982		
11.	Applicant's letter No.	Email dated 08/06/2023		
S. No	Minimum standards on fire prevention and fire safety U/R 33	As Per Old NOC	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	Accessible	9m	MR
	• Gate width	NA	4.30m	NA
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	05 Nos	05 Nos	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.50 m / 0.75m	1.22m, 1.23m, 1.25m, 1.45m, & 1.5m ✓	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	01 Nos	02 Nos	MR
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 ACPH NA	NA	NA
	• Upper floors	12 ACPH	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	12 Nos	12 Nos	MR
	• Types	ABC / CO ₂	ABC WaterCO ₂	MR
	• ISI marking	ISI Marked	Provided	MR
6.	First - Aid Hose Reels			
	• Total numbers on each floor	04 Nos	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	6.5m	Provided	MR

7.	Automatic fire detection and alarming system			
	• Type of detector	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location			
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	Provided	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access			
	• Terrace level			
	➤ Discharge of pump	220 LPM	450 LPM	MR
	➤ Head of the pump	40 m	40 m	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	2,500 liter	3,000 liter	MR
	• Overhead Tank capacity			
15.	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch			
	➤ Lift Signage			


N-15

17.	Standby power supply	NA	NA	NA
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;			NA

The fire protection systems provided in the building were tested, checked at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F.6/DFS/MS/School/2020/SZ/179 dated 11/05/2020, renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.


 Signature of the Inspecting Officer
 Name : Santosh Kumar
 Designation : ADO (SJ)

~~DO (SD)~~

Handwritten signature
10/7/23

Handwritten signature
11/7/2023

Handwritten signature
11/7/23

Sir, f.t letter is placed for your signature

Director: *Handwritten signature*
11/7/23

Handwritten signature
13.07.23