

C 24

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI - 110001**

No.F6/DFS/MS/School/NDZ/2023/490

Dated: 19.07.2023

**FIRE SAFETY CERTIFICATE**

Certified that the Atal Adarsh Vidyalaya located at Balmiki Basti, New Delhi at comprises of Ground + 02 Upper floor was earlier granted FSC by this department vide letter No. F6/DFS/MS/School/NDZ/2020/220 dated 15/07/2020. Now, the premises was re-inspected by the officer concerned of this department on 07-07-2023 in the presence of Sh. Mahender Shokeen, Fire Officer, NDMC and found that the said school building have complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 and that the premises is fit for occupancy of class Group B "Educational Building" Sub-Div. B-I with effect from ...19.07.2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 on the conditions printed below.

Issued on ....19.07.2023.... at New Delhi by.

  
(Atul Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. Director of Education, Govt. of NCT, Delhi.
2. The Principal, Atal Adarsh Vidyalaya, Balmiki Basti, New Delhi.
3. Sh. N.K. Gaur, Fire Officer, Fire Department, NDMC, Palika Kendra, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided there in shall be maintained in good working condition at all time. The owner / occupier shall submit a declaration every year in Form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
2. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration is prohibited.

N/14

### INSPECTION REPORT

1. Name & address of the building:- Atal Adarsh Vidyalaya at Balmiki Basti, New Delhi.
2. Type of occupancy:- Educational Building, Gr. + 2 Floor
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/School/NDZ/2020/220 dated 15/07/2020.
5. Fire safety directives No.- N/A
6. Date of inspection:- 07/07/23
7. Name of the inspecting officer:- Sh. Ravinder Singh (ADO/CC)
  
8. Name & designation of officer  
From the building side:- Sh. Mahendra Shokeen (Fire Officer)
9. Year of construction:- 1971-72
10. Applicant's letter No:- mail id no.<fo@ndmc.gov.in.> dated 08.06.2023.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Exiting fire safety certificate arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	06 mtr.	09 mtr. ✓	MR
	2) Gate width	4.5 mtr.	05 mtr. ✓	MR
	3) Width of internal road	NA	NA	NA
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	02	02	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase		✓	
	1. Upper floors	1.5 mtr.	1.50 & 1.60 mtr. & ramp	MR
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	01	01	MR
	E. Width of corridor	1.25 mtr.	2.0 mtr. ✓	MR
	F. Door size	1 mtr.	1 mtr	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	N/A	N/A	N/A
	2) Upper floors	12 ACPH	Natural	MR
5.	Fire Extinguishers			
	1) Total numbers	10 Nos.	10 Nos. ✓	MR
	2) Types	ABC & CO2	ABC, CO2	MR

	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	N/A	N/A	N/A
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100 mm	100 mm	MR
	2) Number of hydrants per floor	01	01	MR
	3) Hose box	01	01	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	220 LPM	220 LPM	MR
	e) Jockey pump head	30 mtr.	30 mtr.	MR
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	30 mtr.	30 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR

✓  
20/01


116

14.	<b>Captive Water Storage for Fire Fighting</b>			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	Required	Provided	MR
	d) Over head tank capacity	5,000 ltr. ✓	5,000 ltr. ✓	MR
15.	Exit Signage.	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	<b>Refuge Area</b>			
	Total area location	N/A	N/A	N/A
19.	<b>Fire Control Room</b>			
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any: ABC & CO <sub>2</sub>			MR


The fire protection system provided in the school building were tested, checked at random and found functional at the time of inspection.


In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/NDZ/2020/220 dated 15/07/2020, renewal under Rule 35 of the Delhi Fire Service rules 2010, Accordingly, DFA is put up for kind perusal and signature please.


Signature of the Inspecting Officer


  
 Name :- Ravinder Singh  
 Designation :- ADO (CC)


  
 12/7/23

  
 C.F/O

  
 12/07/23

  
 12/07/2023

  
 Dineday  
 ADO/CC

  
 13/07/23