

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE, NEW DELHI
No. F6/DFS/MS/SZ/2023/ 343 Dated: 20/07/2023

FIRE SAFETY CERTIFICATE

Certified that the Ayushman Hospital & Health Services, Located at Sector 10, Dwarka, New Delhi-110075 in a building comprised of two tier **Basement + Ground Floors + Seven upper floors** and service floor above third floor was issued FSC vide Letter No. F6/DFS/MS/Hospital/SZ/2020/259, dated- 16/07/2020. The premises was re inspected by the officers concerned of this department on 06/07/2023 in the presence of Dr. Raj Kumar (Director) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Institutional" Group C with effect from 20/07/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 20/07/2023 at New Delhi by.


(Atul Garg)
(Director)
Delhi Fire Service
13/07/23

Copy to: -

1. The Authorized Signatory, Ayushman Hospital & Health Services, Located at Sector 10, Dwarka, New Delhi-110075.
2. The Executive Engineer (Bldg) HQ-1, SDMC, 8th floor, E-1, Wing, Dr.SPM Civic, Minto Road, New Delhi-110002.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expired.

INSPECTION REPORT

1. Name & address of the building: Ayushman Hospital & Health Services,
Located at Sector 10, Dwarka, New Delhi-110075
2. Type of Occupancy. : Institutional (Hospital).
3. Type of Case : Renewal (02 tier basement, G+7UFs &
Service floors above 3rd floor)
4. Details of previous NOC : F6/DFS/MS/Hospital/SZ/2020/259 dated - 16/07/20
5. Fire Safety directives L. No. : F6/DFS/MS/BP/2020/Hospital/17, dated
20/01/2020.
6. Date of inspection : 06-07-2023
7. Name of the Inspecting Officer : DO/SW & ADO (DWK)
8. Name and designation of Officer :
from the building side : Dr. Raj Kumar (Director)
9. Year of Construction :2016-17
10. Applicant's letter No. : Form J dated 21-06--2023

S No	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	Provided	MR
	• Gate width	4.5 m	Provided	MR
	• Width of internal road	6m	Old case	MR(Being old case)
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases	02 Nos.	Provided	MR
	• Upper floors	02 Nos.+1 Ramp	Provided	MR
	• Basements			
	b. Width of staircases	2mtr each	Provided	MR
	• Upper floors	2 mtr & ramp	Provided	MR
	• Basements			
	c. Protection of exits	Required	Provided	MR
	• Fire check door	Required	Provided	MR
	• Pressurization	02 Nos.	Provided	MR
	d. No of continuous staircase to terrace	2.40mts	Provided	MR
	e. Width Of Corridor	2m, 1.5m & 1.25m	Provided	MR
	f. Door Size			
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	2 Hours rating	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	Required	Provided	MR

[Handwritten signature]

11/12

Smoke managements System				
<ul style="list-style-type: none">BasementsUpper floors	30a/c per hour	Provided	MR	
	12a/c per hour	Provided	MR	
Fire Extinguishers				
<ul style="list-style-type: none">Total numbersTypesIS marking	32 nos. ABC &CO2, ISI marked	Provided	MR	
		Provided	MR	
		Provided	MR	
First – Aid Hose Reels				
<ul style="list-style-type: none">Total numbers on each floorLength of hose reel hoseNozzle diameter	02 Nos.	Provided	MR	
	30 m	Provided	MR	
	5 mm	Provided	MR	
Automatic fire detection and alarming system				
<ul style="list-style-type: none">Type of detectorsLocation of Main PanelLocation of Repeater PanelAlternate source of powerHooters' Location	Smoke / Heat	Provided	MR	
	Basement 1	Provided	MR	
	Required	Provided	MR	
	Required	Provided	MR	
	Appropriate Places	Near Staircase	MR	
3. MOEFA	Required	Provided	MR	
9. Public Address System	Required	Provided	MR	
10. Automatic Sprinkler System				
<ul style="list-style-type: none">BasementsUpper FloorSprinkler above false ceiling	Required	Provided	MR	
	Required	Provided	MR	
	Required	Provided	MR	
11. Internal Hydrants:				
<ul style="list-style-type: none">Size of riser/down- comerNumber of hydrants per floorHose Box	150mm	Provided	MR	
	02 Nos.	Provided	MR	
	Required	Provided	MR	
12. Yard Hydrants				
<ul style="list-style-type: none">Total number of hydrantsHose Box	07 Nos.	Provided	MR	
	07 Nos.	Provided	MR	
13. Pumping Arrangements:				
<ul style="list-style-type: none">Ground LevelDischarge of main pump➤ Head of main pump➤ Number of main pumps➤ Jockey pump out put➤ Jockey pump head➤ Standby Pump out put➤ Standby Pump Head➤ Auto Staring/Manual stopping➤ Pump House AccessTerrace level➤ Discharge of pump➤ Head of the pump➤ Power supply➤ Auto starting of pump	2280lpm	Provided	MR	
	70 m	Provided	MR	
	2 Nos.	Provided	MR	
	180 lpm (2 Nos.)	Provided	MR	
	70 m	Provided	MR	
	2280lpm	Provided	MR	
	70 m	Provided	MR	
	Required	Provided	MR	
	Required	Provided	MR	
	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	
	NA	NA	NA	

Captive water Storage for fire fighting:				
14.	Under ground tank capacity	2,00,000 litre	Provided	MR
	➤ Draw off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Accessible	Provided	MR
	• Overhead Tank capacity	20,000 Litres	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	Required	Provided	MR
	➤ Pressurization of lift lobby	Required	Provided	MR
	➤ Communication in Lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	DG set 500KVA	MR
18.	Refuge Area			
	➤ Total area	Required	Provided as per sanctioned plan	MR
	➤ Location	Required	AT 6 TH Floor	MR
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 flooding system Provided in elect. Panel.	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the NOC issued vide letter no. F6/DFS/MS/Hospital/SZ/2020/59 dated- 16/07/2020 renewal under rule 35 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
Name Sh Ved Pal
Designation DO/SZ

Signature of the Inspecting Officer
Name Uday Vir Singh
Designation DO/SZ

CFO (SZ) 11/11/23
12/11/2023

Director 11/11/23

May 2023