

239

FORM 'H'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/School/2023/ 489

Dated: 19/07/2023

FIRE SAFETY CERTIFICATE

Certified that the Govt. Co- Ed. Senior Secondary School, Located at Sector -06, Site-1, Dwarka New Delhi - 110075, comprised of Ground + 03 Upper Floors namely old block was issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/2020/SZ/284, dated 14/08/2020. The premises was re inspected by the officer concerned of this department on 04/07/2023 in the presence of Mr. Pradosha Kumar Pradip (Principal) and found that premises have deemed complied with the fire prevention and fire safety requirements in accordance with DOE Circular 3298-3398 Dated 01/03/2011 issued by Directorate of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class B "Educational building" with effect from 19/07/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/07/2023 at New Delhi by.


(Anil Garg)
Director
Delhi Fire Service
D/c

Copy to:

1. The Principal, Govt. Co- Ed. Senior Secondary School, Sector -03, Site-I, Dwarka New Delhi - 110075.(School ID-1821206)
2. Directorate of Education Old Secretariat Delhi - 110054

Following fire safety directives must be adhered to:-

- 1 **One another block comprised of Ground floor only was also seen in the school/premises. That must not be used for school activities without getting FSC from Delhi Fire Service.**
- 2 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 3 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 4 The trained staff should be available round the clock.
- 5 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 6 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 7 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 8 Basement shall be used strictly as per building bye laws.
- 9 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Govt. Co- Ed. Senior Secondary School,
Located at Sector -06, Site-1, Dwarka New Delhi - 110075.
2. Type of Occupancy : Educational (Ground+ 3 Upper Floors Old Block)
3. Type of Case : Renewal
4. Details of previous NOC : F6/D/S/MS/School/2020/SZ/284, dated
14/08/2020
5. Fire Safety directives Letter No. : DOE 3298-3398 dated 01-03-2011
6. Date of inspection : 04/07/2023
7. Name of the Inspecting Officer : Udaivir singh ADO (DWK)
8. Name and designation of Officer
from the building side : Mr. Pradosha Kumar Pradip (Principal)
9. Year of Construction : Before 2010
10. Applicant's letter No. : DWK/S-6(I)/2023/361, dated 15/06/2022

Total Area = 20000 sqm.
Covered Area = 3490 sqm
Class rooms = 70
No. of students = 2586

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/16, N/17 & N/18	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06mtrs	Provided	MR
	• Gate width	4.5mtrs	provided	MR
	• Width of internal road	NA	NA	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	4 Nos.	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5m	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	2 Nos.	Provided	MR
	e. Width Of Corridor	1.5 m	Provided	MR
	f. Door Size	1 m	Provided	MR
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA

	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilation	MR
	Fire Extinguishers			
	• Total numbers	16 nos.	18 Nos.	MR
	• Types	ABC & CO ₂	Provided	MR
	• IS marking	ISI marked	Provided	MR
5.	First – Aid Hose Reels			
	• Total numbers on each floor	03 Nos.	5 Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location			
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants:			
	• Size of riser/down- comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements:			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Staring/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	450 lpm	Provided (2 Nos.)	MR
	➤ Head of the pump	40Mtr	Provided	MR
	➤ Power supply	Required	Provided	MR
	➤ Auto starting of pump	Required	Provided	MR

14	Captive water Storage for fire fighting:			
	• Underground tank capacity	NA	NA	NA
	➤ Draw off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000Ltrs	Provided	MR
15	Exit Signage	Required	Provided	MR
16	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire control room			
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any;	Required	ABC Fire Extinguisher provided near electric panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the ~~NO~~ issued vide letter No. F/6/D/S/MS/School/2020/SZ/284, dated 14/08/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Note:- One another block comprised of Ground floor only was also seen in the school/premises. That must not be used for school activities without getting 'A' FSC from Delhi Fire Service

Signature of the Inspecting Officer
Name Uday Var Singh
Designation DDO/PA/1

DDO/STW

6/2/23

CFO (S2)

'A' above is different from the proforma placed at C-35 ? or add in same by HOS.