

C 34

FORM 'II'
FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[Refer sub - rule (1) of rule 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/SZ/2023/486

Dated: 19/07/2023

FIRE SAFETY CERTIFICATE

Certified that the building of Pragati Public School Located at Sector – 13, Phase-II, Dwarka, New Delhi 110078 comprised of Ground + 03 Upper Floors was issued Fire Safety Certificate vide letter No. F6/DFS/MS/School/2020/SZ/214, dated 10/07/2020. The premises was re- inspected by the officer concerned of this department on 11/07/2023 in the presence of Sh. R.K Tandan (Admin) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service 2010, and that the premises is fit for occupancy class-B "Educational" with effect from 19/07/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.. 19/07/2023 at New Delhi by.


(Atul Singh)
Director
Delhi Fire Service.
19/07/23
9/c

Copy to:

1. The Principal Pragati Public School , Sector – 13, Phase-II, Dwarka, New Delhi 110078.
2. Directorate of Education Old Secretariat Delhi – 110054.

Following fire safety directives must be adhered to:-

- 1 All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
- 2 Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
- 3 The trained staff should be available round the clock.
- 4 Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
- 5 The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
- 6 The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.
- 7 Basement shall be used strictly as per building bye laws.
- 8 The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.

INSPECTION REPORT

1. Name & address of the building: Pargati Public School Located at Sector – 13, Phase-II, Dwarka, New Delhi 110078.
2. Type of Occupancy : Educational, Ground + 3 Upper Floor
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/School/2020/SZ/214, dated 10/07/2020
5. Fire Safety directives L. No. : F6/DFS/MS/BP/2015/School/264, dated 16//10/2015
6. Date of inspection : 11/07/2023
7. Name of the Inspecting Officer : Udai vir Singh ADO (DWK)
8. Name and designation of Officer
from the building side : Sh. R.K Tandan (Admin)
9. Year of Construction : 2006 & 2016
10. Applicant's letter No. : PPS/2023-24/1042, dated 30/06/2023

Total Area = 3.953 Acre
Covered Area = 8389 sqm
Class rooms = 60
No. of students = 2158

S No	Minimum standards on fire prevention and fire safety U/R 33	As per N/13, N/14 & N/15	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	06 mtr	Provided	MR
	• Gate width	4.5 mtr	Provided	MR
	• Width of internal road	NA	06 M	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	03 Nos.+ 1 Ramp	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 mtr	Provided	MR(being old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	Provided (One)	MR
	e. Width Of Corridor	1.5 mtr	Provided	MR
	f. Door Size	1 mtr	Old case	MR(Being old case)
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c charge	Natural ventilation	MR

to h

5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers Types IS marking 	<ul style="list-style-type: none"> 6 nos. each floor ABC & CO₂ ISI marked 	<ul style="list-style-type: none"> Provided 35 nos ABC & CO₂ Provided 	<ul style="list-style-type: none"> MR MR MR
6.	First - Aid Hose Reels			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	<ul style="list-style-type: none"> 03 Nos. 30 m 5mm 	<ul style="list-style-type: none"> Provided Provided Provided 	<ul style="list-style-type: none"> MR MR MR
7.	Automatic fire detection and alarming system			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA 	<ul style="list-style-type: none"> NA NA NA NA NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basements Upper Floor Sprinkler above false ceiling 	<ul style="list-style-type: none"> NA NA NA 	<ul style="list-style-type: none"> NA NA NA 	<ul style="list-style-type: none"> NA NA NA
11.	Internal Hydrants:			
	<ul style="list-style-type: none"> Size of riser/down- comer Number of hydrants per floor Hose Box 	<ul style="list-style-type: none"> NA NA NA 	<ul style="list-style-type: none"> NA NA NA 	<ul style="list-style-type: none"> NA NA NA
12.	Yard Hydrants			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA 	<ul style="list-style-type: none"> NA NA
13.	Pumping Arrangements:			
	<ul style="list-style-type: none"> Ground Level Discharge of main pump Head of main pump Number of main pumps Jockey pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Staring/Manual stopping Pump House Access Terrace level Discharge of pump Head of the pump Power supply Auto starting of pump 	<ul style="list-style-type: none"> NA NA NA NA NA NA NA NA NA NA 450 lpm 35 Mtr Required Required 	<ul style="list-style-type: none"> NA NA NA NA NA NA NA NA NA NA Provided Provided DG Set Provided 	<ul style="list-style-type: none"> NA NA NA NA NA NA NA NA NA NA MR MR MR MR

14.	Captive water Storage for fire fighting:		
	• Under ground tank capacity	NA	NA
	➤ Draw off connection	NA	NA
	➤ Fire service inlet	NA	NA
	➤ Access to tank	NA	NA
	• Overhead Tank capacity	10,000Ltr	10,000Ltr
15	Exit Signage	Required	MR
16.	Provision of Lifts	Provided	MR
	➤ Pressurization of Lift Shaft	NA	NA
	➤ Pressurization of lift lobby	NA	NA
	➤ Communication in lift Car	NA	NA
	➤ Fireman's Grounding Switch	NA	NA
	➤ Lift Signage	NA	NA
17.	Standby power supply	Required	MR
18.	Refuge Area	DG Set	MR
	➤ Total area	NA	NA
	➤ Location	NA	NA
19.	Fire control room		
	➤ Detector system panel	NA	NA
	➤ Flow Switch Panel	NA	NA
	➤ PA System Panel	NA	NA
	➤ Battery backup	NA	NA
	➤ Building Floor Plans	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	MR
		ABC fire extinguisher provided near electric panel	

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No. F6/DFS/MS/School/2020/SZ/214, dated 10/07/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

Signature of the Inspecting Officer
 Name Uday Vir Singh
 Designation ASO/DMK

ASO/SW
 12/7/23
 CFO (S2)

13/7/2023
 Director
11/10/22

ASO/DMK