

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No.F6/DFS/MS/SZ/2023/339

Dated: 19/07/2023

**FIRE SAFETY CERTIFICATE FOR PART-2**

Certified that the M/s Ware house Block 2 Located at Khata No. 23/6/1/15/2,16/2,25 Min34,24/11,20,21,57/1, ETC Village Bijwasan Delhi, comprised of Ground + One Upper Floors owned/ occupied by Mrs. Shanti Devi, Mr. Ramesh Chand, Mr. Devender Singh, Mr. Surender Singh & Mr. Ghanshyam have complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and verified by the team of officers concerned of this department on 13/07/2023 in the presence of Sh. Ramesh Chand Rana (Owner) and found that the said premises is fit for occupancy class "Storage" Group H with effect from 19/07/23 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/07/23..... at New Delhi by.

  
(Atul Garg)  
Director  
Delhi Fire Service

Copy to:

1. The Executive Engineer (Bldg), 9<sup>th</sup> Floor, Civic Centre, New Delhi-110002
2. The Authorized Signatory, M/s Ware house Block -2, Located at Khata no 23/6/1/15/2,16/2,25 Min34,24/11,20,21,57/1, ETC Village Bijwasan Delhi

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

419

321

**INSPECTION REPORT**

1. Name & address of the building: M/s Ware house Block No. 2 Located at Khata no 23/6/11,15/2,16/2,25 Min34,24/11,20,21,57/1, ETC Village Bijwasan, New Delhi.
2. Type of Occupancy : Building Group H (Storage Building)
3. Type of Case :New (Ground +1 Upper Floor)
4. Details of previous NOC : Nil
5. Fire Safety directives Letter No. : F 6/DFS/MS/BP/2022/432 Dated-14/10/2022
6. Date of inspection : 13/07/2023
7. Name of the Inspecting Officer : DO/SW & ADO/ DWK
8. Name and designation of Officer  
from the building side : Sh. Ramesh Chand Rana, Owner
9. Year of Construction : 2023
10. Applicant's letter No. : Online ID No. 10116339, dated-11/07/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirements s per Directive issued	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 m	Provided	MR
	• Gate width	06 m	06 m	MR
	• Width of internal road	NA	6m Provided	NA
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	14 nos.	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.5 mtr	Provided	MR
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	NA	NA	NA
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	1.5mr	Provided	MR

3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers			
4.	Smoke managements System			
	• Basements	NA	NA	NA
	• Upper floors	Required	Provided	MR
5.	Fire Extinguishers			
	• Total numbers	60 Nos.	Provided	MR
	• Types	ABC& CO2	ABC, CO2 , DCP & WCO2	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	37 nos	Provided	MR
		30 m	Provided	MR
	• Length of hose reel hose	5 mm	Provided	MR
	• Nozzle diameter			
7.	Automatic fire detection and alarming system			
	• Type of detectors	Heat & Smoke	Provided	MR
	• Location of Main Panel	Ground floor	Ground floor	MR
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Appropriate place	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	37no's each floor	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	10 Nos.	Provided	MR
	• Hose Box	Required	Provided	MR

2/4/11

13.	<b>Pumping Arrangements:</b>			
	<ul style="list-style-type: none"> <li>• Ground Level</li> <li>• Discharge of main pump</li> <li>➤ Head of main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Staring/Manual stopping</li> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power supply</li> <li>➤ Auto starting of pump</li> </ul>	2280 lpm	7570 lpm	MR
		70 m	100 m	MR
		2 Nos.	Provided	MR
		180 lpm	2X300 lpm	MR
		70 m	100 m	MR
		1X2280 lpm	7570 lpm & 2280 lpm	MR
		70 m	100 m each	MR
		Required	Provided	MR
		Required	Provided	MR
		450 lpm	Provided	MR
		40 m	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
14.	<b>Captive water Storage for fire fighting:</b>			
	<ul style="list-style-type: none"> <li>• Under ground tank capacity</li> <li>➤ Draw off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	75000 ltr	700000 ltr Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		Required	Provided	MR
		10000ltr	Provided	MR
15	Exit Signage	Required	Provided	MR
16.	<b>Provision of Lifts</b>			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	NA	NA	NA
	➤ Fireman's Grounding Switch	NA	NA	NA
	➤ Lift Signage	NA	NA	NA
17.	Standby power supply	Required	D.G Set	MR
18	<b>Refuge Area</b>			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	<b>Fire control room</b>			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	Required	Provided	MR
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA