

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI – 110001**

No. F.6/DFS/MS/EH/2023/SZ/ 234

Dated: ...19.../07/2023

FIRE SAFETY CERTIFICATE

Certified that the Eating House in the Name & Style of M/s Malamen located at Ground Floor, Plot No 101, Old Ishwar Nagar, Mathura Road, New Delhi 110025 comprised of 02 Basement, Ground plus Eight upper floors on owned/ occupied by A Unit of Exotic Pride India Pvt Ltd have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and verified by the officer concerned of this department on 07/07/2023 in the presence of Mr. Rajeev Ranjan and found that the said building / premises is fit for occupancy class "Assembly Building" (Ground floor only) and validity upto 31/03/2026 in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on : 19/07/2023 at New Delhi by

(ATUL GARG)
DIRECTOR

DELHI FIRE SERVICE

Copy to: -

1. The Joint C.P. (Licensing), First Floor, Police Station Defence Colony, New Delhi-110049
2. The Dy. Health Officer, South MCD, Public Health Department, Central Zone, Lajpat Nagar, New Delhi-110024 (Ref. MHA Portal ID 2023061610994 Dated 01/07/2023)

Conditions for the validity of Fire Safety Certificate: -

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangement provided therein shall be maintained in good working condition at all time as seen during inspection. Any loss of life property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The basement shall be used strictly in accordance with BBL.
4. All the staff members must know the correct method of operation of fire fighting system.
5. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six months prior to its expiry."

n/1

INSPECTION REPORT				
1	Name & Address of the Building	M/s Malamen (A Unit of Exotic Pride India Pvt Ltd) located at Plot No 101, Old Ishwar Nagar, Mathura Road, New Delhi 110025		
2	Type of Occupancy	Assembly occupancy		
3	Building Comprised of	02 Basement, Ground + Eight Upper Floors (restaurant at Ground floor only) ✓		
4	Type of Case	New Case		
5	Details of Previous NOC	Nil		
6	Fire Safety Directives Letter No	F6/DFS/MS/Business/2021/SZ/582 dated 24/11/2021 building NOC		
7	Date of Inspection	07/07/2023		
8	Name of the Inspecting Officers	DO (South) & ADO (BCP)		
9	Name & Designation of Officers from the building side	Mr. Rajeev Ranjan		
10	Year of construction	2017		
11	Applicant letter No.	MHA Portal ID 2023061610994 Dated 01/07/2023		
S. No	Minimum standards on Fire Prevention and Fire Safety U/R 33	UBBL-2016 requirement	Provided at Site	Remarks MR/NMR
1	Access to Building.			
	• Road width	06 mtr	Main Road	MR
	• Gate width	N/A	N/A	N/A
	• Width of internal road	N/A	N/A	N/A
2	Number, width, type & arrangement of exits			
	a. Number of Staircase	Restaurant at GF only		
	1. Upper floors	N/A	N/A	N/A
	2. Basement floor	N/A	N/A	N/A
	b. Width of Staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basement floor	N/A	N/A	N/A
	c. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	d. No. of continuous staircase to terrace	N/A	N/A	N/A
	e. Width of corridor	N/A	N/A	N/A
	f. Door size	2 x 1.50 mtr	1.50 mtr & 1.50 mtr	MR
3	Compartmentation.			
	• Fire check door.	N/A	N/A	N/A
	• Sealing of electrical shafts.	N/A	N/A	N/A
	• Fire rating of shaft door.	N/A	N/A	N/A
	• Water curtain	N/A	N/A	N/A
	• Fire dampers.	N/A	N/A	N/A
4.	Smoke Management system.			
	• Basement	N/A	N/A	N/A
	• Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers	Fire safety arrangement Common with building		
	• Total numbers	05	Provided	MR
	• Types	ABC / Co2	Provided	MR
	• .ISI Marking	ISI Marked	Provided	MR
6.	First Aid Hose Reels.	Fire safety arrangement Common with building		

	<ul style="list-style-type: none"> Total numbers on each floor. Length of hose-reel hose. Nozzle Diameter 	01 at each floor	Provided	MR
		30 m	Provided	MR
		5 mm	Provided	MR
7	Automatic Fire Detection & Alarming System.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's location 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	<ul style="list-style-type: none"> Basement Upper floors (on 3rd floor) Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
11.	Internal Hydrants.	Fire safety arrangement Common with building		
	<ul style="list-style-type: none"> Size of Riser / Down-comer Number of Hydrant per floor Hose box. 	100 mm	Provided	MR
		01 each floor	Provided	MR
		01 each floor	Provided	MR
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants. Hose box. 	N/A	N/A	N/A
		N/A	N/A	N/A
13.	Pumping arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main pump. Head of main pump. Number of main pumps. Jockey Pump output. Jockey Pump head. Standby Pump output. Standby Pump head. Auto Starting / Manual Stopping. Pump House Access Terrace Level <ul style="list-style-type: none"> Discharge of pump. Head of pump. Power supply. Auto starting of pump. 	Fire safety arrangement Common with building		
		2850 LPM	2850 LPM	MR
		80 M	80 M	MR
		01	01	MR
		180 LPM	180 LPM	MR
		80 M	80 M	MR
		2850 LPM	2850 LPM	MR
		80 M	80 M	MR
		Required	Provided	MR
		Required	Provided	MR
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
14.	Captive water storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity. <ul style="list-style-type: none"> Draw-off connection. Fire Service Inlet. Access to tank. Overhead tank capacity. 	NA	2,00,000 ltrs	NA
		N/A	Provided	N/A
		N/A	Provided	N/A
		N/A	Provided	N/A
		20,000 Ltrs	Provided	MR
15.	Exit Signage.	Required	Provided	MR
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of lift shaft. Pressurization of lift lobby. Communication in lift car. Fireman's switch. Lift signage. 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A

17	Standby Power Supply	Required	Provided	MR
18.	Refuge Area			
	• Total area	N/A	N/A	N/A
	• Location	N/A	N/A	N/A
19.	Fire Control Room.			
	• Detector System Panel.	N/A	N/A	N/A
	• Flow Switch Panel.	N/A	N/A	N/A
	• PA system Panel.	N/A	N/A	N/A
	• Battery backup	N/A	N/A	N/A
	• Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for the Protection of special Risk, if any.	Required	DCP extinguishers provided near electric panel	MR

Note:- Fire Safety arrangement provided by Revenue Estate of Village Bahapur, Kh. No 222, Mathura Road, New Delhi

The Fire protection systems provided in the building were test checked at random and found functional at the time of inspection.

Keeping in view of the substantially satisfactory compliance of the minimum standards on fire prevention and fire safety measures as required under the rules, it is recommended to issue Fire Safety Certificate under rule 35 (3) of the Delhi Fire Service Rules, 2010

Accordingly DFA is put up for approval and signature please.

M.K. Sharma
Signature of the Inspection Officer
Name : Sh. M.K Sharma
Designation :- DO (South)

Rajesh Kumar
Signature of the Inspecting Officer
Name: Sh. Rajesh Kumar
Designation: ADO (BCP)

CFO (HQ)

Vineet
13/7/2023

Director
17/7/23
FT PL

As approved, F.T. letter is put up for your signature P/

Director
10/7/23

1/8/23

Uploaded
19/7/23