



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE, NEW DELHI-110001

No.F.6/DFS/MS/Hospital/ SZ/2023/ 352

Dated: 24/07/2023

FIRE SAFETY CERTIFICATE

Certified that M/s **New Private Ward** located at AIIMS Complex, Ansari Nagar, New Delhi-110029, comprised of **Ground plus + 03 Upper Floors**, owned / occupied by **All India Institute of Medical Sciences** was issued Fire Safety Certificate by this department vide letter No. F6/DFS/MS/Hospital/SZ/2020/156 dated 17/03/2020. The premises was re-inspected by the officer concerned of this department on 30/06/2023 in the presence of Mr. Naresh Kumar Yadav (ASO) and found that the said building have deemed complied with the fire prevention and Fire Safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the building is fit for occupancy "**Group-C "Institutional"** (Hospital) with effect from 24/07/2023 for a period of **three years** in accordance with rule 36 unless renewal under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the DFS rules, 2010.

Issued on 24/07/2023 at New Delhi by.

(ATUL GARG)
DIRECTOR
Delhi Fire Service

Copy to :-

1. Mr. Naresh Kumar Yadav (Asstt. Security Officer), All India Institute of Medical Sciences, Ansari Nagar, New Delhi-110029.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The Basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction.
7. "The owner / Occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
8. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: M/s New Private Ward, AIIMS
: Complex, Ansari Nagar, New Delhi-110029.
2. Type of Occupancy : Institutional Building "Group-C" (Hospital)
3. Building Comprised of : G+ 03 upper floor. All floors for inpatients care
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/Hospital/SZ/2020/156 dated 17/03/2020
6. Fire Safety directives Letter No.: Nil
7. Date of inspection : 30/06/2023
8. Name of the Inspecting Officer : Santosh Kumar AD.O.(SJ)
9. Name and designation of Officer
from the building side : Mr. Naresh Kumar Yadav (ASO)
10. Year of Construction : 1960
11. Applicant's letter received through email ID- dated 07/05/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	9 mtr	Provided	MR
	• Gate width	5 mtr	Provided	MR
	• Width of internal road	NA	Pota cabins removed	MR
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	05 Nos	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper floors	1.37m Each	1m, 1.25 & 1.15m, 0.80m & 0.70m	MR (Old Bldg.)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	Required	One Provided	MR <i>old case</i>
	e. Width Of Corridor	NA	NA	NA
	f. Door Size	NA	1 m	NA
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	Required	Provided	MR
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke managements System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilation	MR
5.	Fire Extinguishers			
	• Total numbers	40 Nos	70 Nos	MR
	• Types	ABC/CO ₂ & WCO ₂	ABC & CO ₂	MR
	• ISI marking	ISI	Provided	MR

6.	First – Aid Hose Reels			
	• Total numbers on each floor	NA	05 Nos	NA
	• Length of hose reel hose	NA	30m	NA
	• Nozzle diameter	NA	5 mm	NA
7.	Automatic fire detection and alarming system			
	• Type of detector	NA	Provided	NA
	• Location of Main Panel	NA	Ground floor	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	Provided	NA
8.	MOEFA	NA	Provided	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basements	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	• Discharge of main pump	NA	NA	NA
	➤ Head of main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	NA	450 LPM (2 Nos)	NA
	➤ Head of the pump	NA	40 m (each)	NA
	➤ Power supply	NA	Provided	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting			
	• Underground tank capacity	NA	NA	NA
	➤ Draw of connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	20,000 Lts	NA

		N/3		
		Required	Provided	MR
15.	Exit Signage			
16.	Provision of Lifts			NA
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			NA
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			NA
	➤ Detector system panel	NA	NA	NA
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	NA	NA	NA
	➤ Battery backup	NA	NA	NA
	➤ Building Floor Plans	NA	NA	NA
20.	Special Fire Protection Systems for Protection of special Risks, if any;	NA	NA	NA

The fire protection systems provided in the building/premises were checked, tested at random and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules the NOC issued vide letter No. F6/DFS/MS/Hospital/SZ/2020/156 dated 17/03/2020 renewal under rule 35 of the Delhi Fire Service rules 2010 is recommended.

Accordingly, DFA is put up for approval and signature please.

Santosh Kumar
 03/07/23
 Signature of the Inspecting Officer
 Name: Santosh Kumar
 Designation: A.D.O.

DO/CS (with)
mm

21/7/23

C/S
5/7/2023

Director

Antony

Aditya