



No.F6/DFS/MS/EH/NDZ/2023/226

Dated: 14/07/2023

FIRE SAFETY CERTIFICATE

Certified that the Rockers and Shockers Pvt. Ltd. running at 2nd floor located at shop no.20, Star City Mall, Mayur Vihar, Delhi, in a building comprising of Basement, Ground & 2 Upper floor, owned / occupied Rockers and Shockers Pvt. Ltd have complied with the Fire Prevention and Fire Safety requirements in accordance with rule 33 of Delhi Fire Service Rules, 2010 and verified by the officer concerned of this department on 19/06/2023 in the presence of Mr. Ankit Gupta and found that the building/premises is fit for occupancy class "Assembly" (Group D) / Eating House (Restaurant at 2nd Floor only) and valid up to 31/03/2026 (Three years) in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued 14/07/2023 at New Delhi by


(ATUL GARG)
DIRECTOR
DELHI FIRE SERVICE

Copy to:-

1. Authorized Signatory, Rockers and Shockers Pvt.Ltd located at shop no.20, 2nd floor, Star City Mall, Mayur Vihar, Delhi.
2. The Joint Commissioner of Police(Lic.), 1st Floor, PS Defence Colony, New Delhi-110024.

Condition for the validity of fire safety certificate

- 1 All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
- 2 Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
- 3 The trained fire fighting staff should be available round the clock.
- 4 Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
- 5 This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
- 6 The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
- 7 The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
- 8 The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry".

INSPECTION REPORT

1	Name & address of the building	Rockers and Shockers Pvt. Ltd located at shop no.20, 2 nd floor, Star City Mall, Mayur Vihar, Delhi.			
2	Building is comprised of	Rockers and Shockers running at 2 nd Floor only.			
3	Type of occupancy	Assembly (E/H)			
4	Type of case	New Case			
5	Details of previous FSC	Nil (FSC also issued to the Star City Mall vide letter no. F6/DFS/MS/NDZ/2021/376 dated 05.08.2021)			
6	Fire safety direction letter no.	Nil			
7	Date of inspection	19.06.2023			
8	Name of the inspecting officers	A.K.Jaiswal, DO (ED) & Yashwant Singh Meena ADO (L.N)			
9	Name of the designation of officer From the building side	Mr. Ankit Gupta			
10	Year of construction	2007			
11	Applicant's letter no.	Emial- 15.06.2023			
S. No	Minimum standard of Fire Prevention and Fire Safety U/R 33	Requirements NBC	Provide at site	Remarks MR/NMR	
1	Access to Building				
	A	Road width	12 mtrs	13 mtr	MR
	B	Gate width	N/A	6.0 mtrs	N/A
	C	Width of internal roads	N/A	6.0 mtrs	N/A
2	Number, Width, Type & Arrangement of Exits				
	A	No. of staircase:			
		a) Upper floor	02 nos.	05 nos.	MR
		b) Basements	N/A	9+1 ramp	N/A
	B	Width of the staircase:			
		a) Upper floors	1.25 mtrs.	1.35 mtrs x 1, 1.25 mtrs x 3, 0.90 mtrs x 1.35 mtrs.	MR
		b) Basements	N/A	1.25 mtrs & 1.35 mtrs	N/A
	C	Protection of Exits			
		a) Fire check door	Required	Provided	MR
		b) Pressurization	N/A	Provided	N/A
	D	No. of continuous staircase to terrace:	N/A	Provided	N/A
	E	Width of the corridor	N/A	N/A	N/A
	F	Door size	1.50 mtrs x 2	Provided	MR
3	Compartmentation:				
	A	Fire check doors	Required	Provided	MR
	B	Sealing of horizontal & vertical opening	N/A	Provided	N/A
	C	Fire rating of shaft, doors	N/A	Provided	N/A
	D	Water curtain	N/A	N/A	N/A
	E	Fire dampers	N/A	Provided	N/A
4	Smoke management System:				
	A	Basements	N/A	Provided	N/A
	B	Upper floors	Required	Provided	MR
5	Fire extinguishers				
	A	Total numbers	02 nos.	04 nos.	MR
	B	Types	ISI marked ABC/CO ₂	Provided	MR
	C	ISI marking	ISI marked	Provided	MR

6	First Aid Hose Reel				
	A	Total no. at each floor	01no.	Provided by the mall	MR
	B	Length of hose reel	30 mtrs	Provided by the mall	MR
	C	Nozzle diameter	5 mm	Provided by the mall	MR
7	Automatic Fire Detection and Alarm System				
	A	Type of detectors	N/A	Provided	N/A
	B	Location of main Panel	N/A	Provided by the mall	N/A
	C	Location of repeater panel	N/A	Provided	N/A
	D	Alternate power source	N/A	Provided	N/A
	E	Hooter's location	N/A	Provided	N/A
8	MOEFA		Required	Provided	MR
9	Public Address System		N/A	N/A	N/A
10	Automatic Sprinkler System				
	A	Basement	N/A	Provided	N/A
	B	Upper floor	Required	Provided	MR
	C	Sprinklers above false ceiling	Required	Provided	MR
11	Internal Hydrants				
	A	Size of the riser/down comer	Required	Provided by the mall	MR
	B	No. of hydrants per floor	Required	Provided by the mall	MR
	C	Hose box	Required	Provided by the mall	MR
12	Yard Hydrants				
	A	Total no. of hydrants	N/A	Provided	N/A
	B	Hose box	N/A	Provided	N/A
13	Pumping arrangements		Provided by the mall		
	A	Ground Level			
		a) Discharge of main pump	4500 LPM	4500 LPM	MR
		b) Head of Main Pump	50 mtrs	50 mtrs	MR
		c) Number of Main Pump	02 nos.	02 nos.	MR
		d) Jockey Pump out put	450 LPM	450 LPM	MR
		e) Jockey Pump Head	50 mtrs	50 mtrs	MR
		f) Standby Pump out put	4500 LPM	4500 LPM	MR
		g) Standby Pump Head	50 mtrs	50 mtrs	MR
		h)Auto Stating/ Manual	Required	Provided	MR
		i) Pump House Access	Required	Provided	MR
	B	Terrace Level			
		All above pups on terrace			
		a) Discharge of Pump	N/A	N/A	N/A
		b) Head of terrace pump	N/A	N/A	N/A
		c) Power supply	N/A	N/A	N/A
		d) Auto starting of pump	N/A	N/A	N/A
14	Captive Water Storage for Fire Fighting.				
	A	Underground tank capacity	N/A	2,00,000 ltrs	MR
	B	Draw off connection	N/A	Provided by the mall	MR
	C	Fire Service Inlet	N/A	Provided by the mall	MR
	E	Access to tank	N/A	Provided by the mall	MR
	D	Overhead tank capacity	20,000 ltrs	25,000 ltrs	MR
15	Exit Signage		Required	Provided	MR
16	Provision of lift				
	A	Pressurization of lift shaft	N/A	Provided	N/A
	B	Pressurization of lift lobby	N/A	Provided	N/A
	C	Communication in lift car	N/A	Provided	N/A
	D	Fireman switch	N/A	Provided	N/A
	E	Lift signage	N/A	Provided	N/A
17	Standby Power Supply		Required	Provided	MR

Rockers and Shockers Pvt.Ltd located at shop no.20, 2nd floor, Star City Mall, Mayur Vihar, Delhi.

18 Refuge Area				
A	location	N/A	N/A	N/A
B	Total area	N/A	N/A	N/A
19 Fire Control Room				
A	Fire Detection System panel	N/A	Provided	N/A
B	Flow switch panel	N/A	Provided	N/A
C	P A system panel	N/A	Provided	N/A
D	Battery backup	N/A	Provided	N/A
E	Building floor plan	N/A	Provided	N/A
20 Special Fire Protection for special risk if any				
A	Special Fire Protection system for Protection of Special Risk, if any:	NA	Provided in all LT & HT Panel	NA

The fire protection system was randomly checked and tested and was found functional at the time of inspection. The shortcomings issued vide letter no. F6/DFS/MS/2023/NDZ/147 dated 23.03.2023 by this department have been rectified by the management.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety measures as required under the Rules, it is recommended to grant Fire Safety Certificate under Rules 37 of Delhi Fire Service Rules 2010.

A.K. Jaiswal
23/06/2023

Signature of the Inspecting Officer
Name: A.K. Jaiswal
Designation: DO (ED)

Yashwant Singh Meena
25/6/2023

Signature of the Inspecting Officer
Name: Yashwant Singh Meena
Designation: ADO (L.N)

Dy.CFO (NDZ) on leave

CFO
Please speak with Dy CFO.
[Signature]
26/6/2023

DO + Dy CFO (NDZ)
on leave

[Signature]
28/06/2023

ADO (L.N.) spoken with worthy CFO along with DO (E) & Dy CFO (NDZ),
Fighting Haze has already been approved by this department vide letter No. F6/DFS/MS) BA/2009/1969 dated 30.8.2009. file is submitted for approval/ Signature already

[Signature]
DO (E)

May please be approved.

[Signature]
6/7/2023