



**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI – 110001**

No. F6/DFS/MS/WZ/IND./2023/ 357

Dated: 24/07/2023

**FIRE SAFETY CERTIFICATE**

Certified that the Om Enterprises Located at Plot No.- A-8, Wazirpur Industrial Area, Delhi-110052, in a building comprised of Basement + Ground + 01 Upper Floors, owned/occupied by Om Enterprises was issued Fire safety Certificate vide Letter No. F6/DFS/MS/WZ/2020/261 dated 06/07/2020, The premises was re-inspected by officer concerned of this department on 12/07/2023 in the presence of Sh. Sunil Mohta (Owner) and found that the said building/Premises have deemed complied with the fire prevention & fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rule 2010 & the said premises is fit for occupancy class "Industrial" Group G with effect from 24/07/2023 for a period of three year in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules 2010 conditions printed overleaf.

Issued on 24/07/2023 at New Delhi by.

  
Atul Garg  
Director

o/c 24/07/2023

**Copy to:**

1. The Owner/occupier Om Enterprises Located at Plot No.- A-8, Wazirpur Industrial Area, Delhi-110052.
2. The Executive Engineer (Building), MCD, Shivaji Enclave, Rajouri Garden New Delhi-110027.

# INSPECTION REPORT

1. Name & address of the building	Om Enterprises, Plot No.-A-8, Wazirpur Industrial Area, Delhi-110052.
2. Type of Occupancy	Industry (Basement + Ground + 01 Upper floors)
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/WZ/2020/261 dated 06/07/2020
5. Fire Safety directives letter No	Nil
6. Date of inspection	12/07/2023
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Sunil Mohta (Owner)
9. Year of Construction	2006 (As per prev, Insp. report dtd- 17/06/2020)
10. Applicant's letter No.	Email dated 27/06/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	18 Mtr	18 Mtr Provided	MR
	• Gate width	05 Mtr	2.70 Mtr Provided	MR(Old Case)
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	02	Provided	MR
	b. Width of staircases			
	• Upper Floors	1.5 m each	1X 140 to 150cm, 1X 113cm	MR(Old Case)
	• Basements	1.5 m each	1x 117cm to 127cm, 1x100cm	MR(Old Case)
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	NA	NA	NA
	g. Door Size	1 Mtr	Varies from 97 to 115cm	MR(Old Case)
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	Required	Provided	MR
	• Upper floors	NA	NA	NA
5	<b>Fire Extinguishers</b>			
	• Total numbers	10nos.	Provided	MR
	• Types	CO <sub>2</sub> , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

88/



6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	Smoke & Heat	Provided	MR
	• Location of Main Panel	Ground Floor	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	<b>MOEFA</b>	Required	Provided	MR
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	• Basement	Required	Provided	MR
	• Upper Floor	Required	Provided	MR
	• Sprinkler above false ceiling	NA	NA	NA
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	100 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	Required	Provided	MR
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	<b>Pumping Arrangements.</b>			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/ Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace level			
	➤ Discharge of pump	900 lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	25,000 ltrs	Provided	MR
	➤ Draw-off connection	NR	NR	NR
	➤ Fire service inlet	NR	NR	NR
	➤ Access to tank	NR	NR	NR
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR



16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	NA	NA	NA
	• Fireman's Grounding Switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

ADDO/MN  
14/07/2023

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/WZ/2020/261 dated 06/07/2020 renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

DCFO (sh.m.kc) / DO (West)

Signature of the Inspecting Officer  
Name: - Sarabjeet Singh  
Designation: - ADO (MN)

14/7

DCFO (MKE)

M.K. CHATTOPADHYAY

CFO

Director  
14/7/2023

ADO MN

Sir, F.T is put up for your kind personal & signature please.

DCFO/.../003  
Dated...14/7/2023