

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, NEW DELHI -110001

No. F6/DFS/MS/DMRC/WZ/2023/ 358

Dated: 25/07/2023

FIRE SAFETY CERTIFICATE

Certified that the Kirti Nagar, Metro station (Line No. -05) Located at Kirti Nagar New Delhi, comprised of Ground + Concourse + Platform (Except PD Area), was issued FSC vide Letter No. F6/DFS/MS/DMRC/2020/WZ/299 dated 07/08/2020. The premises was re - inspected by the officer concerned of this department on 07/07/2023 in the presence of Sh. Sanyam Jain (AM/Fire) and found that the said building have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class "Assembly" Group D (Sub Division D-7) with effect from 25/07/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. Conditions mentioned below.

Issued on 25/07/2023 at New Delhi by.

(Atul Garg)
Director

Copy to: -

1. Sh. Vivek Srivastava (JGM/E&M), Metro Bhawan, Fire Brigade Lane, Barakhamba Road, New Delhi-110001.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations/ Addition & Alteration w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in.
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.

INSPECTION REPORT

1. Name & address of the building : Kirti Nagar, Metro Station (Line No. -05) (Except PD Area), Located at Kirti Nagar, New Delhi-110015.
2. Type of Occupancy : Assembly
3. Type of Case : Renewal (Ground + Concourse + Platform)
4. Details of previous NOC : F6/DFS/MS/DMRC/2020/WZ/299 dated 07/08/2020
5. Fire Safety directives letter No : F6/DFS/MS/BP/2009/167 dated 20/01/2009
6. Date of inspection : 07/07/2023
7. Name of the Inspecting Officers : Sarabjeet Singh (ADO MN)
8. Name and designation of officers from the building side : Sh. Sanyam Jain (AM/Fire)
9. Year of Construction : 2011 (As per prev. Insp. report 30/07/2020)
10. Applicant's letter No. : Email dated - 03/07/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR															
1	Access to building																		
	<ul style="list-style-type: none"> • Road width • Gate width • Width of internal road 	<table border="1"> <tr> <td>On Main Road</td> <td>Provided</td> <td>MR</td> </tr> <tr> <td>05 mts</td> <td>05 m Provided</td> <td>MR</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>MR</td> </tr> </table>	On Main Road	Provided	MR	05 mts	05 m Provided	MR	NA	NA	MR								
On Main Road	Provided	MR																	
05 mts	05 m Provided	MR																	
NA	NA	MR																	
2	Number, Width, Type & Arrangement of Exits																		
	a. Number of staircases																		
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<table border="1"> <tr> <td>02</td> <td>Provided</td> <td>MR</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> </table>	02	Provided	MR	NA	NA	NA											
02	Provided	MR																	
NA	NA	NA																	
	b. Width of staircases																		
	<ul style="list-style-type: none"> • Upper Floors • Basements 	<table border="1"> <tr> <td>2 m</td> <td>1- G.F.to Con.2.50m , 2-Con. to Platform-4.50m</td> <td>MR</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> </table>	2 m	1- G.F.to Con.2.50m , 2-Con. to Platform-4.50m	MR	NA	NA	NA											
2 m	1- G.F.to Con.2.50m , 2-Con. to Platform-4.50m	MR																	
NA	NA	NA																	
	c. Protection of exits																		
	<ul style="list-style-type: none"> • Fire check door • Pressurization 	<table border="1"> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> </table>	NA	NA	NA	NA	NA	NA											
NA	NA	NA																	
NA	NA	NA																	
	e. No. of continuous staircases to terrace	NA	NA	NA															
	f. Width of Corridor	NA	NA	NA															
	g. Door Size	NA	NA	NA															
3	Compartmentation.																		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<table border="1"> <tr> <td>Required</td> <td>Provided</td> <td>MR</td> </tr> <tr> <td>Required</td> <td>Provided</td> <td>MR</td> </tr> <tr> <td>Required</td> <td>Provided</td> <td>MR</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> </table>	Required	Provided	MR	Required	Provided	MR	Required	Provided	MR	NA	NA	NA	NA	NA	NA		
Required	Provided	MR																	
Required	Provided	MR																	
Required	Provided	MR																	
NA	NA	NA																	
NA	NA	NA																	
4	Smoke Management System.																		
	<ul style="list-style-type: none"> • Basements • Upper floors 	<table border="1"> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> <tr> <td>NA</td> <td>NA</td> <td>NA</td> </tr> </table>	NA	NA	NA	NA	NA	NA											
NA	NA	NA																	
NA	NA	NA																	
5	Fire Extinguishers																		
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	35 nos. CO2 & WCO2, ISI Required	<table border="1"> <tr> <td>Provided</td> <td>MR</td> </tr> <tr> <td>Provided</td> <td>MR</td> </tr> <tr> <td>Provided</td> <td>MR</td> </tr> </table>	Provided	MR	Provided	MR	Provided	MR										
Provided	MR																		
Provided	MR																		
Provided	MR																		

6	First-Aid Hose Reels.			
	• Total numbers on each floor	2 (At Each PF)	Provided	MR
	• Length of hose reel hose	45 m	Provided	MR
	• Nozzle diameter	6.5 mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Smoke	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	• Basement	NA	NA	NA
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	02 on each P.F.	Provided	MR
	• Hose Box	Required	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	02	Provided	MR
	• Hose Box	Required	Provided	MR
13	Pumping Arrangements.			
	• Ground Level	All the pumps are connected with generator also		
	➤ Discharge of main Pump	1800 lpm	Provided	MR
	➤ Head of Main pump	80m	Provided	MR
	➤ Number of main pumps	01	Provided	MR
	➤ Jockey Pump out put	180 lpm	Provided	MR
	➤ Jockey pump head	80 m	Provided	MR
	➤ Standby Pump out put	1800 lpm	Provided	MR
	➤ Standby Pump Head	80m	Provided	MR
	➤ Auto Starting/ Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power Supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	1,00,000 ltrs	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	Required	Provided	MR

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	Required	Provided	MR
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	Required	Provided	MR
	• Batter backup	Required	Provided	MR
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	Co ₂ Flooding for ASS, HT, LT Panel	Provided	MR

The fire protection systems provided in the Building were test checked and found functional at the time of inspection.

Keeping in view deemed compliance of the minimum standards on fire prevention and fire safety requirements under the rules, renewal of fire safety certificate is issued vide letter no. F6/DFS/MS/DMRC/2020/WZ/299 dated 07/08/2020 is recommended.

Dy CPO (S.M.K.C.) / DC (F.S.R.)

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

ADD | MN
107 | 2023

M.K. CHATTOPADHYAY
CFO

18/07/2023

Director

DCFO / ... / ...
Dated: 18/07/2023

ADU/MN Sir F.T is put up for your kind personal & signature pls.

18/07/2023