



C-23

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

75
आजादी का
अमृत महोत्सव

No F 6 / DFS / MS / 2023 / School / WZ / 508

Dated: 25/7/2023

FIRE SAFETY CERTIFICATE

Certified that **Dhankaur Devi Convent School** located at **Sannoath, Delhi-110040** comprised of **Ground+ One upper floor** owned/occupied by **Dhankaur Devi Convent School** was issued FSC by this department vide letter No **F6/DFS/MS/2017/WZ/565** dated **19.04.2017**. The premises was inspected by the officer concerned of this department on **17.07.2023** in the presence of **Smt. Seema Rana (Principal)** and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no **3298-3398** dated **01.03.2011** and the building/ premise is fit for occupancy **Group B Educational** with effect from **25/7/2023** for a period of three years and subject to compliance of the conditions mentioned below.

Issued on **25/7/2023** at New Delhi, by


(Atul Garg)
Director
Delhi Fire Service


Copy to : -

1. The Director of Education, GNCT of Delhi, Old Secretariat, Delhi.
2. The Principal, Dhankaur Devi Convent School, Sannoath, Delhi-110040.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

N-13

INSPECTION REPORT

1. Name & address of the building : Dhankaur Devi Convent School located at Sannoath, Delhi-110039.
 2. Type of Occupancy : Educational
 3. Building Comprised : Ground + First Floor
 4. Type of Case : Renewal
 5. Details of Previous NOC : Letter No. F.6/DFS/MS/2017/WZ/565 Dated-19/04/2017
 6. Fire Safety directives letter No : Dir of Edu. Cir. No. 3298-3398 dated 01/03/3011
 7. Date of inspection : 17/07/2023
 8. Name of Inspecting Officer : ADO, R.K.Sinha
 9. Name and designation of officers
 From the building side : Smt. Seema Rana (Principal)
 10. Year of Construction : 2013 & 2016
 11. Applicant's letter No. : D.D.C.S./DFS-07/2023 , Dated-03/07/2023

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6.0 m	6.0 m	MR
	• Gate width	4.5 m	Directly Accessible	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases	1.50 m	1.30 m & 1.05 m	MR(old case)
	• Upper Floor	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	NA	NA	NA
	e. Width of Corridor	1.00 m	Provided	MR
	f. Door Size			
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	NA	NA	NA
	• Upper floors	12 a/c per hour	Natural Ventilated	MR

5.	Fire Extinguishers			
	• Total numbers	04	Provided	MR
	• Types	ABC	ABC	MR
	• IS marking	Yes	Yes	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	NA	NA	NA
	• Length of hose reel hose	NA	NA	NA
	• Nozzle diameter	NA	NA	NA
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	NA	NA
	• Location of Main Panel	NA	NA	NA
	• Location of Repeater Panel	NA	NA	NA
	• Alternate source of power	NA	NA	NA
	• Hooters' Location	NA	NA	NA
8.	MOEFA	NA	NA	NA
9.	Public Address System	NA	NA	NA
10.	Automatic Sprinkler System			
	• Basement	NA	NA	NA
	• Ground Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants			
	• Size of riser/down-comer	NA	NA	NA
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12.	Yard Hydrants			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey Pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby Pump out put	NA	NA	NA
	➤ Standby Pump Head	NA	NA	NA
	➤ Auto Starting/Manual Stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA

Handwritten signature

	<ul style="list-style-type: none"> • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	-	-	-
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		-	-	-
		NA	NA	NA
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
15.	Exit Signage.	NA	NA	NA
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
17.	Standby power supply	NA	NA	NA
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	NA	NA	NA
		NA	NA	NA
9.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Battery backup • Building Floor Plans 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
0.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA

or ✓