

C43

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001

No.F6/DFS/MS/EH/NDZ/2023/240

Dated :- 25.07.2023

FIRE SAFETY CERTIFICATE

Certified that the M/s Jubilant Foodworks Pvt. Ltd. (Domino's Pizza) located at M-40, Connaught Place, New Delhi in a building comprises of Ground + 02 upper floor, Restaurant running at ground floor only, was earlier granted FSC vide letter no. F6/DFS/MS/EH/NDZ/2020/88 dated 29.04.20. Now, the premises was re-inspected by the officers concerned of this department on 14/07/2023 in the presence of Mr. Rahan and found that the said restaurant building has deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Assembly Building (Group D), Restaurant at ground floor only and valid up to 31.03.2026 from the date of issue in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010 printed below.

Issued... 25/07/2023 at New Delhi by.


(Atul Garg)
DIRECTOR
Delhi Fire Service

Copy to:-

1. The Chief Architect, NDMC, Palika Kendra, New Delhi.
2. The Joint Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi.ID No. 2023070612080 dated 06.07.23.
3. M/s Jubilant Foodworks Pvt. Ltd. (Dominos Pizza) located at M-40, Connaught Place, New Delhi.

Conditions for the validity of Fire Safety Certificate

1. This FSC is valid only for restaurant at ground only.
2. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
3. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
4. The trained firefighting staff should be available round the clock.
5. Any deviation w.r.t. construction, use of occupancy, height of building, electric installation, set back area etc. shall be checked & verified by the concerned authority.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
8. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
9. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
10. Any flammable material for interior decoration shall strictly be prohibited.

18
INSPECTION REPORT

1. Name & address of the building M/s Jubilant Foodworks Pvt. Ltd. (Dominos Pizza) located at M-40, Connaught Place, New Delhi. G +M+ 2 upper floor
2. Type of occupancy:- Assembly Building Group-D
Restaurant running at Ground floor only
3. Type of case:- Renewal
4. Details of previous FSC:- F6/DFS/MS/EH/NDZ/2020/88 dated 29.04.20
5. Fire safety directives No.- N/A
6. Date of inspection:- 14/07/23
7. Name of the inspecting officer:- Sh. Rajinder Atwal (DO/CD) & Sh. Ravinder Singh (ADO/CC)
8. Name & designation of officer
From the building side:- Mr. Rahan
9. Year of construction:- Old building.
10. Applicant's letter No:- online id 2023070612080 dated 06.07.2023.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement/ Existing fire safety arrangements	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	6 mtr.	9 mtr.	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	N/A	N/A	N/A
	2. Basements	N/A	N/A	N/A
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace			
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	02 mtr, 1.5m	2.13 mtr, 1.5m	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	12 ACPH	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
5.	Fire Extinguishers			
	1) Total numbers	04 Nos.	08 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
6.	First-Aid Hose Reel			

✓
n 6 w


	1) Total number	01	01	MR
	2) Length of hose reel hose	30 mtr.	30 mtr.	MR
	3) Nozzle diameter	05 mm	05 mm	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors/ Gr. floor	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	100mm	Provided	MR
	2) Number of hydrants	01 nos.	Provided	MR
	3) Hose box	01 nos.	Provided	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
13.	Pumping Arrangement			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	450 LPM	450 LPM	MR
	b) Head of pump	40 mtr.	40 mtr.	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	N/A	N/A	N/A
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	N/A	N/A	N/A
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	20,000 ltr.	20,000 ltr.	MR
15.	Exit Signage.	Required	Provided	MR

16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A
	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	N/A	N/A	N/A
	e) Lift signage	N/A	N/A	N/A
17.	Stand by Power Supply	N/A	N/A	N/A
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The fire protection systems provided in the building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no. F6/DFS/MS/EH/NDZ/2020/88 dated 29.04.20, under rule 35(6) of the Delhi Fire Service rules 2010. Accordingly, DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer



18/7/23

Name :- Rajinder Atwal
Designation :- DO (CD)

Signature of the Inspecting Officer



18/7/23

Name :- Ravinder Singh
Designation :- ADO (CC)

~~By CFS (MS)~~

~~19/07/23~~

~~CFO~~

~~19/07/2023~~

~~Director~~

~~20/07/23~~

~~DO/ID~~

~~Asst~~

~~As a result, FSC put up for kind perusal and signature please.~~

~~Uploaded~~

~~21/7/23~~