

C-42

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No F 6/DFS/MS/2023/School/WZ/ 5/4

Dated: 27/07/2023

FIRE SAFETY CERTIFICATE

Certified that the Avadh Public School, E-Block, 40 Foot Road, Prem Nagar-III, Kirari, Delhi-110086, now comprised of building Ground + 03 upper floors only but school is running on Ground + 01 upper floors owned/occupied by Avadh Public School was granted FSC by this department vide letter No. (F.6/DFS/MS/School/WZ/2020/117 dated 17.03.2020-Gr. + 01 upper floor). The premises was re-inspected by the officer concerned of this department on 04.07.2023 in the presence of Sh. Bajrang Shukla (Manager) and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have deemed complied with requirements of circular issued by Director of Education letter no 3298-3398 dated 01.03.2011 and the building/ premise is fit for occupancy Group B Educational with effect from27/07/2023..... for a period of three years, subject to compliance of the conditions mentioned below:

Issued on ..27/07/2023..... at New Delhi


(Atul Garg)
DIRECTOR
Ph; 011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sect. Delhi - 54.
2. The Principal, Avadh Public School, E-Block, 40 Foot Road, Prem Nagar-III, Kirari, Delhi-110086.

Conditions for the validity of Fire Safety Certificate:

1. All the fire safety arrangement provided there-in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. This certificate cannot be treated in any case for regularizations of unauthorized construction.
6. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director of Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on
8. All the means of escape shall be kept free of any obstruction all the time to evacuate the occupant, in a safe manner, in the event of emergency.

http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Fire+Safety+Acts+and+Ru
[les/ http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms](http://www.delhi.gov.in/wps/wcm/connect/doit_fire/FIRE/Home/Forms)

N/24

INSPECTION REPORT

1. Name & address of the building : Avadh Public School, E-Block, 40 Foot Road, Prem Nagar-III, Kirari, Delhi-110086.
2. Type of Occupancy : Educational
3. Type of Case : Renewal (Gr. + 1 upper floor) Building comprised of Gr.+ 03 upper floors but school is running on ground & 01 upper floors
4. Details of Previous NOC : (F.6/DFS/MS/School/WZ/2020/117 dated 17.03.2020 Previous FSC Ground + 1 upper floor only)
5. Fire Safety directives letter No : Dir. of Education Cir. dated 01.03.2011.
6. Date of inspection : 04.07.2023
7. Name of Inspecting Officer : A.K.Sharma ADO(Rohini)
8. Name and designation of officers
From the building side : Sh. Bajrang Shukla (Manager)
9. Year of Construction : 2005 & 2006
10. Applicant's letter No. : OD No.2622 dated 07.06.2023.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. of Edu. Cir. dated 01.03.2011/ NBC requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	6.0m	4.5m(Accessible by one length of hose from 6.0m road)	MR (Old case)
	• Gate width	4.5m	4.5m	MR
	• Width of internal road	NA	NA	NA
2.	Number, Width, Type & Arrangement of Exits			
	d. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	NA	NA	NA
	e. Width of staircases			
	• Upper Floor	1.5m	1.20m & 0.93m	MR (old case)
	• Basements	NA	NA	NA
	f. Protection of exits			
	Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	1.5m	1.0m	MR (old case)
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4.	Smoke Management System			
	• Basements	30 a/c per hour	NA	NA
	• Upper floors	12 a/c per hour	Natural ventilated	MR
5.	Fire Extinguishers			
	• Total numbers	08nos.	10nos.	MR
	• Types	ABC/CO2	ABC-10	MR
	• IS marking	ISI marked	Yes	MR
6.	First Aid Hose Reels			
	• Total numbers on each floor	01	Provided	MR

Ay k

2/25

Fire Control
• Detect

	<ul style="list-style-type: none"> Length of hose reel hose Nozzle diameter 	30mm 5m	Provided Provided		
7.	Automatic fire detection and alarming system				
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA		NA NA NA NA NA
8.	MOEFA	NA	NA		NA
9.	Public Address System	NA	NA		NA
10.	Automatic Sprinkler System				
	<ul style="list-style-type: none"> Basement Ground & Upper Floors Sprinkler above false ceiling 	NA NA NA	NA NA NA		NA NA NA
11.	Internal Hydrants				
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA NA NA	NA NA NA		NA NA NA
12.	Yard Hydrants				
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA		NA NA
13.	Pumping Arrangements				
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/Manual Stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	NA NA NA NA NA NA NA NA NA NA 450lpm 40m Required Required	NA NA NA NA NA NA NA NA NA NA 450lpm 40m Provided Provided		NA NA NA NA NA NA NA NA NA NA MR MR MR MR
14.	Captive Water Storage for fire fighting				
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA NA NA NA 10,000ltr Required	NA NA NA NA 10,000ltr Provided		NA NA NA NA MR MR
15.	Exit Signage.				
16.	Provision of Lifts.				
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch Lift Signage 	NA NA NA NA NA	NA NA NA NA NA		NA NA NA NA NA
17.	Standby power supply	NA	NA		NA
18.	Refuge Area.				
	<ul style="list-style-type: none"> Total Area Location 	NA NA	NA NA		NA NA

My

N/26

Fire Control Room

20.	Fire Control Room <ul style="list-style-type: none">• Detector System Panel• Flow Switch Panel• PA System Panel• Battery backup• Building Floor Plans	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
20.	Special Fire Protection System for Protection of special Risks, if any:	NA	NA	NA
		All fire protection systems provided in the building were test checked and found functional at the		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view of the deemed compliance of the minimum standards of the fire prevention and fire safety measures required stipulated in **Director of Education Circular**, the FSC issued vide letter no. **F.6/DFS/MS/School/WZ/2020/117 dated 17.03.2020** is recommended for renewal under rule 37 of the Delhi Fire Service rules 2010.

Signature of the Inspecting Officer
 Name **Ajay Kumar Sharma**
 Designation **ADO(Rohini)**

D.B Mukherjee
 DO (NW)

[Signature]
 14/07/2022

[Signature]
 19/8/2022

[Signature]
 24/8/22

[Signature]
 24/8/22

[Signature]
 26/9/23
 on

As letter is put up for
 kind perusal and signature
 please.

[Signature]
 28