



48

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI

No. F6/DFS/MS/WZ/BNQT/2023/31


Dated: 01/08/2023

FIRE SAFETY CERTIFICATE

Certified that the M/s. Clay 1 Grand Banquet (A Unit of SS Banquet), Located, at C-3/2, Wazirpur, Industrial Area, New Delhi-110052 in a building comprised of Basement + Ground + Mezzanine + 02 Upper floors. Owned/Occupied by M/s. Clay 1 Grand Banquet (A Unit of SS Banquet), FSC was already issued by this department Vide letter no. F6/DFS/MS/WZ/2020/487 dated 11/11/2020 (Earlier FSC issued namely Dream Bell Banquet (A unit of S.S Banquet). The Premises was re-inspected by the officer concerned of this department on 20/07/2023 in the presence of Sh. Ankit Singh and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have deemed complied with fire prevention and fire safety requirements in accordance with Rule 33 of Delhi Fire Service Rules, 2010 and that the said floor is fit for occupancy class "Assembly" Group D (GF+FF+SF) with effect from 01/8/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010. conditions printed overleaf.

Issued on 01/08/2023 at New Delhi by.


(Atul Garg)
Director


27/7/2023

Copy to: -

1. The Joint Commissioner of Police, Licensing Unit, 1st floor, Police Station, Defence Colony, New Delhi. Email-ID:- addlcp.lic-dl@nic.in
2. The Owner/Occupier M/s. Clay 1 Grand Banquet (A Unit of SS Banquet), Located, at C-3/2, Wazirpur, Industrial Area, New Delhi-110052. (Online ID No. 2021092322362 dated 10/07/2023)
3. The Dy. Health Officer, Keshav Puram Zone, MCD, New Delhi.

INSPECTION REPORT

1. Name & address of the building	M/s. Clay 1 Grand Banquet (A Unit of SS Banquet), Located at C-3/2, Wazirpur, Industrial Area, New Delhi - 110052.
2. Type of Occupancy	Assembly
3. Type of Case	Renewal
4. Details of previous NOC	F6/DFS/MS/WZ/2020/487 dated 11/11/2020 (Earlier FSC issued namely Dream Bell Banquet A unit of S.S Banquet)
5. Fire Safety directives letter No	F6/DFS/MS/2019/7917 dated 30/12/2019
6. Date of inspection	20/07/2023
7. Name of the Inspecting Officers	Sarabjeet Singh ADO (MN)
8. Name and designation of officers from the building side	Sh. Ankit Singh
9. Year of Construction	2019 (As per prev. insp. report dated 22/10/2020)
10. Applicant's letter No.	Online Application ID No. 2021092322362 dated 10/07/2023

* The said banquet hall running at Ground Floor, First Floor & Second Floor in a building comprised of Basement + Ground + Mezzanine + 02 Upper Floors.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Required as per Rule 35(6) of DFS Rule 2010	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	09 m	Provided	MR
	• Gate width	5m	On Road	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	Provided	MR
	• Basements	02	Provided	MR
	b. Width of staircases			
	• Upper Floors	1x2m, 1x1.5m	1x2m (Iron Stair), 1x1.5m	MR
	• Basements	1x2m, 1x1.5m	Provided	MR
	c. Protection of exits			
	• Fire check door	Required in basement	Provided in basement	MR
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	01	Provided	MR
	f. Width of Corridor	NA	NA	NA
	g. Door Size	1x2m, 1x1.5m	Provided	MR
3	Compartmentation.			
	• Fire check door	Required in basement	Provided	MR
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	08 nos.	Provided	MR
	• Types	CO ₂ , ABC type	Provided	MR
	• IS marking	ISI marked	Provided	MR

6	First-Aid Hose Reels.			
	• Total numbers on each floor	01	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7	Automatic fire detection and alarming system.			
	• Type of detectors	Required	Provided	MR
	• Location of Main Panel	Required	Provided	MR
	• Location of Repeater Panel	Required	Provided	MR
	• Alternate source of power	Required	Provided	MR
	• Hooters' Location	Required	Provided	MR
8	MOEFA	Required	Provided	MR
9	Public Address System.	NR	NR	NR
10	Automatic Sprinkler System.			
	• Basement	Required	Provided	MR
	• Upper Floor	NR	Provided	NR
	• Sprinkler above false ceiling	NA	NA	NA
11	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided	MR
	• Number of hydrants per floor	01	Provided	MR
	• Hose Box	01	Provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	NA	NA	NA
	• Hose Box	NA	NA	NA
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	2280lpm	Provided	MR
	➤ Head of Main pump	70m	Provided	MR
	➤ Number of main pumps	01	Provided	MR
	➤ Jockey Pump out put	180lpm	Provided	MR
	➤ Jockey pump head	70m	Provided	MR
	➤ Standby Pump out put	2280lpm	Provided	MR
	➤ Standby Pump Head	70m	Provided	MR
	➤ Auto Starting/ Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	900lpm	Provided	MR
	➤ Head of the pump	40 m	Provided	MR
	➤ Power Supply	Required	Provided	MR
	➤ Auto Starting of pump	Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	2,00,000ltr	Provided	MR
	➤ Draw-off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	10,000 ltrs	Provided	MR
15	Exit Signage.	Required	Provided	MR

~4

16	Provision of Lifts. Lift will run from Ground to Upper floors			
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication In lift Car	Required	Provided	MR
	• Fireman's Grounding Switch	Required	Provided	MR
	• Lift Signage	Required	Provided	MR
17	Standby power supply	Required	Provided	MR
18	Refuge Area.			
	➤ Total Area	NA	NA	NA
	➤ Location	NA	NA	NA
19	Fire Control Room			
	• Detector System Panel	NA	NA	NA
	• Flow Switch Panel	NA	NA	NA
	• PA System Panel	NA	NA	NA
	• Batter backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire fighting arrangements provided in the building/banquet were checked & found functional at the time of inspection.

Keeping in view of the deemed compliance of minimum standards of fire prevention and fire safety measures as required under the rules, the NOC vide letter no F6/DFS/MS/WZ/2020/487 dated 11/11/2020 renewal under the rule 35 of the Delhi Fire Service rules 2010 is recommended.

100 L/1000/mk
dt. 24/7/2023

(Signature)
24/7/2023

(Signature)
24/7/23

Signature of the Inspecting Officer
Name: Sarabjeet Singh
Designation: ADO (MN)

(Signature)
24/7/2023
DCO (MKC)

(Signature)
25/7/2023

(Signature)
26/07/23

(Signature)
ADP/MN

FT PS

Sir. F. T is put up for your kind personal & signature please.

(Signature)
24/7/2023