



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2023/School/ 495

Dated: 21/07/2023

FIRE SAFETY CERTIFICATE

Certified that the **G.D. Goenka Public School Junior (Bright Educational Society)** located at **B-Block, Main Road, Derawala Nagar, Delhi-110009** comprised of **Basement + Ground floor & 02 upper floors only** owned/ occupied by the **G.D. Goenka Public School Junior (Bright Educational Society)** was issued FSC by this department vide letter **F6/DFS/MS/2020/WZ/School/429 Dated 15.10.2020**. The premise was inspected by the officer concerned of this department on **12.07.2023** in the presence of **Mr. Adhir Sachdeva** and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rules 33 of the Delhi Fire Service Rules, 2010 and building premises is fit for occupancy class **"Group B" Educational** with effect from **.21.07.2023....** for a period of **Valid up to 31.03.2026** in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on **.21.07.2023.....** at New Delhi

(Signature)
 Atul Garg)
 Director

Ph:-011-23414000

Copy to: -

1. The Director, Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, G.D. Goenka Public School Junior (Bright Educational Society) located at B-Block, Main Road, Derawala Nagar, Delhi-110009.

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doi/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in **Form 'J'** [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : G.D. Goenka Public School Junior (Bright Educational Society) located at B-Block, Main Road, Derawala, Nagar, Delhi-110009.
2. Type of Occupancy : Educational
3. Composition of building : Basement, ground & 02 upper floors only
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/2020/WZ/School/429 Dated: 15.10.2020
6. Fire Safety directives letter No : NBC Part-4
7. Date of inspection : 12.07.2023
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers from the building side : Sh. Adhir Sachdeva
10. Year of Construction : 2010-2015
11. Applicant's letter No. : Letter No. Nil DFS Dairy No-3113 dated: 23.06.2023

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part 4 Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	Accessible	MR
	• Gate width	Accessible	Accessible	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	02	02	MR
	• Basements	02	02	MR
	b. Width of staircases			
	• Upper Floors	1.50m each	1.5m each	MR
	• Basements	1.50m & one ramp	1.50m & one ramp	MR
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01	01	MR
	e. Width of Corridor	Required	Provided	MR
	f. Door Size	1m	1.10 m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	Required	Provided	MR
	• Upper floors	Required	Provided	MR
5	Fire Extinguishers			
	• Total numbers	09nos	010nos	MR
	• Types	ABC/WCO2	ABC—07 WCO2-03	MR
	• ISI marking	ISI Marked	Yes	MR
6	First-Aid Hose Reels.			

	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01	01	MR
		30m	30m	MR
		5mm	5mm	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
8	MOEFA	NA	NA	NA
9	Public Address System.	Required	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	Required	Provided	MR
		NA	NA	NA
		NA	NA	NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA	NA	NA
		NA	NA	NA
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		N/A	N/A	N/A
		900 LPM	900 LPM	MR
		40m	40m	MR
		Required	Provided	MR
		Required	Provided	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity <ul style="list-style-type: none"> Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		NA	NA	NA
		10,000 LTR	Provided	MR
		Required	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft 	N/A	N/A	N/A

	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in NBC Part 4, the FSC issued vide letter of even no. F6/DFS/MS/2020/WZ/School/429 dated 15.10.2020 renewal under rule 35(6) of the Delhi Fire Service Rules, 2010 is recommended.

[Signature]
14/07/2023
D.B. Mukharjee
Divisional Officer (NWD)

[Signature]
14/7/23
Signature of the Inspecting Officer
Name:- R.K. Sinha
Designation:- Asst. Div. Officer (RN/BW)

[Signature]
17/7/2023
C/o Bhugh

[Signature]
18/07/23
Director

[Signature]
18/07/23
Sgt. Clerk

[Signature]
18/07/23
Any one

[Signature]
18/07/23
Sgt. Clerk

[Signature]
18/07/23
Director