

FORM 'H'  
FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[Refer sub - rule (1) of rule 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI

No. F6/DFS/MS /SZ/2023/ 366

Dated: 28/07/2023

**FIRE SAFETY CERTIFICATE**

Certified that the building **GGSIIP University** Located at **Sector 16 C, Dwarka, New Delhi.**  
**Administrative Blocks** (02 buildings comprised of G +1 upper floor & G+02 upper floor) **Library Block** (comprised of B+G+2 UFs) **School Building S-1** (Namely BL-A & B comprised of G+5 UFs) was issued Fire Safety Certificate vide letter No. F6/DFS/MS/2020/SZ/319 dated 20/08/2020. The premises was re - inspected by the officer concerned of this department on 19/07/2023 in the presence of Sh. Deepesh Singh Bhati A.E(E) & his team and observed that all the fire prevention and fire safety arrangements provided in the premises found in good working condition. The premises have therefore deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules 2010 and that the premises is fit for occupancy class "Educational" **Group B** with effect from 28/07/2023 for a period of three years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 28/07/2023 at New Delhi by.

  
(Atul Garg)  
Director  
Delhi Fire Service  


Copy to:

1. The Registrar (E&S), GGSIPU, Sector-16-C, Dwarka, New Delhi-110078.
2. The Astt. Registrar to the Hon'ble Vice Chancellor, GGSIPU, Sector-16-C, Dwarka, New Delhi-110078.
3. The Executive Engineer (UWD, GGSIPU) University Works Division, Ground Floor, Library Block, Guru Gobind Singh Indraprastha University, Sector 16-C, Dwarka New Delhi-110078.

**Following fire safety directives must be adhered to:-**

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk and responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviations w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for the regularization of the unauthorized construction, if any.
6. Basement shall be used strictly as per building bye laws.
7. The owner/occupier shall submit a declaration every year in the form 'K' provided in the first schedule of Delhi Fire Service Rules 2010, form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
8. The owner/ occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this certificate, six months prior to its expiry.



## INSPECTION REPORT

1. Name & address of the building: GGSIP University Located at Sector 16C, Dwarka, New Delhi.
2. Type of Occupancy : Educational Cum Business
3. Type of Case : Renewal ( Admin BL, Library BL & 02 School building)
4. Details of previous NOC : F6/DFS/MS/2020/SZ/319, dated 20/08/2020
5. Fire Safety directives L. No. : F6/DFS/MS/BP/2006/1208, dated 25/05/2006
6. Date of inspection : 19/07/2023
7. Name of the Inspecting Officer : ADO (DWK)
8. Name and designation of Officer  
from the building side : Sh. Deepesh Singh Bhati A.E(E) & his team
9. Year of Construction : 2006
10. Applicant's letter No. : GGSIPU/UWD/2023/106, dated-23/06/2023

S No	Minimum standards on fire prevention and fire safety U/R 33	Requirement As per N/58, N/59 & N/60	Provided at site	Remarks MR/NMR
1.	Access of building			
	• Road width	12 mtrs	Provided	MR
	• Gate width	05 mtrs	Provided	MR
	• Width of internal road	06 mtr	Old case	MR being old case
2.	Number, width, Type & Arrangements of exits			
	a. Number of staircases			
	• Upper floors	02 No's each block	Provided	MR
	• Basements	2 Nos. Library Block	Provided	MR
	b. Width of staircases			
	• Upper floors	1.5mtr each	Old case	MR being old case
	• Basements	1.5mtr each	Old case	MR being old case
	c. Protection of exits			
	• Fire check door	Required	Provided	MR
	• Pressurization	NA	NA	NA
	d. No of continuous staircase to terrace	2 Nos. each block.	Provided	MR
	e. Width Of Corridor	1.5 m	Old case	MR being old case
	f. Door Size	NA	NA	NA
3.	Compartmentation			
	• Fire check door	Required	Provided	MR
	• Sealing of electrical shafts	Required	Sealed	MR
	• Fire Rating of shaft door	2 Hrs. Rating	Provided	MR
	• Water Curtain	NA	NA	NA
	• Fire Dampers	Required	Provided	MR
4.	Smoke managements System			
	• Basements	Required	Provided (Mechanical Ventilation)	MR
	• Upper floors	Required	Natural Ventilation	MR






5.	Fire Extinguishers			
	• Total numbers	02 nos each floor	Provided	MR
	• Types	WCO2 & CO2	Provided	MR
	• IS marking	ISI marked	Provided	MR
6.	First – Aid Hose Reels			
	• Total numbers on each floor	02 no each floor	Provided	MR
	• Length of hose reel hose	30m	Provided	MR
	• Nozzle diameter	5mm	Provided	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	NA	Provided	NA
	• Location of Main Panel	Ground floor	Provided	MR
	• Location of Repeater Panel	Control Room	Provided	MR
	• Alternate source of power	Required	UPS/Battery Backup	MR
	• Hooters' Location	Appropriate Places	Provided	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	• Basements	Required	Provided	MR
	• Upper Floor	NA	NA	NA
	• Sprinkler above false ceiling	NA	NA	NA
11.	Internal Hydrants:			
	• Size of riser/down- comer	150 mm	Provided	MR
	• Number of hydrants per floor	02 Nos.	Provided	MR
	• Hose Box	Required	Provided	MR
12.	Yard Hydrants			
	• Total number of hydrants	08 Nos.	Provided	MR
	• Hose Box	Required	Provided	MR
13.	Pumping Arrangements: ( Common with all school building)			
	• Ground Level	2850 Lpm	Provided	MR
	• Discharge of main pump	70 mtr	Provided	MR
	➤ Head of main pump	2	Provided	MR
	➤ Number of main pumps	180 LPM	Provided	MR
	➤ Jockey pump out put	70 mtr	Provided	MR
	➤ Jockey pump head	2850 LPM	Provided	MR
	➤ Standby Pump out put	70 mtr	Provided	MR
	➤ Standby Pump Head	Required	Provided	MR
	➤ Auto Staring/Manual stopping	Required	Provided	MR
	➤ Pump House Access	Required	Provided	MR
	• Terrace level			
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto starting of pump	NA	NA	NA
14.	Captive water Storage for fire fighting:			
	• Under ground tank capacity	2,00,000 ltr	Provided	MR old Case
	➤ Draw off connection	Required	Provided	MR
	➤ Fire service inlet	Required	Provided	MR
	➤ Access to tank	Required	Provided	MR
	• Overhead Tank capacity	25,000 Ltr each block.	Provided	MR
15	Exit Signage	Required	Provided	MR

N/85

16.	Provision of Lifts			
	➤ Pressurization of Lift Shaft	NA	NA	NA
	➤ Pressurization of lift lobby	NA	NA	NA
	➤ Communication in lift Car	Required	Provided	MR
	➤ Fireman's Grounding Switch	Required	Provided	MR
	➤ Lift Signage	Required	Provided	MR
17.	Standby power supply	Required	Provided	MR
18.	Refuge Area			
	➤ Total area	NA	NA	NA
	➤ Location	NA	NA	NA
19.	Fire control room			
	➤ Detector system panel	Required	Provided	MR
	➤ Flow Switch Panel	NA	NA	NA
	➤ PA System Panel	Required	Provided	MR
	➤ Battery backup	Required	Provided	MR
	➤ Building Floor Plans	Required	Provided	MR
20.	Special Fire Protection Systems for Protection of special Risks, if any;	Required	CO2 fire extinguisher provided near electric panels	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the deemed compliance of minimum standards on fire prevention and fire safety as required under the rules the FSC issued vide letter No F6/DFS/MS/2020/SZ/319, dated 20/08/2020 renewal under Rule 37 of the Delhi Fire Service Rules 2010 is recommended.

~~20/8/23~~  
Signature of the Inspecting Officer

Name:

Designation:

~~20/8/23~~  
20/8/23

CFO(S2)  
20/8/2023

Director  
21/8/23

21/8/23