



GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001



No. F6/DFS/MS/2023/School/ 497

Dated: 21/07/2023

FIRE SAFETY CERTIFICATE

Certified that the Lilawati Vidya Mandir Sr. Sec. School located at Shakti Nagar, Delhi-110007 comprised of 03 blocks (Ground+03 upper floors, Ground+02 upper floors & Ground+ first floor only) owned/ occupied by Lilawati Vidya Mandir Sr. Sec. School was issued Fire Safety Certificated vide this office letter no. F6/DFS/MS/2020/WZ/375 dated 29.09.2020. The premise was re-inspected by the officer concerned of this department on 12.07.2023 in the presence of Mr. Vinit Sharma and found that the said premises have deemed complied with the fire prevention and fire safety requirements in accordance with Rules 33 of the Delhi Fire Service Rules, 2010 and building premises is fit for occupancy class "Group B" Educational with effect from ..21/07/2023... for a period of Valid up to 31.03.2026 in accordance with the rule 36 unless renewed under rule 37 or sooner cancelled under rule 40, subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010,

Issued on ..21/07/2023.... at New Delhi

Atul Garg)
Director

Ph:-011-23414000

Copy to :-

1. The Director of Education, Government of N.C.T of Delhi. Old Sectt. Delhi - 110054.
2. The Principal, Lilawati Vidya Mandir Sr. Sec. School at Shakti Nagar, Delhi-110007

Conditions for the validity of Fire Safety Certificate:

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in./wps/wcm/connect/doit fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration (Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, six months prior to its expiry".

INSPECTION REPORT

1. Name & address of the building : Lilawati Vidya Mandir Sr. Sec. School at Shakti Nagar, Delhi-110007.
2. Type of Occupancy : Educational
3. Type of Case : Renewal
4. Composition of building : 03 blocks (Ground +03 floor, Ground+02 floor & Ground + first floor only)
5. Details of previous NOC : F-6/DFS/MS/2020/WZ/375 dated 27.08.2020
6. Fire Safety directives letter No : F6/DFS/MS/BP/98/1161 dated 22.06.1998 (Ground+03 upper floors)
F6/DFS/MS/BP/94/779 dated 20.05.1994 (Ground+02 upper floors)
7. Date of inspection : 12.07.2023
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers
from the building side : Mr. Vinit Sharma
10. Year of Construction : 1974, 1994-1998
11. Applicant's letter No. : Letter No. DE/15(1391)/Misc./North/2023/5734-5737 dated 26.06.2023

	Minimum Standards on fire prevention and fire safety U/R 33	NBC Part-IV Requirements	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	06m	10m	MR
	• Gate width	5m	5m	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	03- S/c in J block 02 S/c in L Block 02 S/c in Activity block	Provided	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	1.50m	1.50m x 02 & 1.25m- S/c in Jblock, 1.50m x 02- S/c in L Block 1.50m x 02- S/c in Activity block	MR(old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	01 each block	Provided	MR
	e. Width of Corridor	1.20m	Provided	MR
	f. Door Size	1.00 m	1.10 m	MR
3	Compartmentation.			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	Smoke Management System.			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilated	MR
5	Fire Extinguishers			
	• Total numbers	40nos	48nos	MR

N-32

	<ul style="list-style-type: none"> Types ISI marking 	ABC/Co2	ABC-40 / Co2-08	MR
		ISI Marked	Yes	MR
6	First-Aid Hose Reels.			MR
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	02 30m 5mm	Provided 30m 5mm	MR MR MR
7	Automatic fire detection and alarming system.			NA
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8	MOEFA	NA	NA	NA
9	Public Address System.	NA	Provided	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	NA NA NA	NA NA NA	NA NA NA
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100mm,04 02 02	Provided 02 02	MR MR MR
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	NA NA	NA NA	NA NA
13	Pumping Arrangements			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A 450lpm G+3 & G+2 block 40m Required Required	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A Provided 40m Provided Provided	N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A MR MR MR MR
14	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet 	50,000ltr NA NA	50,000ltr. NA NA	MR NA NA

	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	10,000 ltrs each block	Provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. F6/DFS/MS/2023/School/295 dated 05.06.2023.

Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular / NBC Part 4, the FSC issued vide letter of even no. F6/DFS/MS/2020/WZ/375 dated 29.09.2020 renewal under rule 35(6) of the Delhi Fire Service Rules, 2010 is recommended.

[Signature]
14/07/2023
D.B. Mukharjee
Divisional Officer (NWD)

[Signature]
14/7/23
Signature of the Inspecting Officer
Name:- R.K. Sinha
Designation:- Asst. Div. Officer (RN/BW)

[Signature]
17/7/2023
c/o

Director

[Signature]
17/7/23
For, F.T. letter - *[Signature]*
18/7/23

[Signature]
17/7/23
Director (NWD)