

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS, DELHI FIRE SERVICE, NEW DELHI - 110001**

No.F6/DFS/MS/GH/NDZ/2023/134

Dated: 27/07/2023

**FIRE SAFETY CERTIFICATE**

Certified that the Metropolis Tourist Home Guest House located at 1624-27-34 & 35, Main Bazar, Pahar Ganj, New Delhi is comprised of Ground + 03 Upper floors, Ground floor-reception, 1<sup>st</sup> floor (12 guest rooms), 2<sup>nd</sup> & 3<sup>rd</sup> floor (04 guest rooms at each floor & store/staff room, total 20 guest rooms up to third floor owned/occupied by Metropolis Tourist Home Guest House, was earlier granted FSC by this department vide letter No.F6/DFS/MS/GH/NDZ/2019/229 dated 29/01/19 for 20 guest rooms upto third floor. Now, the premises was re-inspected by the officer concerned of this department on 20/07/23 in the presence of Manager and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class Residential, (Sub Division-A) Ground floor (Reception), 1st floor (12 guest rooms), 2nd & 3rd floor (04 guest rooms at each floor + 02 store/ staff room), total 20 guest rooms up to third floor and valid up to 31.03.2026 from the date of issue in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules 2010, printed below.

Issued. 27/07/2023 at New Delhi by.

  
Addl. Garg)  
DIRECTOR  
Delhi Fire Service

Copy to:-

1. The Commissioner, MCD, Civic Centre, New Delhi. to kindly ensure the occupancy as detailed above.
2. The Addl. Commissioner of Police (Lic), First Floor, P.S. Defence Colony New Delhi online ID No. 2023071612618 dated 16.07.2023.
3. The Manager, Metropolis Tourist Home Guest House at 1624-27-34 & 35, Main Bazar, Pahar Ganj, New Delhi.

**Conditions for the validity of Fire Safety Certificate**

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. The compliance with regards to electrical installation, structural stability, set back area, occupancy and any deviation in construction etc. shall be verified from authority concerned.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in).
7. The means of escape shall be kept unobstructed / unlocked for unhindered evacuation in case of an emergency.
8. The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in form 'J' [sub rule (I) of rule 37] along with a copy of this Certificate, six month prior to its expiry.
9. Any flammable material for interior decoration shall strictly prohibited.

**INSPECTION REPORT**

1. Name & address of the building:- Metropolis Tourist Home Guest House  
at 1624-27-34 & 35, Main Bazar, Pahar Ganj,  
New Delhi
  2. Type of occupancy:- Residential, Sub Division-A-1  
Gr. + 03 Upper floors (total 20 Guest rooms)  
Ground floor ( Reception ),  
1<sup>st</sup> floor ( 12 guest rooms), 2<sup>nd</sup> & 3<sup>rd</sup> floor  
(04 guest rooms at each floor + 02 store room /staff  
room )
  3. Type of case:- Renewal
  4. Details of previous FSC:- No. F6/DFS/MS/GH/NDZ/2019/229 dated  
29/01/19.
  5. Fire safety directives No.- N/A
  6. Date of inspection:- 20/07/23
  7. Name of the inspecting officer:- Sh. Ravinder Singh, (ADO/CC)
  8. Name & designation of officer  
From the building side:- Manager
  9. Year of construction:- 1981
  10. Applicant's letter No:- Online id no. 2023071612618 dated 16.07.2023
- Old Case

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement Existing fire safety arrangements	Provided at site	Remarks MR/NMR
<b>1. Access to Building</b>				
	1) Road width	06	06mtr	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
<b>2. Number, Width Type &amp; Arrangement of Exits</b>				
<b>A. Number of staircases</b>				
	1. Upper floors	01 Nos.	02 Nos.	MR
	2. Basements	N/A	N/A	N/A
<b>B. Width of staircase</b>				
	1. Upper floors	0.80 mtr.	0.86 mtr.	MR
	2. Basements	N/A	N/A	N/A
<b>C. Protection of exits</b>				
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	N/A	N/A	N/A
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	1 mtr.	1 mtr.	MR
<b>3. Compartmentation</b>				
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
<b>4. Smoke Management System</b>				
	1) Basements	30 ACPH	N/A	N/A
	2) Upper floors	12 a/c per	Natural Ventilation	MR

6 50

N/48

<b>5.</b>	<b>Fire Extinguishers</b>			
	1) Total numbers	10 Nos.	10 Nos.	MR
	2) Types	ABC & CO2	ABC & CO2	MR
	3) ISI marking	Required	Provided	MR
<b>6.</b>	<b>First-Aid Hose Reel</b>			
	1) Total number of each floor	01	01	MR
	2) Length of hose reel hose	30 m	30 m	MR
	3) Nozzle diameter	05 mm	05 mm	MR
<b>7.</b>	<b>Automatic Fire Detection &amp; Alarming System</b>			
	1) Type of detectors Co type	Required	Provided	MR
	2) Location of main panel	At ground floor	Provided	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Required	Provided	MR
	5) Hooter's Location	At each floor	Provided	MR
<b>8.</b>	<b>MOEFA</b>	Required	Provided	MR
<b>9.</b>	<b>Public Address System</b>	Required	Provided	MR
<b>10.</b>	<b>Automatic Sprinkler System</b>			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
<b>11.</b>	<b>Internal Hydrants</b>			
	1) Size of riser/down-comer	N/A	N/A	N/A
	2) Number of hydrants per floor	N/A	N/A	N/A
	3) Hose box	N/A	N/A	N/A
<b>12.</b>	<b>Yard Hydrants</b>			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A
<b>13.</b>	<b>Pumping Arrangement</b>			
	1) Ground level	N/A	N/A	N/A
	a) Discharge of main pump	N/A	N/A	N/A
	b) Head of main pump	N/A	N/A	N/A
	c) Number of main pump	N/A	N/A	N/A
	d) Jockey pump out put	N/A	N/A	N/A
	e) Jockey pump head	N/A	N/A	N/A
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	225 LPM	225 LPM	MR
	b) Head of pump	30 mtr	30 mtr	MR
	c) Power supply	Required	Provided	MR
	d) Auto starting of pump	Required	Provided	MR

L. W.

2149

14. Captive Water Storage for Fire Fighting			
1) Under ground tank capacity	N/A	N/A	N/A
a) Draw-off connection	N/A	N/A	N/A
b) Fire service inlet	N/A	N/A	N/A
c) Access to tank	N/A	N/A	N/A
d) Over head tank capacity	2500 ltr.	2500 ltr.	MR
15. Exit Signage.	Required	Provided	MR
16. Provision of Lifts.			
a) Pressurization of lift shaft	N/A	N/A	N/A
b) Pressurization of lift lobby	N/A	N/A	N/A
c) Communication in lift car	N/A	N/A	N/A
d) Fireman's switch	N/A	N/A	N/A
e) Lift signage	N/A	N/A	N/A
17. Stand by Power Supply	Required	Provided	MR
18. Refuge Area	N/A	N/A	N/A
Total area location	N/A	N/A	N/A
19. Fire Control Room	N/A	N/A	N/A
a) Detector system panel	N/A	N/A	N/A
b) Flow switch panel	N/A	N/A	N/A
c) PA system panel	N/A	N/A	N/A
d) Battery backup	N/A	N/A	N/A
e) Building floor plan	N/A	N/A	N/A
20. Special Fire Protection System for Protection of special Risk, if any:			NA

The fire protection systems provided in the guest house building were randomly tested, checked and found functional at the time of inspection.

In view of the deemed compliance of the minimum standards of fire prevention and fire safety measures as required under the rules, if approved, we may renew the FSC issued vide letter no F6/DFS/MS/GH/NDZ/2019/229 dated 29/01/19, up to third floor only under rule 35 of the Delhi Fire Service rules 2010. Accordingly, DFA is put up for kind perusal and signature please.

Signature of the Inspecting Officer

Name: Ravinder Singh  
Designation: ADO (CC)

~~DO/CO~~

~~[Signature]~~  
24/7

~~[Signature]~~  
C.F/O.

~~[Signature]~~  
24/07/23

~~[Signature]~~  
24/7/2023

~~[Signature]~~  
25/7/22

AD/CC