



C-30

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI- 110001**

No. F6/DFS/MS/2023/School/ 494

Dated: 21/07/2023

**FIRE SAFETY CERTIFICATE**

Certified that the **Uttranchal Public School** located at **Kamal Pur, Burari, Delhi-110084** comprised of **Ground & 03 upper floors only** owned/ occupied by **Uttranchal Public School** was issued Fire Safety Certificated vide this office letter no. **F-6/DFS/MS/2020/School/151** dated **13.04.2020**. The premise was re-inspected by the officer concerned of this department on **12.07.2023** in the presence of **Sh. Sanjay (Principal)** and found that the said premises have deemed complied with the fire prevention and fire safety requirements of circular issued by Director of Education vide letter no 262-362 dated 17.01.2005 and the building/ premise is fit for occupancy class **"Group B Educational"** with effect from **21/07/2023**... for a period of **Valid up to 31.03.2026**, subject to compliance of the conditions mentioned below:

Issued on **21/07/2023**..... at New Delhi

Atul Garg)  
Director  
Ph:-011-23414000

Copy to :-

1. The Director of Education, Government of N.C.T of Delhi, Old Sectt. Delhi - 110054.
2. The Principal, Uttranchal Public School located at Kamal Pur, Burari, Delhi-110084.

**Conditions for the validity of Fire Safety Certificate:**

1. All the means of escape/entry/exit shall be kept free from any obstruction.
2. All the fire safety arrangements provided therein shall be maintained in good working condition at all time as seen during inspection.
3. Any loss of life or property due to non-functional fire safety measures shall be at the responsibility of the management.
4. All the staff members must know the correct method of operation of firefighting system.
5. The owner / occupier shall submit a declaration **every year** in **Form "K"** provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on <http://delhi.gov.in/wps/wcm/connect/doit/fire/FIRE/Home/Forms>.
6. This fire safety certificate may not in any way be treated as regularization (Clause 2.8 of UBBL-2016) of unauthorized construction or Alteration ( Clause 1.4.3 of UBBL-2016), if any.
7. "The owner/occupier shall apply for renewal of this Fire Safety Certificate to the Director in Form 'J' [sub rule (1) of rule 37] along with a copy of this Certificate, **six months** prior to its expiry".

### INSPECTION REPORT

1. Name & address of the building : Uttranchal Public School, Kamal Pur, Burari, Delhi-110084.
2. Type of Occupancy : Educational
3. Composition of building : Ground & 03 upper floors only
4. Type of Case : Renewal
5. Details of previous NOC : F6/DFS/MS/2020/School/151 dated 13.04.2020
6. Fire Safety directives letter No : Director of Education dated 17.01.2005
7. Date of inspection : 12.06.2023
8. Name of the Inspecting Officers : ADO (RN)
9. Name and designation of officers  
from the building side : Sh. Sanjay (Principal)
10. Year of Construction : 2009
11. Applicant's letter No. : Letter No. HM/UPS/2023 Dated 21.02.2023

	Minimum Standards on fire prevention and fire safety U/R 33	Requirement as per Rule 35 (6)	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	06m	Provided	MR
	• Gate width	Old case	2.6m	MR
	• Width of internal road	NA	NA	NA
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	01	02	MR
	• Basements	NA	NA	NA
	b. Width of staircases			
	• Upper Floors	Old case	1.00m-iron staircase & 90cm	MR(old case)
	• Basements	NA	NA	NA
	c. Protection of exits			
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	d. No. of continuous staircases to terrace	Old case	01	MR
	e. Width of Corridor	NA	NA	NA
	f. Door Size	1.0m	1.0m	MR (old case)
3	<b>Compartmentation.</b>			
	• Fire check door	NA	NA	NA
	• Sealing of electrical shafts	NA	NA	NA
	• Fire Rating of shaft door	NA	NA	NA
	• Water Curtain	NA	NA	NA
	• Fire Dampers	NA	NA	NA
4	<b>Smoke Management System.</b>			
	• Basements	NA	NA	NA
	• Upper floors	Required	Natural Ventilation	MR
5	<b>Fire Extinguishers</b>			




	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>ISI marking</li> </ul>	06nos ABC/Co2 Yes	08nos ABC--8 Yes	MR MR MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	01 30m 5mm	Provided Provided Provided	MR MR MR
7	<b>Automatic fire detection and alarming system</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>	NA NA NA NA NA	NA NA NA NA NA	NA NA NA NA NA
8	<b>MOEFA</b>	NA	NA	NA
9	<b>Public Address System.</b>	NA	NA	NA
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	NA NA NA	NA NA NA	NA NA NA
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>	NA NA NA	NA NA NA	NA NA NA
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	NA NA	NA NA	NA NA
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> <li>Power Supply</li> <li>Auto Starting of pump</li> </ul> </li> </ul>	 N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A 450lpm 40m Required Required	 N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A 450lpm 40m Provided Provided	 N/A N/A N/A N/A N/A N/A N/A N/A N/A N/A MR MR MR MR
14	<b>Captive Water Storage for fire fighting.</b>			
	<ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>Draw-off connection</li> <li>Fire service inlet</li> </ul>	NA NA NA	NA NA NA	NA NA NA


N-24


	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	5,000ltrs	Provided	MR
		Required	Provided	MR
15	Exit Signage.			
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	N/A
	• Pressurization of Lift lobby	N/A	N/A	N/A
	• Communication In lift Car	N/A	N/A	N/A
	• Fireman's Grounding Switch	N/A	N/A	N/A
	• Lift Signage	N/A	N/A	N/A
17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	N/A
	• Flow Switch Panel	N/A	N/A	N/A
	• PA System Panel	N/A	N/A	N/A
	• Batter backup	N/A	N/A	N/A
	• Building Floor Plans	N/A	N/A	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were tested/ checked randomly and found in working condition at the time of inspection. The management has complied all the shortcomings issued and communicated by this department vide letter of even no. F6/DFS/MS/2023/School/265 dated 22.05.2023.


Keeping in view the satisfactory compliance of the minimum standards on fire prevention and fire safety required as stipulated in Director of Education Circular issued vide letter of even no. F6/DFS/MS/2020/School/151 dated 13.04.2020 renewal under rule 35(6) of the Delhi Fire Service Rules, 2010 is recommended.


  
D.B. Mukharjee  
Divisional Officer (NWD)

  
Signature of the Inspecting Officer  
Name:- R.K. Sinha  
Designation:- Asst. Div. Officer (RN/BW)

  
17/7/2023

  
10/7/23

  
29/7/23

  
18/7/23